

PHPP

BRIEF INSTRUCTIONS

Copyright
PHPP 1998-2013
Passive House
Institute, Darmstadt,
Version 9.0 beta

For use in EuroPHit, c

Place your mouse here to see the PHPP help.

If no help appears when the mouse passes over cell B4, you can activate it by going into the Menu Bar Tools/Options/View, and under "Comments", select "Comment Indicator Only".

Passive House Verification: Meaning of Field Formats

Example	Field Format	Meaning
78,8	Courier New, blue, bold on yellow background	Input Field: Please enter the required value here
01ud tripple-low-e-cr08	Arial Narrow, blue, bold on brown	Data entry field with drop down list
6619	Arial, black, standard on white background	Calculation field; please do not change
78,8	Courier New, purple, bold on white background	Field with references to another sheet - should not be changed.
126,0	Arial, black, large & bold on green background	Important result

Passive House Planning: Worksheet Directory

Worksheet name (to show/hide worksheets please use the separate 'Profile settings' tool)	Function	Brief Description	Required for the certification?
Verification	Building data; summary of results	Building description, selection of the calculation method, summary of results	yes
Overview	Overview of the specific data of the project entered	In-depth project description, overview of all results and input variables, specific details on building envelope, building services systems as well as general information.	no
Variants	Variant calculation	Input parameters and results for the variant calculations. Predefined fields for frequent entries, as well as user-defined area.	no
Comparison	Comparison between two variants	Comparison between two variants under the energy demand and economic viability perspective. Input of comparison configurations.	no
Climate	Climate Region Selection or Definition of User Data	Climate data for: Annual Heating, Windows, Heating Load, Heating, Summer, Cooling, Cooling Units, Cooling Load worksheets	yes
U-Values	Calculation of Standard building assembly U-Values	Heat transmission coefficient calculations in accordance with DIN EN ISO 6946.	yes
Areas	Areas summary	Building assembly Areas, Thermal Bridges, Treated Floor Area. Use exterior dimension references!	yes
Ground	Calculation of reduction factors against ground	More precise calculation of heat losses through the ground	if applicable
Components	Building component database	Database of certified, Passive House suitable components and entry of user-defined components	yes
Windows	U _w -Value Determination	Input of geometry, orientation, frame lengths, frame widths, U _g and U-values of the frame, and the thermal bridge heat loss coefficients of the connections; from these inputs, determine U _w and total radiation.	yes
Shading	Determination of shading coefficients	Input of shading parameters, e.g. balcony, neighbouring building, window reveal and calculating the shading factors	yes
Ventilation	Air Flow Rates, Exhaust/Supply Air Balancing, Pressurization Test Results	Sizing the ventilation system from extract and supply air requirements, infiltration air change rate and actual efficiency of heat recovery; input of pressurization test results	yes
Additional Vent	Design and planning of ventilation systems with diverse ventilation units	Extension of the Ventilation worksheet for dimensioning air flows, for special building uses and systems with various ventilation units	if used
Annual heating	Annual heating demand / Annual Method	Calculation of the annual space heating demand according to the energy balance method following EN 13790: Transmission + Ventilation - h (Solar Gains + Internal Gains)	no
Heating	Space heating demand calculation Monthly method according to EN 13790	Calculation procedure for the monthly method following EN 13790. Make appropriate selection in the Verification worksheet, if calculations should be performed following this procedure	yes
Heating Load	Building Heating Load Calculation	Calculation of the nominal heating load using a balance procedure for the design day: max transmission + max ventilation - η (minimum solar gains + internal heat gains)	yes
SummVent	Determination of Summer Ventilation	Ventilation in cooling case and estimation of air flow rates for natural ventilation during the summer period	yes
Summer	Assessment of Summer Climate	Calculation of the frequency of overheating as a measure of summer comfort	yes
Cooling	Monthly Method for Cooling Demand	Annual useful cooling demand calculation	if present
Cooling units	Latent Cooling Energy	Calculation of the energy demand for dehumidification and choice of cooling method	if present
Cooling load	Building Cooling Load Calculation	Calculation of the daily average cooling load of the building	no
DHW+Distribution	Distribution losses; DHW Requirement and Losses	Heat loss calculation of the distribution systems (heating; DHW); calculation of the useful heat requirement of DHW and storage losses	yes
SolarDHW	Solar DHW Heating	Solar contribution calculation for DHW and space heating contribution	if solar panels are used
PV	Electricity generation by photovoltaic	Electricity generation calculation of PV system	no
Electricity	Electricity Demand for Dwellings	Calculation of the electricity demand of Passive Houses with residential use	yes
Use non-res	Patterns of non-residential Utilisation	Input or selection of utilisation patterns for planning of electricity demand and internal heat gains	no
Electricity non-res	Electricity Demand for non-residential Use	Calculation of the electricity demand for lighting, electric devices and kitchens for non-residential buildings	no
Aux Electricity	Auxiliary Electricity Demand	Calculation of auxiliary electricity and corresponding primary energy demand	yes
HG	Internal Heat Gains in Dwellings	Calculation of the internal heat gains based on the Electricity and Aux Electricity sheets.	no
HG non-res	Internal Heat Gains for non-residential Use	Calculation of the internal heat gains for non-residential buildings based on the Electricity non-res worksheet and the occupancy	no
PE-Value	Specific Primary Energy and CO ₂ Demands	Selection of heat generators, calculation of the specific primary energy and CO ₂ demands from the present results	yes
Compact	Efficiency of Heat Generator Compact Heat Pump Unit	Calculation of combined heat generation efficiency for heating and DHW only by means of a electric heat pump compact unit, considering the specific project boundary conditions.	if present
HP	Heat generation efficiency of the heat pump	Calculation of heat generation efficiency for one to two electric-run heat pumps, considering the specific project boundary conditions.	if present
HP Ground	Ground probe or ground collector in combination with a heat pump	Heat source calculation for a ground probe or horizontal subsoil heat exchanger for ground-coupled heat pumps, considering the specific project boundary conditions.	if present
Boiler	Efficiency of Heat Generator Boiler	For the calculation of the efficiency of heat generation with standard boilers (NT and calorific boilers) for the project given boundary conditions.	if present
District Heating	District Heat Transfer Station	Calculation of the final and primary energy demands (heat)	if present
Data	Database	Table of primary energy factors following [GEMIS] and database of EnEV (German energy efficiency regulation).	no

EnerPHit verification



Building: **Primary School 8 "Sveti Sveti Kiril i Metodii"**
 Street: **69 Mogilov blv.**
 Postcode/City: **Gabrovo**
 Country: **Bulgaria**
 Building type: **School**
 Climate: **Велико Търнов**

Altitude of building site (in [m] above sea level): **426**
 Home owner/client: **Municipality of Gabrovo**
 Street: **3 Vazrazhdane square**
 Postcode/City: **Gabrovo**

Architecture:		Mechanical System:	
Street:		Street:	
Postcode/City:		Postcode/City:	
Energy consulting:		Certification:	
Street:		Street:	
Postcode/City:		Postcode/City:	
Year of Construction:	2014	Interior temperature winter [C°]	20,0
Number of dwelling units:	1	Internal heat gains winter [W/m²]	2,8
Number of Occupants:	680,0	Interior temp. summer [C°]	25,0
Exterior vol. V _e :	15290,3 m³	IHG summer [W/m²]	2,8
		Spec. capacity [Wh/K per m² TFA]	204
		Mechanical cooling:	

Specific building demands with reference to the treated floor area				
	Treated floor area		Requirements	Fulfilled?*
Space heating	Annual heating demand	17 kWh/(m²a)	25 kWh/(m²a)	yes
	Heating load	13 W/m²	-	-
	Overall specific space cooling demand	kWh/(m²a)	-	-
Space cooling	Cooling load	W/m²	-	-
	Frequency of overheating (> 25 °C)	3,1 %	-	-
	heating, cooling, ventilation, DHW, auxiliary electricity, lighting, elect.	90 kWh/(m²a)	123 kWh/(m²a)	yes
Primary Energy	DHW, space heating and auxiliary electricity	63 kWh/(m²a)	-	-
	Specific primary energy reduction through solar electricity	kWh/(m²a)	-	-
Airtightness	Pressurization test result n ₅₀	1,0 1/h	1 1/h	yes

* empty field: data missing; -: no requirement

I confirm that the values given herein have been determined following the PHPP methodology and were determined based on the characteristics of the building. The PHPP calculations are attached to this application.

EnerPHit building retrofit (acc. to heating demand)?

yes

Name:

Company:

Registration number PHPP:

Surname:

Issued on:

Signature

Basic data		
Building, name of the object	Primary School 8 "Sveti Sveti Kiril I Metodi" -	
Street:	69 Mogilov blv.	
Postcode/City:	Gabrovo	
Country:	Bulgaria	
Building type:		
Climate: region / climate data set	User Data	User data - Berr
Climate: degree days / altitude	77 kKh/a	426
Building type / building status	School University	
Context of urban development	Urban development	
Building type / construction	EnerPHit building retrofit (acc. to heating demand)	
Building category, in terms of energy	EnerPHit-i	
Year of construction / year of construction of existing building	2014	1970, 0
Amount of dwelling units for residential use / non-residential use	Dwelling units	46
Number of occupants standard / planned	P	680
Standard / design occupancy rate	m²/P	7
Home owner / client	Municipality of Gabrovo	
Architect		
Building services		
PHPP/Energy balance		
Building physics		
Structural engineering		
Contractor / tradesperson / other (max. 5000 characters)		
Interior temperatures winter/summer	20 °C	25
IHG winter / summer	2,8 W/m²	2,8
Type of certification	EnerPHit building retrofit (acc. to heating dem	
Project certification / Certificate ID		
Certification body		
PHPP-version / PHPP-registration number	Version 9.0 beta	
Characteristic value according to EnerPHit verification		
Treated floor area A_{TFA} / exterior volume V_e	4630, 41 m²	15290, 25
Space heating demand	Specific Demand	Requirement
Heating load residential	17 kWh/(m²a)	25
Heating load Non-residential	13 kWh/(m²a)	-
Frequency of overheating	3 %	Recommendation: < 10%
Overall specific space cooling demand	kWh/(m²a)	-
Cooling load residential	kWh/(m²a)	-
Cooling load non-residential	13 kWh/(m²a)	-
Airtightness pressure air exchange rate test n_{50}	1,0 1/h	1
Total PE Value	90 kWh/(m²a)	123
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances		
Specific PE Demand - Mechanical System / CO ₂ -Equivalent	63 kWh/(m²a)	15
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)		
Solar power: Primary energy savings / CO ₂ emissions		

Average building quality		
	Specific Demand	Requirement
Average U-value of external insulation to outside air	0,14 W/(m²K)	-
Average U-value of external insulation to ground	1,76 W/(m²K)	-
Average U-value interior insulation to outside air		-
Average U-value interior insulation to ground	3,18 W/(m²K)	-
Average U-value of thermal bridges ΔU	0,00 W/(m²K)	-
Average U-value windows	0,97 W/(m²K)	-
Average U-value of exterior doors	2,20 W/(m²K)	-
Ventilation system eff. heat recovery efficiency	80,83 %	-

Building envelope and site		
Building envelope area A_{total} / treated floor area A_{TFA}	7287 m²	4630
A/V-ratio / Envelope area use ($A_{\text{total}}/A_{\text{TFA}}$)	0,48	1,57
Window area / Window area percentage	1248 m²	17,1%
Specific solar aperture / Passive solar heating mode	2,4%	47346
Building site area / built-up area		
Gross floor area BGF / Gross external volume BRI		
Floor space ratio / Amount of complete storeys		
Building description (max.5000 characters)		

Opaque building components			
Exterior wall: U-value (average value) / area	0,14	W/(m²K)	2553,98
Standard exterior wall: U-value / thickness		W/(m²K)	0,0
Standard exterior wall: total area / area fraction		W/(m²K)	
Standard exterior wall: name / certified?			
Standard exterior wall: short description (materials, manufacturer, product name, special features)			
Exterior wall against ground: U-value (average value) / area	0,18	W/(m²K)	362,08
Standard exterior wall against ground: U-value / thickness		W/(m²K)	0,0
Standard exterior wall against ground: area / area fraction		W/(m²K)	
Standard exterior wall against ground: name / certified?			
Standard exterior wall against ground: short description (materials, manufacturer, product name, special features)			
Roof / top floor ceiling: U-value (average value) / area	0,13	W/(m²K)	1557,73
Standard roof / top floor ceiling: U-value / thickness		W/(m²K)	0,0
Standard roof / top floor ceiling: area / area percentage		W/(m²K)	
Standard roof / top floor ceiling: name / certified?			
Standard roof / top floor ceiling: short description (materials, manufacturer, product name, special features)			

Floor slab / basement ceiling: U-value (average value) / area	2,60	W/(m²K)	1557,73
Standard floor slab / basement ceiling: U-value / thickness		W/(m²K)	0,0
Floor slab / basement ceiling standard: area / area fraction		W/(m²K)	
Standard floor slab / basement ceiling: name / certified?			
Standard floor slab / basement ceiling: short description (materials, manufacturer, product name, special features)			
Thermal bridges: Y-value (Average value) / length	-0,069	W/(mK)	590,05
Thermal bridge free limit value / Complied?	0,01	W/(mK)	yes
Thermal bridges: short description (max.5000 letters) (additional notices, manufacturer, product name, materials, others)			

Windows / doors / shading systems			
windows/facades: U-value (average value) / area	0,97	W/(m²K)	1247,78
window/facade frames: U-value (average value) / area	0,80	W/(m²K)	605,89
Glazing: U-value (Average value) / areas	0,80	W/(m²K)	641,89
Ψ-Value Glazing edge (average) / Ψ-Value Installation (average)	0,030	W/(mK)	0,040
Standard window frame: U-value / frame width		W/(m²K)	
Standard window frame: window area / area percentage		W/(m²K)	
Standard window frame: glass edge Ψ-value / installation Ψ-value		W/(mK)	
Standard window frame: name, certified?			
Standard window frame: Short description (materials, manufacturer, product name, installation)			
Standard curtain wall facade: U-value / Frame width		W/(m²K)	
Standard curtain wall facade: Facade area / Total area percentage		W/(m²K)	
Standard curtain wall facade: Ψ-value glazing edge / Ψ-value installation		W/(mK)	
Standard curtain wall facade: Description / Certified?			
Standard curtain wall facade: short description (materials, manufacturer, product name, installation)			
Standard glazing: U-value / g-value		W/(m²K)	
Standard glazing: Facade area / Area ratio		W/(m²K)	
Standard glazing: Description / Certified?			
Standard glazing: short description (description, manufacturer, product name, installation)			
Standard glazing 2: U-value / g-value		W/(m²K)	
Standard glazing 2: Facade area / Area percentage		W/(m²K)	
Standard glazing 2: Description / Certified?			
Standard glazing 2: short description (description, manufacturer, product name, installation)			
Roof lights / light domes: U-value / frame width		W/(m²K)	
Roof lights / light domes: window area / area section		W/(m²K)	
Roof lights / light domes: glazing U-value / g-value		W/(m²K)	
Roof lights / light domes: Y-value glass edge / Installation Y-value		W/(mK)	
Roof lights / light domes: name / certified?			
Roof lights / light domes: short description (materials, manufacturer, product name, installation situation)			
Exterior door: U-value (average value) / Area	2,20	W/(m²K)	7,97
Standard exterior door: door U-value / door U-value installed		W/(m²K)	
Standard exterior door: frame U-value / door leaf U-value		W/(m²K)	
Standard exterior door: door leaf thickness / frame width		mm	
Standard exterior door: panel border Y-value / installation Y-value		W/(mK)	
Standard exterior door: Name / certified?			
Standard exterior door: Short description (materials, manufacturer, product name, installation situation)			
Temporary sun protection: Type / Add. Reduction factor		W/(m²K)	5,75
Temporary sun protection: Area / Area ratio		W/(m²K)	
Shading reduction factors: orientation	Reduction factor winter		Summer reduction factor
North	81	%	53
East	60	%	43
South	68	%	40
West	51	%	34
Horizontal	100	%	100

Ventilation		
Ventilation: Type of ventilation	Balanced PH-Ventilation with HR	
Calculated supply air demand / supply air per person	10200	m³/h 15
Calculated extract air demand / Amount extract air rooms	0	m³/h
Design air flow rate (maximum) / Average value reference to maximum		m³/h 55
Average flow rate / Average air exchange		m³/h
Airtightness test pressure at n₅₀ / Air permeability q₅₀	1,00	l/h 0,87
Net air flow for pressurization test / Infiltration flow n _{V,Rest}	6329	m³ 0,04
Ventilation unit: Description / Certified?		
Ventilation system: effective heat recovery efficiency / electrical efficiency		%
Ventilation system: Description (type of heat recovery, manufacturer, product name)		
Ventilation system: installation site / Temperature of mechanical services room		20
Nominal width exterior or supply air / exhaust or extract air ducts	60	mm 60
Conductance ambient- or supply air duct / exhaust- or extract air duct		W/(mK)
Length ambient- or supply air duct / exhaust- or extract air duct	2,00	m 2,00
SHX: efficiency / effective heat recovery efficiency		% 0,00
HE defrosting / Defrosting at a minimum temperature of	yes	4,00
Effective energy recovery efficiency ventilation / Humidity recovery		% 0,0
Ventilation system: Short description (installation site, ducts, silencers, others)		

Summer ventilation		
Summer base ventilation: ventilation type		
Air exchange via ventilation system with supply air:	Without heat recovery	1,17
Air exchange via extract air system		0,62
Window ventilation air exchange		0,14
Night summer ventilation: Type of ventilation		
Night air exchange Window Night Ventilation, Manual		0,00
Night air exchange mechanical, automatically Controlled ventilation	Humidity difference regulated	0,62
Summer ventilation: short description (window opening profiles, night ventilation concepts, others)		


Cooling		
Max. indoor absolute humidity / Internal humidity sources	12,0	g/kg 2,0
Frequency of overheating / Overtemperature limit:	3,1	% 25,0
Mechanical cooling: Applied cooling units		
		kW
		kW
	0,0	
		kWh/(m²a)
Mechanical cooling: Average annual coefficient of performance / Electricity demand		0,0
Mechanical cooling: Short description (unit, manufacturer, product name, installation site, installation)		

Heating and DHW		
DHW Demand	12,83 kWh/(m²a)	59405
Annual heating demand	17,46 kWh/(m²a)	80824
Direct electricity: contribution to space heating / domestic hot water	%	
PE value energy carrier / CO ₂ -emission factor	kWh/kWh	
Direct electric heating / domestic hot water		
Final energy demand	kWh/(m²a)	
Direct electricity: short description (description, manufacturer, product name)		
Heat pump: covered fraction of space heating / domestic hot water	%	
PE value energy carrier / CO ₂ -emission factor	kWh/kWh	
COP heat pump for heating / heat pump for DHW		
Final energy demand	kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)		
Compact unit: covered fraction of space heating / domestic hot water	%	
PE value energy carrier / CO ₂ -emission factor	kWh/kWh	
COP heat pump for heating / heat pump for DHW		
Final energy demand	kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)		
Boiler: covered fraction of space heating / domestic hot water	100 %	100
PE value energy carrier / CO ₂ -emission factor	1,1 kWh/kWh	250
Heat generator: building type / COP	Low Temperature Boi-ler Gas	114
Final energy demand	31,5 kWh/(m²a)	
Boiler: short description (description, manufacturer, product name)		
District heating: Covered fraction of space heating / domestic hot water	%	
PE value energy carrier / CO ₂ -emission factor	kWh/kWh	
Heat source / Performance of heat generator		
Final energy demand	kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)		
Solarthermics		
Collector	Improved flat plate PK SL AL	
Collector area / Specific collector area	22,30 m²	0,03
Deviation from north / Angle of inclination from the horizontal	180 °	45
Solarthermics: Short description (description, manufacturer, product name, installation location)		
Solar contribution to DHW	1,86 kWh/(m²a)	15
Solar contribution to space heating	0,71 kWh/(m²a)	4
Solar contribution total	2,57 kWh/(m²a)	8
Solar Storage	Water storage two heat exchangers	
PHOTOVOLTAIC		
Module technology	Poly-Si	
Nominal current / Nominal voltage	A	30,60
Nominal power / Number of modules	#WERT! Wp	45
Deviation from north / Angle of inclination from the horizontal	180 °	45
Solarthermics: Short description (description, manufacturer, product name, installation location)		
Annual yield of PV modules	kWh/(m²a)	

Aux. electricity / Household electricity		
Aux Electricity		
Ventilation units / Electricity demand		47505
Heating system Devices / Electricity demand		2318
DHW-system units / Electricity demand		644
Aux. Electricity solar devices / electr. demand		481
Total aux. Electricity	11,00 kWh/(m²a)	50946,48
Household electricity		
Dishwasher / useful energy demand		48620
Washing machine units / Energy demand		42636
Clothes dryer unit / Energy demand		118703
Refrigerator, Freezer or combination unit / Useful energy demand		574
Cooking unit / energy demand		85000
Lighting		118320
Consumer Electronics		29920
Small appliances, etc.		34000
Other		
Total household electricity	103,18 kWh/(m²a)	477772,28
Economic data		
Total gross construction costs / contained VAT	€	
Building costs (cost group 300+400) / (cost group 200-700)	€	
Total gross construction costs per m² BGF / per m³ BRI	€/m²	
Explanation building costs		
Fostering (Passivhaus, refurbishment, etc.)		
Explanation fostering		
Other		
Ecological aspects: rainwater utilization, etc.		
Material used: Regional products / Natural products		
Special features: first project in the country / first project used as		
Building awards		
Research project / funded project		
Description of research / funded project		
Other		

Section I
ико Търнов
m
Dwelling units
P
m ² /P
°C
W/m ²
land)
m ³
W/(m ² K)
W/m ²
W/m ²
> 25 °C
W/(m ² K)
W/m ²
W/m ²
1/h
W/(m ² K)
kg/(m ² a)
kg/(m ² a)

m²
mm
%
m²
mm
%
m²
mm
%



m²
m²
m²
W/(mK)
mm
%
W/(mK)
mm
%
W/(mK)
%
%
mm
%
W/(mK)
m²
m²
W/(m²K)
mm
W/(mK)
m²
%
%
%
%
%

$\text{m}^3/(\text{P} \cdot \text{h})$
pcs
%
1/h
1/h
1/h
Wh/m^3
$^{\circ}\text{C}$
mm
$\text{W}/(\text{mK})$
mm
%
$^{\circ}\text{C}$
%
1/h
1/h
1/h
1/h
1/h
$\text{g}/(\text{m}^2\text{h})$
0
m^3/h
$\text{kWh}/(\text{m}^2\text{a})$
$\text{kWh}/(\text{m}^2\text{a})$

EnerPHit planning:

select active variants
>>

Results		Units
Annual heating demand		kwh/(m²a)
Heating Load		W/m²
Overall specific space cooling demand		kwh/(m²a)
Cooling load		W/m²
Frequency of overheating		%
Total primary energy demand		kwh/(m²a)
Certifiable as EnerPHit building retrofit (acc. to heating demand)?		yes / no
<<	User defined	Units

Input variables		Units
<< Assembly layers ('U-value')		
a	Exterior insulation EPS-F	W/(mK)
		mm
b	New outside plaster	W/(mK)
		mm
c	of insulation mineral wool (on top of lower slab)	W/(mK)
		mm
d		W/(mK)
		mm
e		W/(mK)
		mm
f	Wall insulation XPS	W/(mK)
		mm
g	Hydroinsulation	W/(mK)
		mm
h		W/(mK)
		mm
i		W/(mK)
		mm
j		W/(mK)
		mm
k	ulation wool on the ceiling of technical corridor	W/(mK)
		mm
l	Floor insulation XPS	W/(mK)

		mm
m		W/(mK)
		mm
n		W/(mK)
		mm
o		W/(mK)
		mm
p	Wall cocle	W/(mK)
		mm
q		W/(mK)
		mm
r		W/(mK)
		mm
s		W/(mK)
		mm
t		W/(mK)
		mm
u		W/(mK)
		mm
v		W/(mK)
		mm
w		W/(mK)
		mm
x		W/(mK)
		mm
y		W/(mK)
		mm
z		W/(mK)
		mm

<< Radiation balance ('Areas')

<< Thermal bridges ('Areas')

<< Glazing and frames ('Window', 'Shading')

a	Doors with console	
Active variants: g-Value:0,51 U-Value: 0,8 W/(m²K)		Glazing
U-Value [W/(m²K)]: Left: 1,1 Right: 1,1 Bottom: 1,14 Top: 1,1 Width [m]: Left: 0,116 Right: 0,116 Bottom: 0,126 Top: 0,116		Frame
Window reveal depth		m
Distance from glazing edge to reveal		m
Overhang depth		m
Distance of the upper edge of glazing to the overhang		m

	Reduction factor for temporary sun protection	%
b	Without winter shading	
	Active variants: g-Value:0,51 U-Value: 0,8 W/(m²K)	Glazing
	U-Value [W/(m²K)]: Left: 0,79 Right: 0,79 Bottom: 0,79 Top: 0,79 Width [m]: Left: 0,131 Right: 0,131 Bottom: 0,161 Top: 0,131	Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
c	Windows with console	
	Active variants: g-Value:0,51 U-Value: 0,8 W/(m²K)	Glazing
	U-Value [W/(m²K)]: Left: 0,79 Right: 0,79 Bottom: 0,79 Top: 0,79 Width [m]: Left: 0,131 Right: 0,131 Bottom: 0,161 Top: 0,131	Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
d	Sector A with console	
	Active variants: g-Value:0,51 U-Value: 0,8 W/(m²K)	Glazing
	U-Value [W/(m²K)]: Left: 0,79 Right: 0,79 Bottom: 0,79 Top: 0,79 Width [m]: Left: 0,131 Right: 0,131 Bottom: 0,161 Top: 0,131	Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
a		Glazing

		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
e	Sector A without winter shading north	
	<i>Active variants:</i> <i>g-Value:0,51</i> <i>U-Value: 0,8 W/(m²K)</i>	Glazing
	<i>U-Value [W/(m²K)]: Left: 0,79 Right: 0,79 Bottom: 0,79 Top: 0,79</i> <i>Width [m]: Left: 0,131 Right: 0,131 Bottom: 0,161 Top: 0,131</i>	Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
f	Sector C Eaves	
	<i>Active variants:</i> <i>g-Value:0,51</i> <i>U-Value: 0,8 W/(m²K)</i>	Glazing
	<i>U-Value [W/(m²K)]: Left: 0,79 Right: 0,79 Bottom: 0,79 Top: 0,79</i> <i>Width [m]: Left: 0,131 Right: 0,131 Bottom: 0,161 Top: 0,131</i>	Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
g		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m

h	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
i		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
j		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
k		
		Glazing
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%

I		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
m		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
n		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
n		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m

o	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
p		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
q		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
r		
		Glazing
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%

s		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
t		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
u		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m

v		Distance of the upper edge of glazing to the overhang	m
		Reduction factor for temporary sun protection	%
			Glazing
			Frame
		Window reveal depth	m
		Distance from glazing edge to reveal	m
		Overhang depth	m
w		Distance of the upper edge of glazing to the overhang	m
		Reduction factor for temporary sun protection	%
			Glazing
			Frame
		Window reveal depth	m
		Distance from glazing edge to reveal	m
		Overhang depth	m
x		Distance of the upper edge of glazing to the overhang	m
		Reduction factor for temporary sun protection	%
			Glazing
			Frame
		Window reveal depth	m
		Distance from glazing edge to reveal	m
		Overhang depth	m
y		Distance of the upper edge of glazing to the overhang	m
		Reduction factor for temporary sun protection	%
			Glazing
		Window reveal depth	m
		Distance from glazing edge to reveal	m
		Overhang depth	m

Z	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%

<< Ventilation ('Ventilation', 'SummVent')

<< Heat generator ('PE-value')

<< Compressor cooling unit ('Cooling units')

<< User defined

	Description	Units
1	Mechanical cooling	x
2	Light Transmission Glazing	-
3	Defroster HX	0/1
4	Extra kitchen consumption	kWh/d
5	Refrigerator	kWh/d
6	Solar Collector Area	m ²
7	Insulation Thickness:	mm
8	Heat Loss Coefficient per m Pipe	W/mK
9	Heat Loss Coefficient per m Pipe	W/mK
10	Power of the boiler	kW
11	Shading	
12	Hybrid solar collector (PV + Heat generation)	(A)
13	Cooking appliances	el/gas
14	Lighting in classrooms	W/m ²
15	Lighting in 200 lux	W/m ²
16	Lighting in 100 lux	W/m ²
17	Lighting in 200 lux with fluorescent	W/m ²
18		

19	Lighting in 100 lux with fluorescent	W/m2
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		

62		
63		
64		
65		
66		
67		
68		
69		
70		
71		
72		
73		
74		
75		
76		
77		
78		
79		
80		
81		
82		
83		
84		
85		
86		
87		
88		
89		
90		
91		
92		
93		
94		
95		
96		
97		
98		
99		
100		

CALCULATION OF VARIANTS

Active

5-Step 4 (after 10 years) - Windows	No measures	Step 1 - Roof	Step 2 - walls, HVAC, DHW & kitchen appliances, airtightnes	Step 3 - Ground walls periferial insulation; insulation
5	1	2	3	4
17,3	142,4	111,0	50,5	44,2
13,0	66,3	53,1	27,8	26,1
3,1	7,9	2,9	6,6	5,2
89,9	233,5	196,4	117,2	120,8
yes	no	no	no	no
Link	Link	Link	Link	Link

Value	1	2	3	4
-------	---	---	---	---

0,032			0,032	0,032
200			200	200
0,87			0,87	0,87
20			20	20
0,041		0,041	0,041	0,041
300		300	300	300
0				
0				
0				
0				
0,035				0,035
180				180
0,17				0,17
7,5				7,5
0				
0				
0				
0				
0				
0				
0,041				0,041
100				100
0				

80%	80%	80%	80%	80%
-----	------------	------------	------------	------------

[Go to glazing list](#)

[Go to window frames list](#)

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4
0081wi03 Rehau - REHAU GENEOPHZ - with Swisspacer V	01ud Plastic window frame good	01ud Plastic window frame good	02ud Plastic window frame good after wall insulation	02ud Plastic window frame good after wall insulation
0,180	0, 2	0, 2	0, 2	0, 2
0,070	0, 14	0, 14	0, 14	0, 14
0,180	0, 15	0, 15	0, 15	0, 15
0,070	0, 14	0, 14	0, 14	0, 14
60%	80%	80%	80%	80%

[Go to glazing list](#)

[Go to window frames list](#)

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4
0081wi03 Rehau - REHAU GENEOPHZ - with Swisspacer V	01ud Plastic window frame good	01ud Plastic window frame good	02ud Plastic window frame good after wall insulation	02ud Plastic window frame good after wall insulation
0,180	0, 2	0, 2	0, 2	0, 2
0,070	0, 14	0, 14	0, 14	0, 14
2,050	2, 15	2, 15	2, 15	2, 15
0,170	0, 24	0, 24	0, 24	0, 24
80%	80%	80%	80%	80%

[Go to glazing list](#)

[Go to window frames list](#)

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4
0081wi03 Rehau - REHAU GENEOPHZ - with Swisspacer V	01ud Plastic window frame good	01ud Plastic window frame good	02ud Plastic window frame good after wall insulation	02ud Plastic window frame good after wall insulation
0,180	0, 2	0, 2	0, 2	0, 2
0,070	0, 14	0, 14	0, 14	0, 14
1,580	1, 62	1, 62	1, 62	1, 62
0,170	0, 25	0, 25	0, 25	0, 25
80%	80%	80%	80%	80%

[Go to glazing list](#)

[Go to window frames list](#)

--	--	--	--	--

[Go to glazing list](#)

[Go to window frames list](#)

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4
0081wi03 Rehau - REHAU GENEOPHZ - with Swisspacer V	01ud Plastic window frame good	01ud Plastic window frame good	02ud Plastic window frame good after wall insulation	02ud Plastic window frame good after wall insulation
0,180	0, 2	0, 2	0, 2	0, 2
0,070	0, 14	0, 14	0, 14	0, 14
0,180	0, 15	0, 15	0, 15	0, 15
0,070	0, 14	0, 14	0, 14	0, 14
80%	80%	80%	80%	80%

[Go to glazing list](#)

[Go to window frames list](#)

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4
0081wi03 Rehau - REHAU GENEOPHZ - with Swisspacer V	01ud Plastic window frame good	01ud Plastic window frame good	02ud Plastic window frame good after wall insulation	02ud Plastic window frame good after wall insulation
0,180	0, 2	0, 2	0, 2	0, 2
0,070	0, 14	0, 14	0, 14	0, 14
0,750	0, 75	0, 75	0, 75	0, 75
1,400	1, 4	1, 4	1, 4	1, 4
60%	80%	80%	60%	60%

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

--	--	--	--	--

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

--	--	--	--	--

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

--	--	--	--	--

[Go to glazing list](#)

[Go to window frames list](#)

0,510	0,78	0,78	0,78	0,78
1,000	0	0	1	1
0,000	8	8	0	0
1,640	7,5	7,5	1,64	1,64
22,300	0	0	22,3	22,3
60,000	60	60	60	60
0,253	0,295	0,295	0,253	0,253
0,198	0,23	0,23	0,198	0,198
400,000	400	400	400	400
0,600			0,6	0,6
Gas	Electricity	Electricity	Gas	Gas
8,000	8	8	8	8
21,600	21,6	21,6	21,6	21,6
13,800	13,8	13,8	13,8	13,8
7,200	7,2	7,2	7,2	7,2

[illegible]

[illegible]

Step 4 (after 10 years) - Windows				
5	6	7	8	9
17,3				
13,0				
3,1				
89,9				
yes				
Link	Link	Link	Link	

5	6	7	8	9
---	---	---	---	---

0,032				
200				
0,87				
20				
0,041				
300				
0,035				
180				
0,17				
7,5				
0,041				
100				

80%				
------------	--	--	--	--

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENE0 PHZ - with Swisspacer V				
0, 18				
0, 07				
0, 18				
0, 07				
60%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENE0 PHZ - with Swisspacer V				
0, 18				
0, 07				
2, 05				
0, 17				
80%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENE0 PHZ - with Swisspacer V				
0, 18				
0, 07				
1, 58				
0, 17				
80%				

--	--	--	--	--

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENE0 PHZ - with Swisspacer V				
0, 18				
0, 07				
0, 18				
0, 07				
80%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENE0 PHZ - with Swisspacer V				
0, 18				
0, 07				
0, 75				
1, 4				
60%				

--	--	--	--	--





--	--	--	--	--

--	--	--	--	--

0,51				
1				
0				
1,64				
22,3				
60				
0,253				
0,198				
400				
0,6				
Gas				
8				
21,6				
13,8				
7,2				

[illegible]

[illegible]



--

--

--

[illegible]

[illegible]

Selection of comparison configuration

Description	8-S4:windows
Component type	Complete building
Component	- No additional input

Calculation of selected configuration

	Lower Efficiency	High Efficiency
Design according to variant	4-Step 3 - Ground wall	5-Step 4 (i)
Annual heating demand	44,162	17,33
Minimal interior surface temperature	-	-
Design Temperature outside	-	-
Interior temperature	20,0	20,0
Normal surface thermal resistance	-	-
Increased Heat Transfer Resistance	-	-
Minimal surface temperature unobstructed	-	-

	Investment costs		
	Per m² of TFA	Entire building	Per m² of TFA
Treated Floor Area (TFA)	1,00	4630	1,00
Investment costs less sum of financial support	0,00	0	42,77
Investment costs	0,00	0	42,77
Real interest rate	4,89%		4,89%
Period of use	35		35
Annuity factor (Lifespan)	0,06		0,06
Present value factor (period under consideration)	12,58		12,58
Annuity factor (period under consideration)	0,08		0,08
Residual value after period under consideration	0,00	0	10,37
Investment costs less residual value	0,00	0	32,41
Annuity (capital costs)	0,00	0	2,58

	Energy (Space heating + cooling)		
	Per m² of TFA	Entire building	Per m² of TFA
Area	1	4630	1
Annual heating demand	44,16	204488	17,33

Cooling + dehumidification demand			
--	--	--	--

Electricity demand:

Auxiliary electricity for Heating	0,56	2591	0,50
Auxiliary electricity ventilation winter	2,64	12202	2,64
Direct electric	0,00	0	0,00
HP	0,00	0	0,00
Compact heat pump unit	0,00	0	0,00
Auxiliary electricity ventilation summer	6,71	31076	6,71
Compressor cooling unit	0,00	0	0,00

Final energy demand:

Total electricity demand	9,91	45869	9,85
Gas	47,44	219666	18,79
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	0,00	0	0,00
Others	0,00	0	0,00

CO2-Emissions:

Total electricity demand	6,74	31191	6,70
Gas	11,86	54917	4,70
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	0,00	0	0,00
Others	0,00	0	0,00

PE-demand

Total electricity	25,76	119258	25,60
Gas	52,18	241633	20,67
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	0,00	0	0,00
Others	0,00	0	0,00

Costs:

Total electricity	0,99	4587	0,98
Gas	2,85	13180	1,13
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	0,00	0	0,00
Others	0,00	0	0,00
Total energy costs	3,84	17767	2,11
Maintenance costs	0,00	0	0,00

Final energy demand	67,25	311404	38,49
CO ₂ -Emissions	18,60	86107	11,39
Primary energy demand	77,94	360891	46,28
Total cost space conditioning	3,84	17767	2,11

	Economic		
Total annual costs	3,84	17767	4,69

Maximal economically viable additional i

Cost per kWh of s

<<

Boundary conditions

Approximate estimate of cost effectiveness (all c

Boundary		
Interest rate + Inflation		Energy price
Nominal interest rate	6, 50%	Electricity
Inflation	1, 53%	Gas/Oil
Period under consideration [a]	20	Logs
		Pellet
		District heating
		Others

ETWEEN TWO VARIANTS

her iciency	Difference / Savings / Profit
after 10 ye	
330	kWh(m²a)
-	°C
-	°C
, 0	°C
-	m²K/W
-	m²K/W
-	°C

tment			
Entire building	Per m² of TFA	Entire building	
4630	1, 00	4630	m²
198052	42,77	198052	€
198052	42,77	198052	€
9%			
5			a
06			
,58			
08			
47996	10,37	47996	€
150056	32,41	150056	€
11931	2,58	11931	€/a

ooling + mech. ventilation)			
Entire building	Per m² of TFA	Entire building	
4630	1	4630	m²
80244	26,83	124244	kWh/a

			kWh/a
--	--	--	-------

2318	0,06	273	kWh/a
12202	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
31076	0,00	0	kWh/a
0	0,00	0	kWh/a

45595	0,06	273	kWh/a
87022	28,65	132645	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a

31005	0,04	186	kg/a
21755	7,16	33161	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a

118548	0,15	710	kWh/a
95724	31,51	145909	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a

4560	0,01	27	€/a
5221	1,72	7959	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
9781	1,72	7986	€/a
0	0,00	0	€/a

178213	28,76	133191	kWh/a
52760	7,20	33347	kg/a
214272	31,66	146619	kWh/a
9781	1,72	7986	€/a

c viability			
21711	-0,85	-3945	€/a
investment costs	28,63	132571	€
aved final energy	9,0		Cent/kWh

omponents with the same mean lifetime)!

conditions			
s [cent/kWh]	Period of use		
10	Build. assemblies	50	a
6	Vent. system	25	a
3	Thermal bridges	50	a
4	Complete building	35	a
6	Windows	30	a
20			

Input: comparison configuration

Comparison configuration	1	2
Description	31.roof_insulation	32.wall_insulation
Component type	Building assemblies ("U-Value")	Building assemblies ("U-Value")
Component	03ud Ventilated roof	01ud Brick walls
"Lower Efficiency" variant	1-No measures	2-Step 1 - Roof
Investment costs [€]	30 . 949 , 25	26 . 180 , 94
Annual maintenance costs [€/a]		
"Higher Efficiency" variant	2-Step 1 - Roof	3-Step 2 - walls, HVAC, DHW & K
Investment costs [€]	63 . 196 , 24	97 . 929 , 71
Annual maintenance costs [€/a]		0 , 00
Financial support (present value) [€]		

Results (manual transfer)

[illegible]

[illegible]

[illegible]

3

4

5

S2:HVAC	S2:Building	S3:Gr.walls
Ventilation system ("Ventilation")	Complete building	Building assemblies ("U-Value")
- No additional input	- No additional input	04ud Ground walls
2-Step 1 - Roof	2-Step 1 - Roof	3-Step 2 - walls, HVAC, DHW & K
27 . 592 , 59	53 . 773 , 53	0 , 00
3-Step 2 - walls, HVAC, DHW & K	3-Step 2 - walls, HVAC, DHW & K	4-Step 3 - Ground walls periferia
91 . 198 , 62	380 . 458 , 54	14 . 187 , 94
0 , 00	799 , 94	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

10

4-Step 3 - Ground walls peripheral insulatio; insulation of the technical corridor

0,00

5-Step 4 (after 10 years) - Windows

[illegible]

[illegible]

[illegible]

CLIMATE DATA

Region:

User Data

Climate data set:

User data - Велико Търнов

Weather station (altitude):

137, 0

m

Building location (height above sea level):

426

m

Building:

primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Climate Building

Велико Търнов

Monthly Data:

User data - Велико Търнов

Annual Data:

no

Use Annual Climate Data Set

no

Results:

Annual heating demand17, 3kWh/(m²a)

Heating load

13, 0

W/m²

Primary Energy

89, 9

kWh/(m²a)

Transfer to annual method (Annual Heating)

H_T

194

d/a

G_t

77

kKh/a

North

127

kWh/(m²a)

East

251

kWh/(m²a)

South

444

kWh/(m²a)

West


253

kWh/(m²a)

Horizontal

417

kWh/(m²a)



Parameters for PHPP Calculated Ground Temperatures:

Phase shift months	Ambient Temp	-1,1	1,4	5,1	10,2	15,8	19,4	21,6	21,3	15,7	10,8	5,5	-0,3	-9,3	-4,8	27,9
0,60	North	14	19	28	37	48	54	51	44	32	24	15	13	19	16	92
Damping	East	28	35	55	80	97	100	103	89	70	50	28	24	39	23	197
-0,31	South	61	68	85	90	86	81	87	93	96	91	65	57	82	40	185
Depth m	West	27	35	58	74	90	90	95	89	72	54	31	23	35	24	197
1,00	Global	42	59	95	135	166	172	181	159	121	84	48	37	56	36	349
User data - Example	Dew Point	-2,6	-2,0	0,5	5,1	10,6	14,3	15,6	15,1	11,7	7,9	3,7	-1,6			18,6
1,00	Sky Temp	-11,1	-9,3	-6,3	-1,1	5,3	9,4	11,4	10,9	6,3	1,9	-2,6	-9,3			16,5
	Ground Temp	18, 2	18, 1	18, 2	18, 4	18, 7	23, 2	23, 4	23, 4	19, 1	18, 9	18, 6	18, 4	18, 1	18, 1	23, 4

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B** Wedge-shaped building assemblies (tapered insulation),
 Unventilated air layers and unheated attics

-> Auxiliary calculation to the right

Assembly No.	Building assembly description						Interior insulation?
01ud	Brick walls						☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13			
		exterior R _{se} :		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1. Inside plaster	0,700					40	
2. Bricks	0,520					250	
3. Outside plaster	0,870					40	
4. EPS	0,032					200	
5. Outside plaster	0,870					20	
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						55,0 cm	
U-value supplement		W/(m²K)		U-Value:		0,142 W/(m²K)	

Assembly No.	Building assembly description						Interior insulation?
02ud	Wall socle						☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13			
		exterior R _{se} :		0,04			
Area section 2	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1. Inside plaster	0,700					20	
2. Bricks	0,520					400	
3. Boucharde	2,100					30	
4. EPS	0,035					180	
5. Outside plaster	0,870					30	
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						66,0 cm	
U-value supplement		W/(m²K)		U-Value:		0,162 W/(m²K)	

Assembly No.	Building assembly description						Interior insulation?
03ud	Ventilated roof						☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,10			
		exterior R _{se} :		0,10			
Area section 3	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1. Cement plaster	0,930					30	
2. Concrete	2,100					120	
3. Inside plaster	0,700					20	
4. Mineral wool	0,041					300	
5. Перлит	0,260					85	
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						55,5 cm	
U-value supplement		W/(m²K)		U-Value:		0,126 W/(m²K)	

Assembly No.	Building assembly description					Interior insulation?
04ud	Ground walls					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13		
		exterior R _{se} :				
Area section 4	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Inside plaster	0,700					20
2. Concrete	2,100					400
3. XPS	0,035					180
4. Hydroisulation	0,170					8
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						60,8 cm
U-value supplement		W/(m²K)		U-Value:		0,181 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
05ud	Floor to unheated basement					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,17		
		exterior R _{se} :		0,17		
Area section 5	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. New flooring	0,000					0
2. XPS	0,000					0
3. Flooring	3,500					30
4. Cement	0,930					20
5. Concrete	2,100					150
6. Plaster	0,700					20
7. EPS	0,041					100
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						32,0 cm
U-value supplement		W/(m²K)		U-Value:		0,344 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
06ud	Floor					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,17		
		exterior R _{se} :				
Area section 6	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Flooring	3,500					30
2. Cement	0,930					20
3. Concrete	2,100					150
4. Rubble	3,500					150
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						35,0 cm
U-value supplement		W/(m²K)		U-Value:		3,181 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
07ud	Inside brick wall					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13		
		exterior R _{se} :		0,04		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Inside plaster	0,700					40
2. Bricks	0,520					250
3. Inside plaster	0,070					40
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						33,0 cm
U-value supplement		W/(m²K)		U-Value:		0,782 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
08ud	Non ventilated roof					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,10		
		exterior R _{se} :		0,10		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Inside plaster	0,700					20
2. Concrete	2,100					150
3. Hydroinsulation	0,170					8
4. balast/mineral wool	0,000					0
5. new hydroinsulation	0,000					0
6. balast new	0,000					0
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						17,8 cm
U-value supplement		W/(m²K)		U-Value:		2,906 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
09ud	Floor Block A					☒
Heat transfer resistance [m²K/W]		interior R _{si} :		0,17		
		exterior R _{se} :				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. New flooring	0,000					0
2. XPS	0,000					0
3. Flooring	3,500					30
4. Cement	0,930					20
5. Concrete	2,100					150
6. Rubble	3,500					150
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						35,0 cm
U-value supplement		W/(m²K)		U-Value:		3,181 W/(m²K)

Assembly No.	Building assembly description					Interior insulation?
10ud	Floor to unheated basement Block C					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,17		
		exterior R _{se} :		0,17		
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
10						
1. Flooring	3,500					30
2. Cement	0,930					20
3. Concrete	2,100					150
4. Plaster	0,700					20
5. EPS	0,000					0
6. Plaster	0,000					0
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						22,0 cm
U-value supplement		W/(m²K)		U-Value: 2,127 W/(m²K)		

Assembly No.	Building assembly description					Interior insulation?
11ud	Ground walls Sector B					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13		
		exterior R _{se} :				
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
11						
1. Inside plaster	0,700					20
2. Concrete	2,100					500
3. XPS	0,035					180
4. Hydroisulation	0,170					8
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						70,8 cm
U-value supplement		W/(m²K)		U-Value: 0,179 W/(m²K)		

Assembly No.	Building assembly description					Interior insulation?
12ud	Wall socle Sector B					☐
Heat transfer resistance [m²K/W]		interior R _{si} :		0,13		
		exterior R _{se} :		0,04		
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
12						
1. Inside plaster	0,700					40
2. Bricks	0,520					500
3. Boucharde	2,100					40
4. EPS	0,032					200
5. Outside plaster	0,870					20
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						80,0 cm
U-value supplement		W/(m²K)		U-Value: 0,134 W/(m²K)		

Assembly No.	Building assembly description					Interior insulation?
13ud						☐
Heat transfer resistance [m²K/W]		interior R _{si} :				
		exterior R _{se} :				

exterior R_{se} :

Area section 13

	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1	100%	Percentage of sec. 2		Percentage of sec. 3		Total cm

U-value supplement W/(m²K) U-Value: W/(m²K)

Assembly No. 14ud Building assembly description

Interior insulation? ☐

Heat transfer resistance [m²K/W] interior R_{si} :
 exterior R_{se} :

Area section 14

	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1	100%	Percentage of sec. 2		Percentage of sec. 3		Total cm

U-value supplement W/(m²K) U-Value: W/(m²K)

Assembly No. 15ud Building assembly description

Interior insulation? ☐

Heat transfer resistance [m²K/W] interior R_{si} :
 exterior R_{se} :

Area section 15

	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1	100%	Percentage of sec. 2		Percentage of sec. 3		Total cm

U-value supplement W/(m²K) U-Value: W/(m²K)

Assembly No. 16ud Building assembly description

Interior insulation? ☐

Heat transfer resistance [m²K/W] interior R_{si} :
 exterior R_{se} :

Area section 16

	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						

1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
	Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
	100%						cm
	U-value supplement		W/(m²K)		U-Value:		W/(m²K)

Assembly No.	Building assembly description						Interior insulation?
17ud							
Heat transfer resistance [m²K/W]		interior R _{si} :					
		exterior R _{se} :					
Area section							
17	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
	Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
	100%						cm
	U-value supplement		W/(m²K)		U-Value:		W/(m²K)

Assembly No.	Building assembly description						Interior insulation?
18ud							
Heat transfer resistance [m²K/W]		interior R _{si} :					
		exterior R _{se} :					
Area section							
18	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
	Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
	100%						cm
	U-value supplement		W/(m²K)		U-Value:		W/(m²K)

Assembly No.	Building assembly description						Interior insulation?
19ud							
Heat transfer resistance [m²K/W]		interior R _{si} :					
		exterior R _{se} :					
Area section							
19	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.							
2.							
3.							
4.							

5.							
6.							
7.							
8.							
	Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
	100%						cm
	U-value supplement		U-Value:				
	W/(m²K)		W/(m²K)				

Assembly No.	Building assembly description					Interior insulation?
20ud						
Heat transfer resistance [m²K/W]		interior R _{si} :				
		exterior R _{se} :				
Area section						
20	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
	Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
	100%					
	U-value supplement		U-Value:			
	W/(m²K)		W/(m²K)			

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness		mm	Convective heat transfer
Direction of the thermal flow:		Upwards	h_a W/(m ² K)
		Horizontal	Radiation heat transfer
		Downwards	h_r W/(m ² K)
Emissivity of surface 1			equivalent thermal conductivity
Emissivity of surface 2			λ W/(mK)

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness		mm	Convective heat transfer
of the		Upwards	h_a W/(m ² K)
		Horizontal	Radiation heat transfer
		Downwards	h_r W/(m ² K)
Emissivity of surface 1			equivalent thermal conductivity
Emissivity of surface 3			λ W/(mK)

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description						
1a Exemplary flat roof with wedge-shaped insulation						
Heat transfer resistance [m²K/W]		interior R _{si} : 0,10				
		exterior R _{se} : 0,04				
A parallel assemblies layer						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Total Width Thickness d ₀ [mm]
1. Concrete Ceiling	2,100					160
2. PS Rigid Foam	0,040					200
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						36,0 cm
				U ₀ : 0,192 W/(m²K)		
				R ₀ : 5,216 (m²K)/W		
B Wedge-Shaped Assembly Layer						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness d ₁ [mm]
PS rigid foam insulation	0,040					150
		Percentage of sec. 2		Percentage of sec. 3		Thickness d ₁ [cm]
						15,0 cm
				U ₁ : 0,267 W/(m²K)		
				R ₁ : 3,750 (m²K)/W		
		Rectangular Area U-Value:		0,144 W/(m²K)		
		U-value of triangular area with the thickest point at the apex:		0,157 W/(m²K)		
		U-value of triangular area with the thinnest point at the apex:		0,131 W/(m²K)		

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description						
2a						
Heat transfer resistance [m²K/W] interior R _{si} :						
exterior R _{se} :						
A parallel assemblies layer						
						Total Width
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness d ₀ [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						cm
U₀: W/(m²K) R₀: (m²K)/W						
B Wedge-Shaped Assembly Layer						
		Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness d ₁ [mm]
		Percentage of sec. 2		Percentage of sec. 3		Thickness d ₁ [cm]
						cm
U₁: W/(m²K) R₁: (m²K)/W						
Rectangular Area U-Value: W/(m²K)						
U-value of triangular area with the thickest point at the apex: W/(m²K)						
U-value of triangular area with the thinnest point at the apex: W/(m²K)						

Non-conditioned attic

Building assembly description						
Roof						
Heat transfer resistance [m²K/W]		interior R _{si} : 0,17	Exterior absorption coefficient		0,80	
		exterior R _{se} : 0,04	Exterior emissivity		0,93	

	Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Corrugated galvanised iron	60,000					3
2.							
3.							
4.							
5.							
6.							
7.							
8.							

Percentage of sec. 1	Percentage of sec. 2	Percentage of sec. 3	Total
100%			0,3 cm

U-value supplement W/(m²K)	U-Value: 4,761 W/(m²K)
--	-------------------------------

Building assembly description						
Exterior attic wall						
Heat transfer resistance [m²K/W]		interior R _{si} : 0,13	Exterior absorption coefficient		0,80	
		exterior R _{se} : 0,04	Exterior emissivity		0,93	

	Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Interior plaster	0,350					15
2.	Masonry	1,100					175
3.	Exterior Render	0,800					20
4.							
5.							
6.							
7.							
8.							

Percentage of sec. 1	Percentage of sec. 2	Percentage of sec. 3	Total
100%			21,0 cm

U-value supplement W/(m²K)	U-Value: 2,519 W/(m²K)
--	-------------------------------

Building assembly description

Intermediate ceiling

Heat transfer resistance [m²K/W]

interior R_{si} : 0,17

exterior R_{se} : 0,17

	Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Wooden floor	0,130					22
2.							
3.							
4.							
5.							
6.							
7.							
8.							

Percentage of sec. 1

83%

Percentage of sec. 2

16,7%

Percentage of sec. 3

Total

2,2

cm

U-value supplement

W/(m²K)

U-Value:

1,964

W/(m²K)

Attic area

Roof area

200,0

m²

Area of exterior walls and attic

200,0

m²

Area of intermediate ceiling

100,0

m²

emissivity in the attic

Inner side of the roof / exterior wall

0,93

Upper side of the interior ceiling

0,93

Air exchange in the attic

Air change rate

0,20

1/h

Volume

200,0

m³

Equivalent value for the intermediate ceiling (to be linked to worksheets "Components" and "Areas")

U-Value:

2,732

Absorptivity:

0,780

Emissivity:

0,907

Total solar energy transmittance (informative): 0,085

AREAS DETERMINATION

Building: **Primary School 8 "Sveti Sveti Kiril I Metodij"** Heating demand: **17** kWh/(m²a)

Summary					Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit				
1	Treated Floor Area		4630,41	m²	Treated floor area according to PHPP manual		9 months	7 months
2	North Windows	A	258,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the "Windows" worksheet.	0,969	11657	10241
3	East Windows	A	286,55	m²		0,977	16109	15406
4	South Windows	A	348,24	m²		0,969	34616	18986
5	West Windows	A	354,44	m²		0,976	18476	15187
6	Horizontal Windows	A	0,00	m²				
7	Exterior Door	A	7,97	m²	Please subtract area of door from respective building assembly	2,200		
8	Exterior Wall - Ambient	A	2553,98	m²	Temperature Zone "A" is ambient air.	0,143	568	1149
9	Exterior Wall - Ground	B	362,08	m²	Temperature zone "B" is the ground.	0,180		
10	Roof/Ceiling - Ambient	A	1557,73	m²		0,126	3044	4932
11	Floor slab / basement ceiling	B	1557,73	m²		2,597		
12			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
13			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
14		X	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f _r < 1):	Factor for X 75%		
Thermal bridges - Overview						Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	316,95	m	Units in m			
16	Perimeter Thermal Bridges	P	273,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	0,062		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	-0,221		
18	Partition Wall to Neighbour	I	28,60	m²	No heat losses, only considered for the heating load calculation.	0,782		
Total thermal envelope						0,804		

[Go to building components list](#)

Area input													Sort: AS LIST													
Area Nr.	Building assembly description	Group Nr.	Assigned to group	Quantity	x (	a [m]	x	b [m]	+	User-Determined [m²]	-	User Subtraction [m²]	-	Subtraction window areas [m²]	) =	Area [m²]	Selection of building element assembly / certified building system	Nr.	Description (certified component)	U-Value [W/(m²K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity
	Treated floor area	1	Treated Floor Area	1	x (		x		+	4630,41	-		-		) =	4630,4										
	North Windows	2	North Windows													258,6	From 'Windows' worksheet			0,969						
	East Windows	3	East Windows													286,6	From 'Windows' worksheet			0,977						
	South Windows	4	South Windows													348,2	From 'Windows' worksheet			0,969						
	West Windows	5	West Windows													354,4	From 'Windows' worksheet			0,976						
	Horizontal Windows	6	Horizontal Windows													0,0	From 'Windows' worksheet			0,000						
	Exterior Door	7	Exterior Door	1	x (	1,70	x	2,10	+	4,40	-		-		) =	8,0	U-value exterior door:			2,20						
1	Section 2 West fasade	8	Exterior Wall - Ambient	1	x (	2,95	x	10,65	+		-		-	5,0	) =	26,5	01ud Brick walls			0,142	260	90	West	0,70	0,40	0,90
2	Section 2 North fasade	8	Exterior Wall - Ambient	1	x (	53,70	x	10,65	+		-		-	173,5	) =	398,4	01ud Brick walls			0,142	0	90	North	0,70	0,40	0,90
3	Section 2 East fasade	8	Exterior Wall - Ambient	1	x (	12,50	x	10,65	+		-	5,75	-	0,0	) =	127,4	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
4	Section 2 South fasade 1	8	Exterior Wall - Ambient	1	x (	45,00	x	10,65	+		-		-	211,5	) =	267,8	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
5	Section 2 South fasade 2	8	Exterior Wall - Ambient	1	x (	9,35	x	10,65	+		-		-	9,4	) =	90,2	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
6	Section 2 Roof	10	Roof/Ceiling - Ambient	1	x (		x		+	546,63	-		-	0,0	) =	546,6	03ud Ventilated roof			0,126	0	0	Hor	0,70	0,95	0,90
7	Section 2 Floor	11	Floor slab / basement ceiling	1	x (		x		+	546,63	-		-	0,0	) =	546,6	06ud Floor			3,181						
8	Section 2 socle - West	8	Exterior Wall - Ambient	1	x (		x		+	4,72	-		-	0,7	) =	4,0	12ud Wall socle Sector B			0,134	260	90	West	0,70	0,40	0,90
9	Section 2 socle - North	8	Exterior Wall - Ambient	1	x (		x		+	85,92	-		-	37,0	) =	48,9	12ud Wall socle Sector B			0,134	0	90	North	0,70	0,40	0,90
10	Section 2 socle - East	8	Exterior Wall - Ambient	1	x (		x		+	4,80	-		-	0,0	) =	4,8	12ud Wall socle Sector B			0,134	90	90	East	0,70	0,40	0,90
11	Section 2 socle - South	8	Exterior Wall - Ambient	1	x (		x		+	86,96	-		-	39,0	) =	47,9	12ud Wall socle Sector B			0,134	180	90	South	0,70	0,40	0,90
12	Section 2 ground - West	9	Exterior Wall - Ground	1	x (	2,95	x	3,55	+		-	4,72	-	0,0	) =	5,8	11ud Ground walls Sector B			0,179						
13	Section 2 ground - North	9	Exterior Wall - Ground	1	x (	53,70	x	3,55	+		-	85,92	-	0,0	) =	104,7	11ud Ground walls Sector B			0,179						
14	Section 2 ground - East	9	Exterior Wall - Ground	1	x (	12,50	x	3,55	+		-	4,80	-	0,0	) =	39,6	11ud Ground walls Sector B			0,179						
15	Section 2 ground - South	9	Exterior Wall - Ground	1	x (	45,00	x	3,55	+		-	77,14	-	0,0	) =	82,6	11ud Ground walls Sector B			0,179						
16	Section 2 ground - South	9	Exterior Wall - Ground	1	x (	9,35	x	3,55	+		-	9,82	-	0,0	) =	23,4	11ud Ground walls Sector B			0,179						
17	Section 3 North fasade	8	Exterior Wall - Ambient	1	x (	20,95	x	7,10	+		-		-	29,9	) =	118,8	01ud Brick walls			0,142	0	90	North	0,70	0,40	0,90
18	Section 3 East fasade	8	Exterior Wall - Ambient	1	x (	9,50	x	7,10	+		-		-	2,8	) =	64,7	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
19	Section 3 South fasade	8	Exterior Wall - Ambient	1	x (	20,95	x	7,10	+		-		-	65,5	) =	83,2	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
20	Section 3 Roof	10	Roof/Ceiling - Ambient	1	x (		x		+	199,03	-		-	0,0	) =	199,0	03ud Ventilated roof			0,126	0	0	Hor	0,70	0,90	0,90
21	Section 3 Floor	11	Floor slab / basement ceiling	1	x (		x		+	199,03	-	63,73	-	0,0	) =	135,3	06ud Floor			3,181						
22	Section 3 Floor above te	11	Floor slab / basement ceiling	1	x (		x		+	63,73	-		-	0,0	) =	63,7	10ud Floor to unheated basement Block C			2,127						
23	Section 1 - West fasade	8	Exterior Wall - Ambient	1	x (	51,55	x	14,25	+		-		-	327,6	) =	407,0	01ud Brick walls			0,142	260	90	West	0,70	0,40	0,90
24	Section 1 - North 1 fasa	8	Exterior Wall - Ambient	1	x (	15,90	x	14,25	+		-	14,12	-	18,1	) =	194,3	01ud Brick walls			0,142	0	90	North	0,70	0,40	0,90
25	Section 1 - North 2 fasa	8	Exterior Wall - Ambient	1	x (	0,65	x	14,25	+		-		-	0,0	) =	9,3	01ud Brick walls			0,142	0	90	North	0,70	0,40	0,90
26	Section 1 - East 1 fasad	8	Exterior Wall - Ambient	1	x (	15,30	x	14,25	+		-		-	96,4	) =	121,7	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
27	Section 1 - East 2 fasad	8	Exterior Wall - Ambient	1	x (	11,95	x	14,25	+		-	101,71	-	8,3	) =	60,3	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
28	Section 1 - East 3 fasad	8	Exterior Wall - Ambient	1	x (	24,30	x	14,25	+		-		-	160,1	) =	186,2	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
29	Section 1 - South 1 fasa	8	Exterior Wall - Ambient	1	x (	15,90	x	14,25	+		-		-	22,8	) =	203,8	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
30	Section 1 - South 2 fasa	8	Exterior Wall - Ambient	1	x (	0,65	x	3,60	+		-		-	0,0	) =	2,3	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
31	Section 1 socle - West	8	Exterior Wall - Ambient	1	x (		x		+	64,40	-		-	21,2	) =	43,2	02ud Wall socle			0,162	260	90	West	0,70	0,40	0,90
32	Section 1 socle - North	8	Exterior Wall - Ambient	1	x (		x		+	23,96	-		-	0,0	) =	24,0	02ud Wall socle			0,162	0	90	North	0,70	0,40	0,90
33	Section 1 socle - East	8	Exterior Wall - Ambient	1	x (		x		+	38,43	-		-	19,0	) =	19,4	02ud Wall socle			0,162	90	90	East	0,70	0,40	0,90
34	Section 1 socle - South	8	Exterior Wall - Ambient	1	x (		x		+		-		-	0,0	) =	0,0	02ud Wall socle			0,162	180	90	South	0,70	0,40	0,90
35	Section 1 ground - West	9	Exterior Wall - Ground	1	x (	31,96	x	3,30	+		-	64,40	-	0,0	) =	41,1	04ud Ground walls			0,181						

AREAS DETERMINATION

Building: **Primary School 8 "Sveti Sveti Kiril I Metodij"** Heating demand: **17** kWh/(m²a)

Summary					Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period
Group Nr.	Area group	Temp.-zone	Area	Unit				
1	Treated Floor Area		4630,41	m²	Treated floor area according to PHPP manual		9 months	7 months
2	North Windows	A	258,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the "Windows" worksheet.	0,969	11657	10241
3	East Windows	A	286,55	m²		0,977	16109	15406
4	South Windows	A	348,24	m²		0,969	34616	18986
5	West Windows	A	354,44	m²		0,976	18476	15187
6	Horizontal Windows	A	0,00	m²				
7	Exterior Door	A	7,97	m²	Please subtract area of door from respective building assembly	2,200		
8	Exterior Wall - Ambient	A	2553,98	m²	Temperature Zone "A" is ambient air.	0,143	568	1149
9	Exterior Wall - Ground	B	362,08	m²	Temperature zone "B" is the ground.	0,180		
10	Roof/Ceiling - Ambient	A	1557,73	m²		0,126	3044	4932
11	Floor slab / basement ceiling	B	1557,73	m²		2,597		
12			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
13			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
14		X	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f _r < 1):			
					Factor for X			
					75%			
15	Thermal Bridges Ambient	A	316,95	m	Units in m	Ψ [W/(mK)]		
16	Perimeter Thermal Bridges	P	273,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	0,062		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	-0,221		
18	Partition Wall to Neighbour	I	28,60	m²	No heat losses, only considered for the heating load calculation.	0,782		
Total thermal envelope					Average Therm. Envelope	0,804		

[Go to building components list](#)

36	Section 1 ground - North	9	Exterior Wall - Ground	1	x (	11,90	x	3,30	+		-	23,96	)	-	0,0	=	15,3	04ud Ground walls			0,181							
37	Section 1 ground - East	9	Exterior Wall - Ground	1	x (	26,70	x	3,30	+		-	38,43	)	-	0,0	=	49,7	04ud Ground walls			0,181							
38	Section 1 Roof	10	Roof/Ceiling - Ambient	1	x (		x		+	812,07	-		)	-	0,0	=	812,1	03ud Ventilated roof			0,126	0	0	Hor	0,70	0,90	0,90	
39	Section 1 Floor	11	Floor slab / basement ceiling	1	x (		x		+	812,07	-	296,98	)	-	0,0	=	515,1	09ud Floor Block A			3,181							
40	Wall to Sector D	18	Partition Wall to Neighbour	1	x (	4,00	x	7,15	+		-		)	-	0,0	=	28,6	07ud Inside brick wall			0,782							
41	Section 1 Floor	11	Floor slab / basement ceiling	1	x (		x		+	296,98	-		)	-	0,0	=	297,0	05ud Floor to unheated basement			0,344							
42					x (		x		+		-		)	-	0,0	=												
43					x (		x		+		-		)	-	0,0	=												
44					x (		x		+		-		)	-	0,0	=												
45					x (		x		+		-		)	-	0,0	=												
46					x (		x		+		-		)	-	0,0	=												
47					x (		x		+		-		)	-	0,0	=												
48					x (		x		+		-		)	-	0,0	=												
49					x (		x		+		-		)	-	0,0	=												
50					x (		x		+		-		)	-	0,0	=												
Aend																												

AREAS DETERMINATION

Building: **Primary School 8 "Sveti Sveti Kiril I Metodij"** Heating demand: **17** kWh/(m²a)

Summary					Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period
Group Nr.	Area group	Temp.-zone	Area	Unit				
1	Treated Floor Area		4630,41	m²	Treated floor area according to PHPP manual		9 months	7 months
2	North Windows	A	258,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	0,969	11657	10241
3	East Windows	A	286,55	m²		0,977	16109	15406
4	South Windows	A	348,24	m²		0,969	34616	18986
5	West Windows	A	354,44	m²		0,976	18476	15187
6	Horizontal Windows	A	0,00	m²				
7	Exterior Door	A	7,97	m²	Please subtract area of door from respective building assembly	2,200		
8	Exterior Wall - Ambient	A	2553,98	m²	Temperature Zone "A" is ambient air.	0,143	568	1149
9	Exterior Wall - Ground	B	362,08	m²	Temperature zone "B" is the ground.	0,180		
10	Roof/Ceiling - Ambient	A	1557,73	m²		0,126	3044	4932
11	Floor slab / basement ceiling	B	1557,73	m²		2,597		
12			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
13			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"			
14		X	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f _r < 1):	Factor for X 75%		
Thermal bridges - Overview						Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	316,95	m	Units in m		0,062	
16	Perimeter Thermal Bridges	P	273,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).		-0,221	
17	Thermal bridges FS/BC	B	0,00	m	Units in m			
18	Partition Wall to Neighbour	I	28,60	m²	No heat losses, only considered for the heating load calculation.		0,782	
Total thermal envelope							0,804	

[Go to building components list](#)

Thermal Bridge Inputs										
Nr.	Thermal bridge description	Group Nr.	Assigned to group	Quantity	X (	User determined length [m]	-	Subtraction user-determined length [m]	=	Length ℓ [m]
1	Ceiling to walls connect	15	Thermal Bridges Ambient	1	X (	123,50	-		=	123,50
2	Entrance ceiling to wall	15	Thermal Bridges Ambient	1	X (	7,45	-		=	7,45
3	Entrance floor to walls	16	Perimeter Thermal Bridges	1	X (	6,45	-		=	6,45
4	Consola entrance East	15	Thermal Bridges Ambient	1	X (	1,50	-		=	1,50
5	Consola entrance South	15	Thermal Bridges Ambient	1	X (	2,00	-		=	2,00
6	Consola entrance North	15	Thermal Bridges Ambient	1	X (	2,00	-		=	2,00
7	Ceiling to walls connect	15	Thermal Bridges Ambient	1	X (	136,20	-		=	136,20
8	Consola entrance South	15	Thermal Bridges Ambient	1	X (	3,45	-		=	3,45
9	Consola entrance West	15	Thermal Bridges Ambient	1	X (	6,20	-		=	6,20
10	Consola entrance East 1	15	Thermal Bridges Ambient	1	X (	2,65	-		=	2,65
11	Consola entrance East 2	15	Thermal Bridges Ambient	1	X (	6,30	-		=	6,30
12	Steirs South	16	Perimeter Thermal Bridges	1	X (	3,45	-		=	3,45
13	Steirs West	16	Perimeter Thermal Bridges	1	X (	6,20	-		=	6,20
14	Steirs East 2	16	Perimeter Thermal Bridges	1	X (	6,30	-		=	6,30
15	Ceiling to walls connect	16	Perimeter Thermal Bridges	1	X (	51,40	-		=	51,40
16	Consola	15	Thermal Bridges Ambient	1	X (	22,00	-		=	22,00
17	Насип	16	Perimeter Thermal Bridges	1	X (	20,95	-		=	20,95
18	Stairs	15	Thermal Bridges Ambient	1	X (	3,70	-		=	3,70
19	Wall to ground SectA	16	Perimeter Thermal Bridges	1	X (	26,75	-		=	26,75
20	Walls to ground Sect B	16	Perimeter Thermal Bridges	1	X (	151,60	-		=	151,60
21					X (		-		=	
22					X (		-		=	
23					X (		-		=	
24					X (		-		=	
25					X (		-		=	
26					X (		-		=	
27					X (		-		=	
28					X (		-		=	
29					X (		-		=	
30					X (		-		=	
31					X (		-		=	
32					X (		-		=	
33					X (		-		=	
34					X (		-		=	
35					X (		-		=	
36					X (		-		=	
37					X (		-		=	
38					X (		-		=	
39					X (		-		=	

AREAS DETERMINATION

Building: Primary School 8 "Sveti Sveti Kiril I Metodij" Heating Demand: 17 kWh/(m²a)

Summary					Comment	Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period
Group Nr.	Area group	Temp.-zone	Area	Unit					
1	Treated Floor Area		4630,41	m²	Treated floor area according to PHPP manual			9 months	7 months
2	North Windows	A	258,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	North Windows	0,969	11657	10241
3	East Windows	A	286,55	m²		East Windows	0,977	16109	15406
4	South Windows	A	348,24	m²		South Windows	0,969	34616	18986
5	West Windows	A	354,44	m²		West Windows	0,976	18476	15187
6	Horizontal Windows	A	0,00	m²		Horizontal Windows			
7	Exterior Door	A	7,97	m²	Please subtract area of door from respective building assembly	Exterior Door	2,200		
8	Exterior Wall - Ambient	A	2553,98	m²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	0,143	568	1149
9	Exterior Wall - Ground	B	362,08	m²	Temperature zone "B" is the ground.	Exterior Wall - Ground	0,180		
10	Roof/Ceiling - Ambient	A	1557,73	m²		Roof/Ceiling - Ambient	0,126	3044	4932
11	Floor slab / basement ceiling	B	1557,73	m²		Floor slab / basement ceiling	2,597		
12			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"				
13			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "T"				
14		X	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	Factor for X	75%		
Thermal bridges - Overview							Σ [W/(mK)]		
15	Thermal Bridges Ambient	A	316,95	m	Units in m	Thermal Bridges Ambient	0,062		
16	Perimeter Thermal Bridges	P	273,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,221		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	28,60	m²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour	0,782		
Total thermal envelope			7287,27	m²		Average Therm. Envelope	0,804		

[Go to building components list](#)

40					x (	-	) =			
41					x (	-	) =			
42					x (	-	) =			
43					x (	-	) =			
44					x (	-	) =			
45					x (	-	) =			
46					x (	-	) =			
47					x (	-	) =			
48					x (	-	) =			
49					x (	-	) =			
50					x (	-	) =			
TBend										

A tool for thermal bridge conversion to exterior dimensions						
Description		Units	of perimeter			
Adjacent Area I	Ψ Interior Dimensions	W/(mK)	0,699	0,213	0,256	
	Temperature Diff. TB	K	20,000	20,000	20,000	
	Temperature Diff. Δφ I	K	20,000	20,000	20,000	
	Exterior - Interior Dim. I	m	0,235	0,235	0,235	
Adjacent Area II	U-Value building assembly I	W/(m²K)	1,326	0,142	0,142	
	Temperature Diff. Δφ II	K	20,000	20,000	20,000	
	Exterior - Interior Dim. II	m	0,275	0,275	0,275	
	U-Value building assembly II	W/(m²K)	0,131	0,131	0,131	
Ψ Exterior Dimensions		W/(mK)	0.351	0.144	0.187	

Building part 1

Ground characteristics			
Thermal conductivity	λ	2,0	W/(mK)
Heat capacity	ρC	2,0	MJ/(m³K)
Periodic Penetration Depth	δ	3,17	m

Climate data			
Av. Indoor Temp. Winter	T_i	20,0	°C
Av. Indoor Temp. Summer	T_i	25,0	°C
Average Ground Surface Temperature	$T_{g,ave}$	11,4	°C
Amplitude of $T_{g,ave}$	$T_{g,\Delta}$	11,4	°C
Phase shifting of $T_{e,m}$	τ	1,0	Months
Length of the Heating Period	n	6,4	Months
Heating Degree Hours - Exterior	G_e	76,7	kKh/a

Building data			
Area of ground floor slab / basement ceiling	A	1557,7	m²
Perimeter length	P	291,4	m
Charact. Dimension of floor slab	B'	10,69	m
U-value floor slab/basement ceiling	U_f	2,597	W/(m²K)
Thermal bridges floor slab/basement ceiling	$\Psi_{B',f}$	0,00	W/K
U-value floor slab / basement ceiling incl. TB	U_f'	2,597	W/(m²K)
Eq. Thickness Floor	d_f	0,77	m

Floor Slab Type (select only one)

Slab on Grade			
Perimeter Insulation Width/Depth	D		m
Perimeter Insulation Thickness	d_n		m
Conductivity perimeter insulation	λ_n		W/(mK)
Orientation of the Perimeter Ins.		horizontal	
(check only one field)		vertical	X
X Heated basement or floor slab completely / partially below ground level			
Basement wall height below ground level	z	1,71	m
U-Value below ground wall	U_{WB}	0,181	W/(m²K)
Unheated basement			
Height aboveground wall	h		m
Basement wall height below ground level	z		m
Air Change Unheated Basement	n		h⁻¹
Air flow basement	V		m³
Suspended Floor Above a Ventilated Crawl Space (at max. 0.5 m Below Ground)			
U-Value Crawl Space	U_{Crawl}		W/(m²K)
Height of crawl space wall	h		m
U-Value crawl space wall	U_W		W/(m²K)
Area of Ventilation Openings	εP		m²
Wind Velocity at 10 m Height	v	4,0	m/s
Wind Shield factor	f_W	0,05	-

Additional Thermal Bridge Heat Losses at Perimeter			
Phase shift	β		Months
Steady-State Fraction	$\Psi_{P,stat}^{*I}$	-60,290	W/K
Harmonic Fraction	$\Psi_{P,harm}^{*I}$	-60,290	W/K

Groundwater correction			
Depth of the Groundwater Table	z_w	3,0	m
Groundwater flow rate	q_w	0,05	m/d
Groundwater Correction Factor	G_w	1,14964435	-

Interim Results

Phase shift	β	0,81 Months	Steady-state heat flow	Φ_{stat}	5461,2 W
Steady-state transmittance	L_S	636,21 W/K	Periodic Heat Flow	Φ_{harm}	1171,0 W
Exterior Periodic transmittance	L_{pe}	190,12 W/K	Heat Losses During Heating Period	Q_{tot}	30875 kWh
Transmittance building	L_0	4075,15 W/K			

Monthly Average temperatures in the ground for monthly method (building assembly 1)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	18,2	18,1	18,2	18,4	18,7	19,0	19,1	19,2	19,1	18,9	18,6	18,4	18,7
Summer	22,4	22,4	22,4	22,7	22,9	23,2	23,4	23,4	23,3	23,1	22,8	22,6	22,9

Design ground temperature for 'Heating load' worksheet

18,1

For 'Cooling load' worksheet

23,4

Reduction factor for 'Annual heating' worksheet

0,10

Total result (all building parts)

Phase shift	β	0,81 Months	Steady-state heat flow	Φ_{stat}	5461,2 W
Steady-state transmittance	L_S	636,21 W/K	Periodic Heat Flow	Φ_{harm}	1171,0 W
Exterior Periodic transmittance	L_{pe}	190,12 W/K	Heat Losses During Heating Period	Q_{tot}	30875 kWh
Transmittance building	L_0	4075,15 W/K	Charact. Dimension of floor slab	B'	10,69 m

Monthly Average temperatures in the ground for monthly method (all building assemblies)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	18,2	18,1	18,2	18,4	18,7	19,0	19,1	19,2	19,1	18,9	18,6	18,4	18,7
Summer	22,4	22,4	22,4	22,7	22,9	23,2	23,4	23,4	23,3	23,1	22,8	22,6	22,9

Design ground temperature for 'Heating load' worksheet

18,1

For 'Cooling load' worksheet

23,4

Reduction factor for 'Annual heating' worksheet

0,10

Either there are inconsistencies between the building assemblies in contact with the ground entered in the worksheets 'Areas' and 'Ground' OR you made an incorrect selection of the typ

Go to: ['AREAS'](#)
[Glazing](#)
[Window frame](#)

<http://www.passiv.de/komponentendatenbank/en-EN>
[Ventilation units](#)
[Compact units](#)

Building assemblies (U-values)					
1					
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
	Summary of the constructions calculated in 'U values' worksheet		m	W/(m²K)	-
01ud	Brick walls	Brick walls	0,550	0,142	
02ud	Wall socle	Wall socle	0,660	0,162	
03ud	Ventilated roof	Ventilated roof	0,555	0,126	
04ud	Ground walls	Ground walls	0,608	0,181	
05ud	Floor to unheated basement	Floor to unheated basement	0,320	0,344	
06ud	Floor	Floor	0,350	3,181	
07ud	Inside brick wall	Inside brick wall	0,330	0,782	
08ud	Non ventilated roof	Non ventilated roof	0,178	2,906	
09ud	Floor Block A	Floor Block A	0,350	3,181	yes
10ud	Floor to unheated basement Block C	Floor to unheated basement Block C	0,220	2,127	
11ud	Ground walls Sector B	Ground walls Sector B	0,708	0,179	
12ud	Wall socle Sector B	Wall socle Sector B	0,800	0,134	
13ud					
14ud					
15ud					
16ud					
17ud					
18ud					
19ud					
20ud					
21ud					
22ud					
23ud					
24ud					
25ud					
26ud					
27ud					
28ud					
29ud					
30ud					
31ud					
32ud					
33ud					
34ud					
35ud					
36ud					
37ud					
38ud					
39ud					
40ud					
41ud					
42ud					
43ud					
44ud					
45ud					

Building assemblies (U-values)					
		1			
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
	Summary of the constructions calculated in 'U values' worksheet		m	W/(m²K)	-
46ud					
47ud					
48ud					
49ud					
50ud					
51ud					
52ud					
53ud					
54ud					
55ud					
56ud					
57ud					
58ud					
59ud					
60ud					
61ud					
62ud					
63ud					
64ud					
65ud					
66ud					
67ud					
68ud					
69ud					
70ud					
71ud					
72ud					
73ud					
74ud					
75ud					
76ud					
77ud					
78ud					
79ud					
80ud					
81ud					
82ud					
83ud					
84ud					
85ud					
86ud					
87ud					
88ud					
89ud					
90ud					
91ud					
92ud					
93ud	Brickwork 24 years old	Brickwork 24 years old	0,275	1,440	
94ud	Solid Brick 38-old	Solid Brick 38-old	0,415	1,640	
95ud	Half timbered 18-old	Half timbered 18-old	0,210	1,800	
96ud	Brickwork 30 years old	Brickwork 30 years old	0,335	1,230	

Building assemblies (U-values)					
		1			
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
	Summary of the constructions calculated in 'U values' worksheet		m	W/(m²K)	-
97ud	Precast concrete-old	Precast concrete-old	0,275	1,300	
98ud	Wooden joist ceiling-old	Wooden joist ceiling-old	0,284	0,990	
99ud	Basement ceiling-old	Basement ceiling-old	0,242	1,230	

Glazing		Glazing	
ID	Description	g-Value	U _g -Value
			W/(m²K)
01ud	44 mm. triple glazing, 2 Low-E, air, alum.spacer	0,51	0,80
02ud			
03ud			
04ud			
05ud			
06ud			
07ud			
08ud			
09ud			
10ud			
11ud			
12ud			
13ud			
14ud			
15ud			
16ud			
17ud			
18ud			
19ud			
20ud			
21ud			
22ud			
23ud			
24ud			
25ud			
26ud			
27ud			
28ud			
29ud			
30ud			
31ud			
32ud			
33ud			
34ud			
35ud			
36ud			
37ud			
38ud			
39ud			
40ud			
41ud			
42ud			
43ud			
44ud			
45ud			
46ud			
47ud			
48ud			
49ud			
50ud			
51ud			

Glazing		Glazing	
ID	Description	g-Value	U _g -Value
			W/(m²K)
52ud			
53ud			
54ud			
55ud			
56ud			
57ud			
58ud			
59ud			
60ud			
61ud			
62ud			
63ud			
64ud			
65ud			
66ud			
67ud			
68ud			
69ud			
70ud			
71ud			
72ud			
73ud			
74ud			
75ud			
76ud			
77ud			
78ud			
79ud			
80ud			
81ud			
82ud			
83ud			
84ud			
85ud			
86ud			
87ud			
88ud			
89ud			
90ud			
91ud			
92ud	Single glazing	0,87	5,80
93ud	Double glazing 4/12mm air/4	0,77	2,90
94ud	Double glazing 4/16mm air/4	0,77	2,70
95ud	Double glazing 4/20mm air/4	0,77	2,80
96ud	Double glazing 4/25mm air/4	0,77	2,80
97ud	Double glazing 4/30mm air/4	0,77	2,80
98ud	Triple glazing 4/10 air/4/10 air/4	0,70	2,00
99ud	Double low-e 4/16Argon90%/4 Epsilon=0.1	0,64	1,30

Window frames										Window frames									
ID	Description	U _f -Value				Frame Width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:	
		left	right	bottom	above	left	right	bottom	above	Ψ _{Glazing edge left}	Ψ _{Glazing edge right}	Ψ _{Glazing edge bottom}	Ψ _{Glazing edge top}	Ψ _{Installation left}	Ψ _{Installation right}	Ψ _{Installation bottom}	Ψ _{Installation top}	χ _{GC} -value	Glass carrier
		W/(m²K)	W/(m²K)	W/(m²K)	W/(m²K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K	
01ud	Plastic window frame good	1,60	1,60	1,60	1,60	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040		
02ud	Plastic window frame good after wall insulation	1,60	1,60	1,60	1,60	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,088	0,088	0,088	0,088		
03ud	VEKA AG ALPHALINE 90 MD	0,97	0,97	0,97	0,97	0,118	0,118	0,118	0,118	0,030	0,030	0,030	0,030	0,040	0,040	0,040	0,040		
04ud																			
05ud																			
06ud																			
07ud																			
08ud																			
09ud																			
10ud																			
11ud																			
12ud																			
13ud																			
14ud																			
15ud																			
16ud																			
17ud																			
18ud																			
19ud																			
20ud																			
21ud																			
22ud																			
23ud																			
24ud																			
25ud																			
26ud																			
27ud																			
28ud																			
29ud																			
30ud																			
31ud																			
32ud																			
33ud																			
34ud																			
35ud																			
36ud																			
37ud																			
38ud																			
39ud																			
40ud																			
41ud																			
42ud																			
43ud																			
44ud																			
45ud																			
46ud																			
47ud																			
48ud																			
49ud																			
50ud																			
51ud	PH-FRAMES: average thermal quality	0,75	0,75	0,75	0,75	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040		

Window frames										Window frames									
ID	Description	U _F -Value				Frame Width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:	
		left	right	bottom	above	left	right	bottom	above	Ψ _{Glazing edge left}	Ψ _{Glazing edge right}	Ψ _{Glazing edge bottom}	Ψ _{Glazing edge top}	Ψ _{Installation left}	Ψ _{Installation right}	Ψ _{Installation bottom}	Ψ _{Installation top}	λ _{GC} -value Glass carrier	
		W/(m²K)	W/(m²K)	W/(m²K)	W/(m²K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K	
52ud	PH-FRAMES: good thermal quality	0,72	0,72	0,72	0,72	0,140	0,140	0,140	0,140	0,035	0,035	0,035	0,035	0,040	0,040	0,040	0,040		
53ud	EXISTING: timber 45 mm	2,50	2,50	2,50	2,50	0,140	0,140	0,140	0,140	0,050	0,050	0,050	0,050	0,040	0,040	0,040	0,040		
54ud	EXISTING: timber 68 mm	1,60	1,60	1,60	1,60	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040		
55ud	EXISTING: synthetic, good	1,60	1,60	1,60	1,60	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040		
56ud	EXISTING: synthetic before 1998	1,80	1,80	1,80	1,80	0,140	0,140	0,140	0,140	0,050	0,050	0,050	0,050	0,040	0,040	0,040	0,040		
57ud	EXISTING: synthetic, before 1972	2,20	2,20	2,20	2,20	0,140	0,140	0,140	0,140	0,050	0,050	0,050	0,050	0,040	0,040	0,040	0,040		
58ud	EXISTING: metal, thermal break	2,40	2,40	2,40	2,40	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040		
59ud	EXISTING: metal, no thermal break	4,50	4,50	4,50	4,50	0,140	0,140	0,140	0,140	0,030	0,030	0,030	0,030	0,040	0,040	0,040	0,040		
60ud	EXISTING: metal, no thermal break, paint finish	5,50	5,50	5,50	5,50	0,140	0,140	0,140	0,140	0,030	0,030	0,030	0,030	0,040	0,040	0,040	0,040		
61ud	INSTALLATION SITUATION: timber, not insulated, masonry, not insulated													0,088					
62ud	INSTALLATION SITUATION: timber, not insulated, covered with 60 mm insulation													0,002					
63ud	INSTALLATION SITUATION: PVC, not insulated, masonry, not insulated													0,088					
64ud	INSTALLATION SITUATION: PVC, not insulated, überdämmt mit WDVS 60 mm													0,002					
65ud	INSTALLATION SITUATION: Metal, no thermal break, masonry wall, insulated													0,088					
66ud	INSTALLATION SITUATION: insulated timber, EIFS, in insulation layer													0,009					
67ud	INSTALLATION SITUATION: insulated timber, EIFS, partially on masonry													0,021					
68ud	INSTALLATION SITUATION: insulated timber, EIFS, flush with the masonry													0,076					
69ud	INSTALLATION SITUATION: insulated timber, lightweight wall (optimal)													0,009					
70ud	INSTALLATION SITUATION: insulated timber, insulated concrete formwork													0,001					
71ud	INSTALLATION SITUATION: insulated PVC, EIFS, insulation layer													0,009					
72ud	INSTALLATION SITUATION: insulated PVC, EIFS, partially on masonry													0,021					
73ud	INSTALLATION SITUATION: insulated PVC, EIFS, flush with the masonry													0,076					
74ud	INSTALLATION SITUATION: insulated PVC, lightweight wall (optimal)													0,009					
75ud	INSTALLATION SITUATION: insulated PVC, insulated concrete formwork													0,001					
76ud	INSTALLATION SITUATION: insulated timber-aluminium, EIFS, insulated													0,013					
77ud	INSTALLATION SITUATION: insulated timber-aluminium, EIFS, partially insulated													0,023					
78ud	INSTALLATION SITUATION: insulated timber-aluminium, lightweight wall													0,013					
79ud	INSTALLATION SITUATION: insulated timber-aluminium, insulated concrete													0,002					
80ud	INSTALLATION SITUATION: insulated timber-aluminium, insulated concrete													0,013					
81ud	INSTALLATION SITUATION: insulated timber-aluminium, short aluminium													0,002					
82ud	INSTALLATION SITUATION: insulated timber-aluminium, short aluminium													0,010					
83ud	INSTALLATION SITUATION: insulated timber-aluminium, short aluminium													0,006					
84ud	INSTALLATION SITUATION: insulated timber-aluminium, short aluminium													0,013					
85ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, outside, in front of the facade													0,343					
86ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, flush with the facade on the outside													0,036					
87ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, in the insulation layer													0,034					
88ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, between insulation layer and wall													0,059					
89ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, flush with the insulation layer on the inside													0,397					
90ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, outside, in front of the facade													0,666					
91ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, flush with the insulation layer on the outside													0,047					
92ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, in the insulation layer													0,044					
93ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, between insulation layer and wall													0,062					
94ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, flush with the insulation layer on the inside													0,409					
95ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, outside, in front of the facade													0,747					
96ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, flush with the insulation layer on the outside													0,056					
97ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, in the insulation layer													0,053					
98ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, between insulation layer and wall													0,070					
99ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, flush with the insulation layer on the inside													0,421					

Ventilation units with heat recovery					Ventilation units with heat recovery								
					Additional Device Data								
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection			Additional info
	User defined area	%	%	Wh/m³	m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)	
01ud	Tangra ventilation unit EVB 04 HiE	82%	0%	0,40	150	400	100	incl.	yes	–	57	57	
02ud	Tangra ventilation unit EVB 06 HiE	82%	0%	0,40	250	600	100	incl.	yes	–	61	61	
03ud	Tangra ventilation unit EVB 08 HiE	82%	0%	0,40	400	800			yes	–	61	61	
04ud	Tangra ventilation unit EVB 10 HiE	82%	0%	0,40	500	1000			yes	–	61	61	
05ud	Tangra ventilation unit EVB 12 HiE	82%	0%	0,40	750	1200			yes	–	68	68	
06ud	Tangra ventilation unit EVB 16 HiE	82%	0%	0,40	800	1600			yes	–	68	68	
07ud	Tangra ventilation unit EVB 20 HiE	82%	0%	0,40	1000	2000			yes	–	68	68	
08ud													
09ud													
10ud													
11ud													
12ud													
13ud													
14ud													
15ud													
16ud													
17ud													
18ud													
19ud													
20ud													
21ud													
22ud													
23ud													
24ud													
25ud													
26ud													
27ud													
28ud													
29ud													
30ud													
31ud													
32ud													
33ud													
34ud													
35ud													
36ud													
37ud													
38ud													
39ud													
40ud													
41ud													
42ud													
43ud													
44ud													
45ud													
46ud													
47ud													
48ud													
49ud													
50ud													
51ud													

Ventilation units with heat recovery					Ventilation units with heat recovery								
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Additional Device Data								
					Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection			Additional info
					m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)	
	User defined area	%	%	Wh/m³									
52ud													
53ud													
54ud													
55ud													
56ud													
57ud													
58ud													
59ud													
60ud													
61ud													
62ud													
63ud													
64ud													
65ud													
66ud													
67ud													
68ud													
69ud													
70ud													
71ud													
72ud													
73ud													
74ud													
75ud													
76ud													
77ud													
78ud													
79ud													
80ud													
81ud													
82ud													
83ud													
84ud													
85ud													
86ud													
87ud													
88ud													
89ud													
90ud													
91ud													
92ud													
93ud													
94ud													
95ud													
96ud													
97ud	Default	75%		0,45									
98ud	Extract air system	0%		0,25									
99ud	Compact unit to be chosen from 'Compact' worksheet												

REDUCTION FACTOR SOLAR RADIATION, WINDOW U-VALUE

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B						Annual heating demand: 17		kWh/(m²a)		Heating degree hours:														
Climate:		User data - Велико Търнов														76,7								
Window area orientation	Global radiation (cardinal points)	Shading	Dirt	Non-perpendicular incident radiation	Glazing fraction	g-Value	Solar radiation reduction factor	Window area	Window U-Value	Glazing area	Average global radiation	Transmission losses	Heat gains solar radiation											
maximum:	kWh/(m²a)	0,75	0,95	0,85				m²	W/(m²K)	m²	kWh/(m²a)	kWh/a	kWh/a											
North	127	0,81	0,95	0,85	0,586	0,51	0,38	258,55	0,97	151,54	127	19217	6435											
East	251	0,60	0,95	0,85	0,489	0,51	0,24	286,55	0,98	140,16	251	21456	8646											
South	444	0,68	0,95	0,85	0,507	0,51	0,28	348,24	0,97	176,40	444	25867	21971											
West	253	0,51	0,95	0,85	0,490	0,51	0,20	354,44	0,98	173,79	281	26537	10294											
Horizontal	417	1,00	0,95	0,85	0,000	0,00	0,00	0,00	0,00	0,00	417	0	0											
Total or Average Value for All Windows.						0,51	0,27	1247,78	0,97	641,89		93078	47346											
						Go to glazing list		Go to window frames list																
Quant ity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for Ψ _{installed} or '1': Ψ _{installed} from worksheet 'Components' '0': in the case of abutting windows				Results U- and Ψ-values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.						
		Degrees	Degrees		Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ _{spacer} (centre)	left	right	bottom	above	Ψ _{Installation} (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains
					m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	kWh/a	kWh/a
1	S2/Type 1	180	90	South	0,800	0,900	11-Section 2 socle - South	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	0,7	0,33	1,03	45%	57	38
1	S2/Type 1	180	90	South	1,000	0,900	11-Section 2 socle - South	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	0,9	0,45	1,01	50%	70	54
1	S2/Type 2 level	260	90	West	0,800	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	0,8	0,38	1,02	48%	62	32
1	S2/Type 2 level	260	90	West	0,850	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	0,9	0,42	1,01	49%	66	35
1	S2/Type 2 level	260	90	West	0,800	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	0,8	0,38	1,02	48%	62	32
1	S2/Type 2 level	260	90	West	0,850	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	0,9	0,42	1,01	49%	66	35
1	S2/Type 2 level	260	90	West	0,800	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	0,8	0,38	1,02	48%	62	32
1	S2/Type 2 level	260	90	West	0,850	1,000	1-Section 2 West facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	0,9	0,42	1,01	49%	66	35
1	S2/Type 3 level	260	90	West	0,600	1,150	8-Section 2 socle - West	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	1	1	1	0,040	0,7	0,29	1,10	42%	58	23
12	S2/Type 4	180	90	South	0,800	1,450	11-Section 2 socle - South	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	13,9	7,48	0,99	54%	1055	1000
12	S2/Type 4	180	90	South	1,350	1,450	11-Section 2 socle - South	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	23,5	15,12	0,95	64%	1711	2145
8	S2/Type 4	0	90	North	0,800	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	9,3	4,98	0,99	54%	703	207
4	S2/Type 4	0	90	North	1,350	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	15,7	10,08	0,95	64%	1141	448
4	S2/Type 5	0	90	North	0,700	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	4,1	2,03	1,00	50%	312	82
4	S2/Type 5	0	90	North	0,700	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	4,1	2,03	1,00	50%	312	82
1	S2/Type 6	0	90	North	0,800	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	1,2	0,62	0,99	54%	88	26
1	S2/Type 6	0	90	North	1,300	1,450	9-Section 2 socle - North	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	1,9	1,20	0,95	64%	138	53
15	S2/Type 7 level	0	90	North	0,800	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	18,0	9,75	0,99	54%	1361	406
15	S2/Type 7 level	0	90	North	1,350	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	30,4	19,71	0,95	65%	2207	878
15	S2/Type 7 level	0	90	North	0,800	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	18,0	9,75	0,99	54%	1361	406
15	S2/Type 7 level	0	90	North	1,350	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	30,4	19,71	0,95	65%	2207	878
15	S2/Type 7 level	0	90	North	0,800	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	1	0,040	18,0	9,75	0,99	54%	1361	406
15	S2/Type 7 level	0	90	North	1,350	1,500	2-Section 2 North facade	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	1	0,040	30,4	19,71	0,95	65%	2207	878
10	S2/Type 8 level	180	90	South	1,175	0,400	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 level	180	90	South	1,175	0,400	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 level	180	90	South	0,800	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	0	0,040	12,8	7,04	0,96	55%	939	959
10	S2/Type 8 level	180	90	South	0,750	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	0	1	0	0,040	12,0	6,38	0,91	53%	837	861
10	S2/Type 8 level	180	90	South	0,800	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	0	0,040	12,8	7,04	0,96	55%	939	959
10	S2/Type 8 level	180	90	South	1,175	0,400	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 level	180	90	South	1,175	0,400	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 level	180	90	South	0,800	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	1	0	1	0	0,040	12,8	7,04	0,96	55%	939	959
10	S2/Type 8 level	180	90	South	0,750	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	0	1	0	0,040	12,0	6,38	0,91	53%	837	861
10	S2/Type 8 level	180	90	South	0,800	1,600	4-Section 2 South facade 1	01ud 44 mm, triple glazing, 2 Low-E, air, al0001w03 Rehau - REHAU GENE0 PHZ - w	0,51	0,80	0,79	0,030	0,030	0	1	1	0	0,040	12,8	7,04	0,96	55%	939	959
1	S2/Type 8 level	180	90	South	1,175	0,400	5-Section 2 South facade 2	01ud 44 mm, triple glazing,																

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for Ψ _{member} Or 1°: Ψ _{member} from worksheet 'Components' 0°: in the case of abutting windows					Results U- and Ψ-values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.					
Quant ity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ _{spacer} (centre)	left	right	bottom	above	Ψ _{installation} (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains
		Degrees	Degrees		m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	kWh/a	kWh/a
2	S2/Type 8 Level	0	90	North	0,800	1,600	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	2,6	1,41	0,96	55%	188	59
2	S2/Type 8 Level	0	90	North	1,175	0,400	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	0,9	0,20	1,06	21%	76	6
2	S2/Type 8 Level	0	90	North	1,175	0,400	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	0,9	0,20	1,06	21%	76	6
2	S2/Type 8 Level	0	90	North	0,800	1,600	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	2,6	1,41	0,96	55%	188	59
2	S2/Type 8 Level	0	90	North	0,750	1,600	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	2,4	1,28	0,91	53%	167	53
2	S2/Type 8 Level	0	90	North	0,800	1,600	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	2,6	1,41	0,96	55%	188	59
10	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	4,7	0,99	1,06	21%	381	66
10	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	12,8	7,04	0,96	55%	939	959
10	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	12,0	6,38	0,91	53%	837	861
10	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	12,8	7,04	0,96	55%	939	959
1	S2/Type 8 Level	180	90	South	1,175	0,400	5-Section 2 South fasade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	0,5	0,10	1,06	21%	38	7
1	S2/Type 8 Level	180	90	South	1,175	0,400	5-Section 2 South fasade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	0,5	0,10	1,06	21%	38	7
1	S2/Type 8 Level	180	90	South	0,800	1,600	5-Section 2 South fasade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	1,3	0,70	0,96	55%	94	96
1	S2/Type 8 Level	180	90	South	0,750	1,600	5-Section 2 South fasade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	1,2	0,64	0,91	53%	84	86
1	S2/Type 8 Level	180	90	South	0,800	1,600	5-Section 2 South fasade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	1,3	0,70	0,96	55%	94	96
2	S2/Type 9	0	90	North	0,800	0,800	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	0	1	0,040	1,3	0,63	1,17	50%	115	12
2	S2/Type 9	0	90	North	0,800	0,800	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	1	0,040	1,3	0,63	1,17	50%	115	12
2	S2/Type 9	0	90	North	0,800	1,400	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	0	0	0,040	2,2	1,32	1,07	59%	184	32
2	S2/Type 9	0	90	North	0,800	1,400	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	0	0,040	2,2	1,32	1,07	59%	184	32
2	S2/Type 9	0	90	North	0,800	0,800	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	1	0	0,040	1,3	0,63	1,17	50%	115	12
2	S2/Type 9	0	90	North	0,800	0,800	2-Section 2 North fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	1	0	0,040	1,3	0,63	1,17	50%	115	12
1	S2/Type 10	0	90	North	1,100	0,800	9-Section 2 socle - North	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	1	0,040	0,9	0,43	1,06	48%	71	17
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,30	1,06	21%	114	15
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,30	1,06	21%	114	15
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	3,8	2,11	0,96	55%	282	216
3	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	3,6	1,91	0,91	53%	251	194
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	3,8	2,11	0,96	55%	282	216
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,30	1,06	21%	114	11
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,30	1,06	21%	114	11
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	3,8	2,11	0,96	55%	282	167
3	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	3,6	1,91	0,91	53%	251	150
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	3,8	2,11	0,96	55%	282	167
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,30	1,06	21%	114	13
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,30	1,06	21%	114	13
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	3,8	2,11	0,96	55%	282	184
3	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	3,6	1,91	0,91	53%	251	165
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	3,8	2,11	0,96	55%	282	184
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,30	1,06	21%	114	14
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,30	1,06	21%	114	14
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	3,8	2,11	0,96	55%	282	201
3	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	3,6	1,91	0,91	53%	251	181
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	3,8	2,11	0,96	55%	282	201
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,30	1,06	21%	114	15
3	S2/Type 8 Level	180	90	South	1,175	0,400	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,30	1,06	21%	114	15
3	S2/Type 8 Level	180	90	South	0,800	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	3,8	2,11	0,96	55%	282	216
3	S2/Type 8 Level	180	90	South	0,750	1,600	4-Section 2 South fasade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	3,6	1,91	0,91	53%	251	194
2	S1/Type 3 Level	90	90	East	0,600	1,150	19-Section 3 East fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w</																

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for Ψ _{member} Or 1°: Ψ _{member} from worksheet 'Components' 0°: in the case of abutting windows				Ψ _{installation} (Average)		Results U- and Ψ-values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.					
Quant ity	Description	Deviation from North	Angle of inclination from the horizontal	Orientatio n	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpen- dicular Radiation	Glazing	Frames (centre)	Ψ _{spacer} (centre)	left	right	bottom	above	Ψ _{installation} (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Trans- mission- losses	Solar gains	
		Degrees	Degrees		m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	kWh/a	kWh/a	
7	S1/Type 16	180	90	South	0,850	0,700	19-Section 3 South fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	1	0,040	4,2	1,68	1,01	40%	322	178	
7	S1/Type 16	180	90	South	0,900	0,700	19-Section 3 South fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	1	0,040	4,4	1,82	1,05	41%	356	194	
1	L-1 W Type 6	260	90	West	1,175	0,450	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	0,5	0,14	1,04	27%	42	5	
1	L-1 W Type 6	260	90	West	1,175	0,450	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	0,5	0,14	1,04	27%	42	5	
1	L-1 W Type 6	260	90	West	0,800	1,600	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	1,3	0,70	0,96	55%	94	28	
1	L-1 W Type 6	260	90	West	0,750	1,600	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	1,2	0,64	0,91	53%	84	25	
1	L-1 W Type 6	260	90	West	0,800	1,600	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	1,3	0,70	0,96	55%	94	28	
5	L-1 W Type 7	260	90	West	0,800	1,350	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	1	0,040	5,4	2,85	0,99	53%	411	113	
5	L-1 W Type 7	260	90	West	0,750	1,350	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	1	0,040	5,1	2,58	0,95	51%	367	101	
1	L-1 W Type 7	260	90	West	0,800	1,350	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	1	0,040	5,4	2,85	0,99	53%	411	113	
1	L-1 W Type 1	260	90	West	0,550	0,900	31-Section 1 socle - West	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	1	0,040	0,5	0,18	1,14	35%	43	6	
6	L-1 E Type 7	90	90	East	0,800	1,350	33-Section 1 socle - East	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	1	0,040	6,5	3,42	0,99	53%	493	121	
6	L-1 E Type 7	90	90	East	0,750	1,350	33-Section 1 socle - East	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	1	0,040	6,1	3,10	0,95	51%	441	108	
6	L-1 E Type 7	90	90	East	0,800	1,350	33-Section 1 socle - East	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	1	0,040	6,5	3,42	0,99	53%	493	121	
10	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	5,3	1,44	1,04	27%	421	67	
10	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	5,3	1,44	1,04	27%	421	67	
10	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	12,8	7,04	0,96	55%	939	399	
10	L 0 W Type 6 - a	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	12,0	6,38	0,91	53%	837	356	
10	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	12,8	7,04	0,96	55%	939	399	
2	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,1	0,29	1,04	27%	84	8	
2	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,1	0,29	1,04	27%	84	8	
2	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	2,6	1,41	0,96	55%	188	50	
2	L 0 W Type 6 - a	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	2,4	1,28	0,91	53%	167	44	
2	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	2,6	1,41	0,96	55%	188	50	
2	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,1	0,29	1,04	27%	84	13	
2	L 0 W Type 6 - a	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,12	0,031	0	1	0	1	0,040	1,1	0,39	1,26	37%	102	6	
2	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	1	0	1	0	0,040	2,6	1,54	1,09	60%	214	50	
2	L 0 W Type 6 - a	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	0	1	0	0,040	2,4	1,41	1,05	59%	193	45	
2	L 0 W Type 6 - a	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	1	1	0	0,040	2,6	1,54	1,09	60%	214	50	
2	L 0 W Type 2	260	90	West	0,850	0,450	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	0	1	0,040	0,8	0,19	1,09	24%	64	8	
2	L 0 W Type 2	260	90	West	0,850	1,600	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	0	0,040	2,7	1,54	1,00	57%	208	88	
2	01/Door 1 (Glasse)	260	90	West	0,800	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	1	0	0	1	0,040	1,3	0,63	1,17	50%	115	19	
2	01/Door 1 (Glasse)	260	90	West	0,900	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	0	0	1	0,040	1,4	0,75	1,11	52%	122	23	
2	01/Door 1 (Glasse)	260	90	West	0,800	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	1	0	1	0,040	1,3	0,63	1,17	50%	115	19	
2	01/Door 1 (Glasse)	260	90	West	0,800	1,400	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	1	0	0	0	0,040	2,2	1,32	1,07	59%	184	57	
2	01/Door 1 (Glasse)	260	90	West	0,900	1,400	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	0	0	0	0,040	2,5	1,55	1,01	61%	195	69	
2	01/Door 1 (Glasse)	260	90	West	0,800	1,400	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	1	0	0	0,040	2,2	1,32	1,07	59%	184	57	
2	01/Door 1 (Glasse)	260	90	West	0,800	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	1	0	1	0	0,040	1,3	0,63	1,17	50%	115	19	
2	01/Door 1 (Glasse)	260	90	West	0,900	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	0	1	0	0,040	1,4	0,75	1,11	52%	122	23	
2	01/Door 1 (Glasse)	260	90	West	0,800	0,800	23-Section 1 - West fasade	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	1,11	0,031	0	1	1	0	0,040	1,3	0,63	1,17	50%	115	19	
3	01/Type 8 South	180	90	South	1,000	0,450	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	1,4	0,35	1,04	26%	108	46	
3	01/Type 8 South	180	90	South	0,950	0,450	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	0	1	0,040	1,3	0,33	1,00	25%	98	42	
3	01/Type 8 South	180	90	South	1,000	0,450	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	1,4	0,35	1,04	26%	108	46	
3	01/Type 8 South	180	90	South	1,000	1,600	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	4,8	2,90	0,94	60%	345	455	
3	01/Type 8 South	180	90	South	0,950	1,600	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	4,6	2,70	0,90	59%	315	422	
3	01/Type 8 South	180	90	South	1,000	1,600	29-Section 1 - South 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	4,8	2,90	0,94	60%	345	455	
2	01/Type 8 NORTH	0	90	North	1,000	0,450	24-Section 1 - North 1 fasad	01ud 44 mm. triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	0,9						

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for Ψ _{member} Or 1°: Ψ _{member} from worksheet 'Components' 0°: in the case of abutting windows				Results U- and Ψ-values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.						
Quant ity	Description	Deviation from North	Angle of inclination from the horizontal	Orientatio n	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpen- dicular Radiation	Glazing	Frames (centre)	Ψ _{spacer} (centre)	left	right	bottom	above	Ψ _{installation} (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Trans- mission- losses	Solar gains
		Degrees	Degrees		m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	kWh/a	kWh/a
1	01/Type 8 NORTH	0	90	North	1,000	1,600	23-Section 1 - North 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	1,6	0,97	0,94	60%	115	0
16	L 1 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 1 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 1 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	20,5	11,26	0,96	55%	1503	0
16	L 1 W Type 6	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	19,2	10,21	0,91	53%	1340	0
16	L 1 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	20,5	11,26	0,96	55%	1503	0
2	L 1 W Type 2	260	90	West	0,850	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	0	1	0,040	0,8	0,19	1,09	24%	64	0
2	L 1 W Type 2	260	90	West	0,850	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	0	0,040	2,7	1,54	1,00	57%	208	0
16	L 2 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 2 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 2 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	20,5	11,26	0,96	55%	1503	0
16	L 2 W Type 6	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	19,2	10,21	0,91	53%	1340	0
16	L 2 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	20,5	11,26	0,96	55%	1503	0
2	L 2 W Type 2	260	90	West	0,850	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	0	1	0,040	0,8	0,19	1,09	24%	64	0
2	L 2 W Type 2	260	90	West	0,850	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	0	0,040	2,7	1,54	1,00	57%	208	0
16	L 3 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 3 W Type 6	260	90	West	1,175	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	8,5	2,31	1,04	27%	673	0
16	L 3 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	20,5	11,26	0,96	55%	1503	0
16	L 3 W Type 6	260	90	West	0,750	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	19,2	10,21	0,91	53%	1340	0
16	L 3 W Type 6	260	90	West	0,800	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	20,5	11,26	0,96	55%	1503	0
2	L 3 W Type 2	260	90	West	0,850	0,450	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	0	1	0,040	0,8	0,19	1,09	24%	64	0
2	L 3 W Type 2	260	90	West	0,850	1,600	23-Section 1 - West fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	1	1	0	0,040	2,7	1,54	1,00	57%	208	0
20	L0, 1, 2, 3 E Type	90	90	East	1,175	0,450	26-Section 1 - East 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	10,6	2,89	1,04	27%	841	0
20	L0, 1, 2, 3 E Type	90	90	East	1,175	0,450	26-Section 1 - East 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	10,6	2,89	1,04	27%	841	0
20	L0, 1, 2, 3 E Type	90	90	East	0,800	1,600	26-Section 1 - East 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	0	0,040	25,6	14,07	0,96	55%	1879	0
20	L0, 1, 2, 3 E Type	90	90	East	0,750	1,600	26-Section 1 - East 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	0	1	0	0,040	24,0	12,77	0,91	53%	1675	0
20	L0, 1, 2, 3 E Type	90	90	East	0,800	1,600	26-Section 1 - East 1 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	0	0,040	25,6	14,07	0,96	55%	1879	0
1	01/Door 3 (Glase)	90	90	East	0,450	1,400	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	0	1	0,040	0,6	0,25	1,24	40%	60	0
1	01/Door 3 (Glase)	90	90	East	0,450	1,400	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	0	0	1	0,040	0,6	0,25	1,15	40%	55	0
1	01/Door 3 (Glase)	90	90	East	0,450	1,400	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	0	0	1	0,040	0,6	0,25	1,15	40%	55	0
1	01/Door 3 (Glase)	90	90	East	0,450	1,400	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	1	0,040	0,6	0,25	1,24	40%	60	0
1	01/Door 3 (Glase)	90	90	East	0,900	0,800	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	1	0	0,040	0,7	0,37	1,15	52%	64	0
1	01/Door 3 (Glase)	90	90	East	0,900	0,800	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	1	0	0,040	0,7	0,37	1,15	52%	64	0
3	L 1, 2, 3 E Type 6	90	90	East	0,900	0,800	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	1	1	0,040	2,2	0,97	1,03	45%	171	0
3	L 1, 2, 3 E Type 6	90	90	East	0,900	0,800	27-Section 1 - East 2 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	1	1	0,040	2,2	0,97	1,03	45%	171	0
2	01/Door 4 (Glase)	90	90	East	0,850	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	0	1	0,040	1,4	0,69	1,16	51%	121	0
2	01/Door 4 (Glase)	90	90	East	0,900	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	0	0	1	0,040	1,4	0,75	1,11	52%	122	0
2	01/Door 4 (Glase)	90	90	East	0,850	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	1	0,040	1,4	0,69	1,16	51%	121	0
2	01/Door 4 (Glase)	90	90	East	0,850	1,400	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	0	0	0,040	2,4	1,43	1,06	60%	194	0
2	01/Door 4 (Glase)	90	90	East	0,900	1,400	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	0	0	0	0,000	2,5	1,55	1,01	61%	195	0
2	01/Door 4 (Glase)	90	90	East	0,850	1,400	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	0	0,040	2,4	1,43	1,06	60%	194	0
2	01/Door 4 (Glase)	90	90	East	0,850	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	1	0	1	0	0,040	1,4	0,69	1,16	51%	121	0
2	01/Door 4 (Glase)	90	90	East	0,900	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	0	1	0	0,040	1,4	0,75	1,11	52%	122	0
2	01/Door 4 (Glase)	90	90	East	0,850	0,800	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0066w03 Nestle - Novum K1-P - with Ther		0,51	0,80	1,11	0,031	0	1	0	1	0,040	1,4	0,69	1,16	51%	121	0
6	L 0 E Type 6	90	90	East	1,175	0,450	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	1	0	0	1	0,040	3,2	0,87	1,04	27%	252	0
6	L 0 E Type 6	90	90	East	1,175	0,450	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51	0,80	0,79	0,030	0	1	0	1	0,040	3,2	0,87	1,04	27%	252	0
6	L 0 E Type 6	90	90	East	0,800	1,600	28-Section 1 - East 3 fasade	01ud 44 mm, triple glazing, 2 Low-E, air, al0081w03 Rehau - REHAU GENE0 PHZ - w		0,51														

[illegible]

EnerPHit planning: CALCULATING SHADING FACTORS

Climate:

User data - Беларусь Республика

Building:

Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Latitude:

43,086 °

Orientation	Glazing area	Reduction factor winter	Summer reduction factor
	m²	r _s	r _s
North	151,54	81%	53%
East	140,16	60%	43%
South	176,40	68%	40%
West	173,79	51%	34%
Horizontal	0,00	100%	100%

Space heating demand:	17,3	kWh/(m²a)
Useful Cooling Demand:	1,1	kWh/(m²a)
Frequency of overheating:	3,1%	

Quantity	Description	Deviation from North	Angle of Inclination from the Horizontal	Orientation	Glazing width	Glazing height	Glazing area	Horizon		Reveal		Overhang		Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Winter				Summer			
		Degrees	Degrees					m	m	m	m	m	m				%	%	%	%	%	%	%	%
1	S2/Type 1	180	90	South	0,54	0,61	0,3	h _{horiz}	d _{horiz}	d _{reveal}	d _{reveal}	d _{over}	d _{over}	F _{winter,w}	F _{summer,s}	z	F _w	F _s	F _o	F _s	F _w	F _s	F _o	F _s
1	S2/Type 1	180	90	South	0,74	0,61	0,4			0,18	0,07	0,60	0,07				100%	90%	73%	66%	100%	88%	29%	26%
1	S2/Type 2 leve	260	90	West	0,54	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	81%	89%	72%	100%	93%	93%	52%
1	S2/Type 2 leve	260	90	West	0,59	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	82%	89%	73%	100%	93%	93%	52%
1	S2/Type 2 leve	260	90	West	0,54	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	81%	89%	72%	100%	93%	93%	52%
1	S2/Type 2 leve	260	90	West	0,59	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	82%	89%	73%	100%	93%	93%	52%
1	S2/Type 2 leve	260	90	West	0,54	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	81%	89%	72%	100%	93%	93%	52%
1	S2/Type 2 leve	260	90	West	0,59	0,71	0,4			0,18	0,070	0,18	0,07			60%	100%	82%	89%	73%	100%	93%	93%	52%
1	S2/Type 3 leve	260	90	West	0,34	0,86	0,3			0,18	0,070	0,18	0,07			60%	100%	75%	90%	67%	100%	90%	95%	51%
12	S2/Type 4	180	90	South	0,54	1,16	7,5			0,18	0,07	0,60	0,07				100%	88%	84%	73%	100%	85%	48%	41%
12	S2/Type 4	180	90	South	1,09	1,16	15,1			0,18	0,07	0,60	0,07				100%	93%	84%	78%	100%	91%	48%	44%
8	S2/Type 4	0	90	North	0,54	1,16	5,0			0,18	0,070	0,18	0,07			60%	100%	86%	93%	79%	100%	86%	97%	50%
8	S2/Type 4	0	90	North	1,09	1,16	10,1			0,18	0,070	0,18	0,07			60%	100%	92%	93%	85%	100%	92%	97%	53%
4	S2/Type 5	0	90	North	0,44	1,16	2,0			0,18	0,070	0,18	0,07			60%	100%	84%	93%	77%	100%	84%	97%	49%
4	S2/Type 5	0	90	North	0,44	1,16	2,0			0,18	0,070	0,18	0,07			60%	100%	84%	93%	77%	100%	84%	97%	49%
1	S2/Type 6	0	90	North	0,54	1,16	0,6			0,18	0,070	0,18	0,07			60%	100%	86%	93%	79%	100%	86%	97%	50%
1	S2/Type 6	0	90	North	1,04	1,16	1,2			0,18	0,070	0,18	0,07			60%	100%	91%	93%	85%	100%	91%	97%	53%
15	S2/Type 7 leve	0	90	North	0,54	1,21	9,7			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	97%	50%
15	S2/Type 7 leve	0	90	North	1,09	1,21	19,7			0,18	0,070	0,18	0,07			60%	100%	92%	93%	85%	100%	92%	97%	54%
15	S2/Type 7 leve	0	90	North	0,54	1,21	9,7			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	97%	50%
15	S2/Type 7 leve	0	90	North	1,09	1,21	19,7			0,18	0,070	0,18	0,07			60%	100%	92%	93%	85%	100%	92%	97%	54%
15	S2/Type 7 leve	0	90	North	0,54	1,21	9,7			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	97%	50%
15	S2/Type 7 leve	0	90	North	1,09	1,21	19,7			0,18	0,070	0,18	0,07			60%	100%	92%	93%	85%	100%	92%	97%	54%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	1,0			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	1,0			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
10	S2/Type 8 Leve	180	90	South	0,54	1,31	7,0			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
10	S2/Type 8 Leve	180	90	South	0,49	1,31	6,4			0,18	0,07	0,60	0,07				100%	87%	85%	74%	100%	83%	53%	44%
10	S2/Type 8 Leve	180	90	South	0,54	1,31	7,0			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	1,0			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	0,1			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
1	S2/Type 8 Leve	180	90	South	0,91	0,11	0,1			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
1	S2/Type 8 Leve	180	90	South	0,54	1,31	0,7			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
1	S2/Type 8 Leve	180	90	South	0,49	1,31	0,6			0,18	0,07	0,60	0,07				100%	87%	85%	74%	100%	83%	53%	44%
1	S2/Type 8 Leve	180	90	South	0,54	1,31	0,7			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
2	S2/Type 8 Leve	0	90	North	0,91	0,11	0,2			0,18	0,070	0,18	0,07			60%	100%	90%	69%	63%	100%	90%	68%	37%
2	S2/Type 8 Leve	0	90	North	0,91	0,11	0,2			0,18	0,070	0,18	0,07			60%	100%	90%	69%	63%	100%	90%	68%	37%
2	S2/Type 8 Leve	0	90	North	0,54	1,31	1,4			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	98%	50%
2	S2/Type 8 Leve	0	90	North	0,49	1,31	1,3			0,18	0,070	0,18	0,07			60%	100%	85%	93%	79%	100%	85%	98%	50%
2	S2/Type 8 Leve	0	90	North	0,54	1,31	1,4			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	98%	50%
2	S2/Type 8 Leve	0	90	North	0,91	0,11	0,2			0,18	0,070	0,18	0,07			60%	100%	90%	69%	63%	100%	90%	68%	37%
2	S2/Type 8 Leve	0	90	North	0,91	0,11	0,2			0,18	0,070	0,18	0,07			60%	100%	90%	69%	63%	100%	90%	68%	37%
2	S2/Type 8 Leve	0	90	North	0,54	1,31	1,4			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	98%	50%
2	S2/Type 8 Leve	0	90	North	0,49	1,31	1,3			0,18	0,070	0,18	0,07			60%	100%	85%	93%	79%	100%	85%	98%	50%
2	S2/Type 8 Leve	0	90	North	0,54	1,31	1,4			0,18	0,070	0,18	0,07			60%	100%	86%	93%	80%	100%	86%	98%	50%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	1,0			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
10	S2/Type 8 Leve	180	90	South	0,91	0,11	1,0			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
10	S2/Type 8 Leve	180	90	South	0,54	1,31	7,0			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
10	S2/Type 8 Leve	180	90	South	0,49	1,31	6,4			0,18	0,07	0,60	0,07				100%	87%	85%	74%	100%	83%	53%	44%
10	S2/Type 8 Leve	180	90	South	0,54	1,31	7,0			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
1	S2/Type 8 Leve	180	90	South	0,91	0,11	0,1			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
1	S2/Type 8 Leve	180	90	South	0,91	0,11	0,1			0,18	0,07	0,60	0,07				100%	92%	40%	37%	100%	90%	20%	18%
1	S2/Type 8 Leve	180	90	South	0,54	1,31	0,7			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
1	S2/Type 8 Leve	180	90	South	0,49	1,31	0,6			0,18	0,07	0,60	0,07				100%	87%	85%	74%	100%	83%	53%	44%
1	S2/Type 8 Leve	180	90	South	0,54	1,31	0,7			0,18	0,07	0,60	0,07				100%	88%	85%	75%	100%	85%	53%	45%
2	S2/Type 9	0	90	North	0,57	0,56	0,6			0,18	0,070	2,05	0,17			80%	100%	86%	42%	36%	100%	86%	45%	31%
2	S2/Type 9	0	90	North	0,57	0,56	0,6			0,18	0,070	2,05	0,17			80%	100%	86%	42%	36%	100%	86%	45%	31%
2	S2/Type 9	0	90	North	0,57	1,16	1,3			0,18	0,070	2,05	0,17			80%	100%	86%	54%	46%	100%	86%	53%	36%
2																								

Quantity	Description	Deviation from North	Angle of Inclination from the Horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Horizontal shading reduction factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor	Horizontal Shading Reduction Factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor
		Degrees	Degrees		m	m	A _G	m	m	m	m	m	m	%	%	%	%	%	%	%	%	%	%	%
					w _G	h _G	A _G	h _{ext}	d _{hor}	d _{reveal}	d _{reveal}	d _{over}	d _{over}	f _{other,w}	f _{other,s}	z	f _h	f _r	f _o	f _s	f _h	f _r	f _o	f _s
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	75%			100%	88%	85%	56%	100%	85%	53%	34%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	58%			100%	92%	40%	21%	100%	90%	20%	11%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	58%			100%	92%	40%	21%	100%	90%	20%	11%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	58%			100%	88%	85%	43%	100%	85%	53%	26%
3	S2/Type 8 Leve	180	90	South	0,49	1,31	1,9			0,18	0,07	0,60	0,07	58%			100%	87%	85%	43%	100%	83%	53%	26%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	58%			100%	88%	85%	43%	100%	85%	53%	26%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	64%			100%	92%	40%	23%	100%	90%	20%	12%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	64%			100%	92%	40%	23%	100%	90%	20%	12%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	64%			100%	88%	85%	48%	100%	85%	53%	29%
3	S2/Type 8 Leve	180	90	South	0,49	1,31	1,9			0,18	0,07	0,60	0,07	64%			100%	87%	85%	47%	100%	83%	53%	28%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	64%			100%	88%	85%	48%	100%	85%	53%	29%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	70%			100%	92%	40%	26%	100%	90%	20%	13%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	70%			100%	92%	40%	26%	100%	90%	20%	13%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	70%			100%	88%	85%	52%	100%	85%	53%	31%
3	S2/Type 8 Leve	180	90	South	0,49	1,31	1,9			0,18	0,07	0,60	0,07	70%			100%	87%	85%	52%	100%	83%	53%	31%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	70%			100%	88%	85%	52%	100%	85%	53%	31%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	75%			100%	92%	40%	27%	100%	90%	20%	14%
3	S2/Type 8 Leve	180	90	South	0,91	0,11	0,3			0,18	0,07	0,60	0,07	75%			100%	92%	40%	27%	100%	90%	20%	14%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	75%			100%	88%	85%	56%	100%	85%	53%	34%
3	S2/Type 8 Leve	180	90	South	0,49	1,31	1,9			0,18	0,07	0,60	0,07	75%			100%	87%	85%	55%	100%	83%	53%	33%
3	S2/Type 8 Leve	180	90	South	0,54	1,31	2,1			0,18	0,07	0,60	0,07	75%			100%	88%	85%	56%	100%	85%	53%	34%
2	S1/Type 3 Leve	90	90	East	0,34	0,86	0,6			0,18	0,070	0,18	0,07			80%	100%	74%	90%	67%	100%	90%	95%	68%
2	S1/Type 3 Leve	90	90	East	0,34	0,86	0,6			0,18	0,070	0,18	0,07			80%	100%	74%	90%	67%	100%	90%	95%	68%
1	S1/Type 11	0	90	North	0,59	1,11	0,7			0,18	0,070	0,18	0,07			80%	100%	87%	92%	80%	100%	87%	97%	67%
4	S1/Type 12 Lev	0	90	North	0,54	1,16	2,5			0,18	0,070	0,18	0,07			80%	100%	86%	93%	79%	100%	86%	97%	67%
4	S1/Type 12 Lev	0	90	North	1,14	1,16	5,3			0,18	0,070	0,18	0,07			80%	100%	92%	93%	85%	100%	92%	97%	71%
5	S1/Type 12 Lev	0	90	North	0,54	1,16	3,1			0,18	0,070	0,18	0,07			80%	100%	86%	93%	79%	100%	86%	97%	67%
5	S1/Type 12 Lev	0	90	North	1,14	1,16	6,6			0,18	0,070	0,18	0,07			80%	100%	92%	93%	85%	100%	92%	97%	71%
7	S1/Type 13	180	90	South	0,64	1,51	6,7			0,18	0,07	0,60	0,07			100%	100%	89%	87%	77%	100%	86%	59%	51%
7	S1/Type 13	180	90	South	0,64	1,51	6,7			0,18	0,07	0,60	0,07			100%	100%	89%	87%	77%	100%	86%	59%	51%
7	S1/Type 14	180	90	South	0,64	1,26	6			0,18	0,07	0,60	0,07			100%	100%	88%	85%	75%	100%	86%	51%	44%
5	S1/Type 14	180	90	South	0,59	1,26	3,7			0,18	0,07	0,60	0,07			100%	100%	88%	85%	75%	100%	85%	51%	44%
7	S1/Type 14	180	90	South	0,64	1,26	5,6			0,18	0,07	0,60	0,07			100%	100%	89%	85%	75%	100%	86%	51%	44%
2	S1/Type 15	180	90	South	0,59	1,26	1,5			0,18	0,07	0,60	0,07			100%	100%	88%	85%	75%	100%	85%	51%	44%
2	S1/Type 15	180	90	South	0,59	0,36	0,4			0,18	0,07	0,60	0,07			100%	100%	88%	63%	56%	100%	85%	23%	20%
7	S1/Type 16	180	90	South	0,64	0,41	1,8			0,18	0,07	0,60	0,07			100%	100%	89%	65%	58%	100%	86%	24%	21%
7	S1/Type 16	180	90	South	0,59	0,41	1,7			0,18	0,07	0,60	0,07			100%	100%	88%	65%	58%	100%	85%	24%	20%
7	S1/Type 16	180	90	South	0,64	0,41	1,8			0,18	0,07	0,60	0,07			100%	100%	89%	65%	58%	100%	86%	24%	21%
1	L-1 W Type 6	260	90	West	0,91	0,16	0,1	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	87%	71%	29%	57%	95%	68%	15%
1	L-1 W Type 6	260	90	West	0,91	0,16	0,1	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	87%	71%	29%	57%	95%	68%	15%
1	L-1 W Type 6	260	90	West	0,54	1,31	0,7	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	81%	93%	35%	57%	93%	97%	22%
1	L-1 W Type 6	260	90	West	0,49	1,31	0,6	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	80%	93%	34%	57%	92%	97%	21%
1	L-1 W Type 6	260	90	West	0,54	1,31	0,7	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	81%	93%	35%	57%	93%	97%	22%
5	L-1 W Type 7	260	90	West	0,54	1,06	2,8	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	80%	92%	34%	57%	93%	96%	21%
5	L-1 W Type 7	260	90	West	0,49	1,06	2,6	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	80%	92%	34%	57%	93%	96%	21%
5	L-1 W Type 7	260	90	West	0,54	1,06	2,8	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	81%	92%	34%	57%	93%	96%	21%
1	L-1 W Type 1	260	90	West	0,29	0,61	0,2	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	72%	87%	29%	57%	89%	91%	19%
6	L-1 E Type 7	90	90	East	0,54	1,06	3,4	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	81%	92%	34%	57%	93%	96%	21%
6	L-1 E Type 7	90	90	East	0,49	1,06	3,1	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	80%	92%	34%	57%	92%	96%	21%
6	L-1 E Type 7	90	90	East	0,54	1,06	3,4	1,00	1,10	0,18	0,070	0,18	0,07	95%	70%	60%	49%	81%	92%	34%	57%	93%	96%	21%
10	L 0 W Type 6 -	260	90	West	0,91	0,16	1,4	21,40	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	68%	87%	71%	40%	74%	95%	68%	20%
10	L 0 W Type 6 -	260	90	West	0,54	1,31	7,0	21,40	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	68%	81%	93%	49%	74%	93%	97%	28%
10	L 0 W Type 6 -	260	90	West	0,49	1,31	6,4	21,40	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	68%	80%	93%	48%	74%	92%	97%	28%
10	L 0 W Type 6 -	260	90	West	0,54	1,31	7,0	21,40	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	68%	81%	93%	49%	74%	93%	97%	28%
2	L 0 W Type 6 -	260	90	West	0,91	0,16	0,3	3,10	2,80	0,18	0,070	0,18	0,07	95%	70%	60%	43%	87%	71%	25%	51%	95%	68%	14%
2	L 0 W Type 6 -	260	90	West	0,91	0,16	0,3	3,10	2,80	0,18	0,070	0,18	0,07	95%	70%	60%	43%	87%	71%	25%	51%	95%	68%	14%
2	L 0 W Type 6 -	260	90	West	0,54	1,31	1,4	3,10	2,80	0,18	0,070	0,18	0,07	95%	70%	60%	43%	81%	93%	31%	51%	93%	97%	19%
2	L 0 W Type 6 -	260	90	West	0,49	1,31	1,3	3,10	2,80	0,18	0,070	0,18	0,07	95%	70%	60%	43%	80%	93%	30%	51%	92%	97%	19%
2	L 0 W Type 6 -	260	90	West	0,54	1,31	1,4	3,10	2,80	0,18	0,070	0,18	0,07	95%	70%	60%	43%	81%	93%	31%	51%	93%	97%	19%
2	L 0 W Type 6 -	260	90	West	0,91	0,16	0,3	21,40	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	68%	87%	71%	40%	74%	95%	68%	20%
2	L 0 W Type 6 -	260	90	West	0,94	0,21	0,4	21,40	47,00	0,18	0,070	2,05	0,17	95%	70%	60%	68%	88%	72%	12%	74%	95%	22%	9%
2	L 0 W Type 6 -	260	90	West	0,57	1,36	1,5																	

Quantity	Description	Deviation from North	Angle of inclination from the Horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Horizontal shading reduction factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor	Horizontal Shading Reduction Factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor
		Degrees	Degrees		m	m	A _G	m	m	m	m	m	m	%	%	%	%	%	%	%	%	%	%	%
		°	°		w _G	h _G	A _G	h _{ext}	d _{hor}	d _{reveal}	d _{reveal}	d _{over}	d _{over}	F _{ather,w}	F _{ather,s}	z	r _h	r _r	r _o	r _s	r _h	r _r	r _o	r _s
2	01/Type 8 NORT	0	90	North	0,69	1,31	1,8			0,18	0,070	0,18	0,07			60%	100%	88%	93%	82%	100%	88%	98%	52%
2	01/Type 8 NORT	0	90	North	0,74	1,31	1,9			0,18	0,070	0,18	0,07			60%	100%	89%	93%	83%	100%	89%	98%	52%
1	01/Door 2 (Gla	180	90	South	0,57	0,56	0,3			0,18	0,070	2,05	0,17			80%	100%	88%	42%	37%	100%	85%	20%	14%
1	01/Door 2 (Gla	180	90	South	0,57	0,56	0,3			0,18	0,070	2,05	0,17			80%	100%	88%	42%	37%	100%	85%	20%	14%
1	01/Door 2 (Gla	180	90	South	0,57	1,06	0,6			0,18	0,070	2,05	0,17			80%	100%	88%	57%	50%	100%	85%	22%	15%
1	01/Door 2 (Gla	180	90	South	0,57	1,06	0,6			0,18	0,070	2,05	0,17			80%	100%	88%	57%	50%	100%	85%	22%	15%
1	01/Door 2 (Gla	180	90	South	0,57	0,56	0,3			0,18	0,070	2,05	0,17			80%	100%	88%	42%	37%	100%	85%	20%	14%
1	01/Door 2 (Gla	180	90	South	0,57	0,56	0,3			0,18	0,070	2,05	0,17			80%	100%	88%	42%	37%	100%	85%	20%	14%
1	01/Type 8 NORT	0	90	North	0,74	0,16	0,1			0,18	0,070	0,18	0,07			60%	100%	89%	73%	65%	100%	89%	73%	39%
1	01/Type 8 NORT	0	90	North	0,69	0,16	0,1			0,18	0,070	0,18	0,07			60%	100%	88%	73%	64%	100%	88%	73%	38%
1	01/Type 8 NORT	0	90	North	0,74	0,16	0,1			0,18	0,070	0,18	0,07			60%	100%	89%	73%	65%	100%	89%	73%	39%
1	01/Type 8 NORT	0	90	North	0,74	1,31	1,0			0,18	0,070	0,18	0,07			60%	100%	89%	93%	83%	100%	89%	98%	52%
1	01/Type 8 NORT	0	90	North	0,69	1,31	0,9			0,18	0,070	0,18	0,07			60%	100%	88%	93%	82%	100%	88%	98%	52%
1	01/Type 8 NORT	0	90	North	0,74	1,31	1,0			0,18	0,070	0,18	0,07			60%	100%	89%	93%	83%	100%	89%	98%	52%
16	L 1 W Type 6	260	90	West	0,91	0,16	2,3	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	87%	71%	43%	78%	95%	68%	21%
16	L 1 W Type 6	260	90	West	0,91	0,16	2,3	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	87%	71%	43%	78%	95%	68%	21%
16	L 1 W Type 6	260	90	West	0,54	1,31	11,3	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	81%	83%	52%	78%	93%	28%	20%
16	L 1 W Type 6	260	90	West	0,49	1,31	10,2	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	80%	93%	51%	78%	92%	97%	29%
16	L 1 W Type 6	260	90	West	0,54	1,31	11,3	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	81%	93%	52%	78%	93%	97%	29%
2	L 1 W Type 2	260	90	West	0,59	0,16	0,2	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	82%	71%	40%	78%	93%	68%	21%
2	L 1 W Type 2	260	90	West	0,59	1,31	1,5	17,85	47,00	0,18	0,070	0,18	0,07	95%	70%	60%	73%	82%	93%	53%	78%	93%	97%	30%
16	L 2 W Type 6	260	90	West	0,91	0,16	2,3	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	87%	71%	48%	82%	95%	68%	32%
16	L 2 W Type 6	260	90	West	0,91	0,16	2,3	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	87%	71%	48%	82%	95%	68%	32%
16	L 2 W Type 6	260	90	West	0,54	1,31	11,3	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	81%	93%	58%	82%	93%	97%	44%
16	L 2 W Type 6	260	90	West	0,49	1,31	10,2	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	80%	93%	57%	82%	93%	97%	44%
16	L 2 W Type 6	260	90	West	0,54	1,31	11,3	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	81%	93%	58%	82%	93%	97%	44%
2	L 2 W Type 2	260	90	West	0,59	0,16	0,2	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	82%	71%	45%	82%	93%	68%	31%
2	L 2 W Type 2	260	90	West	0,59	1,31	1,5	14,30	47,00	0,18	0,070	0,18	0,07			60%	77%	82%	93%	59%	82%	93%	97%	44%
16	L 3 W Type 6	260	90	West	0,91	0,16	2,3	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	87%	71%	51%	86%	95%	68%	33%
16	L 3 W Type 6	260	90	West	0,91	0,16	2,3	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	87%	71%	51%	86%	95%	68%	33%
16	L 3 W Type 6	260	90	West	0,54	1,31	11,3	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	81%	93%	62%	86%	92%	97%	46%
16	L 3 W Type 6	260	90	West	0,49	1,31	10,2	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	80%	93%	61%	86%	92%	97%	46%
16	L 3 W Type 6	260	90	West	0,54	1,31	11,3	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	81%	93%	62%	86%	93%	97%	46%
2	L 3 W Type 2	260	90	West	0,59	0,16	0,2	10,75	47,00	0,18	0,070	0,18	0,07			60%	82%	82%	71%	48%	86%	93%	68%	32%
2	L 3 W Type 2	260	90	West	0,59	1,31	1,5		47,00	0,18	0,070	0,18	0,07			60%	100%	82%	93%	72%	100%	93%	97%	54%
20	L0,1,2,3 E Typ	90	90	East	0,91	0,16	2,9			0,18	0,070	0,18	0,07			60%	100%	87%	71%	67%	100%	95%	68%	39%
20	L0,1,2,3 E Typ	90	90	East	0,91	0,16	2,9			0,18	0,070	0,18	0,07			60%	100%	87%	71%	62%	100%	95%	68%	39%
20	L0,1,2,3 E Typ	90	90	East	0,54	1,31	14,1			0,18	0,070	0,18	0,07			60%	100%	81%	93%	75%	100%	93%	97%	54%
20	L0,1,2,3 E Typ	90	90	East	0,49	1,31	12,8			0,18	0,070	0,18	0,07			60%	100%	80%	93%	74%	100%	92%	97%	54%
20	L0,1,2,3 E Typ	90	90	East	0,54	1,31	14,1			0,18	0,070	0,18	0,07			60%	100%	81%	93%	75%	100%	93%	97%	54%
1	01/Door 3 (Gla	90	90	East	0,22	1,16	0,3			0,18	0,070	2,05	0,17			80%	100%	68%	48%	33%	100%	87%	42%	29%
1	01/Door 3 (Gla	90	90	East	0,22	1,16	0,3			0,18	0,070	2,05	0,17			80%	100%	68%	48%	33%	100%	87%	42%	29%
1	01/Door 3 (Gla	90	90	East	0,22	1,16	0,3			0,18	0,070	2,05	0,17			80%	100%	68%	48%	33%	100%	87%	42%	29%
1	01/Door 3 (Gla	90	90	East	0,22	1,16	0,3			0,18	0,070	2,05	0,17			80%	100%	68%	48%	33%	100%	87%	42%	29%
1	01/Door 3 (Gla	90	90	East	0,67	0,56	0,4			0,18	0,070	2,05	0,17			80%	100%	84%	33%	27%	100%	94%	30%	23%
1	01/Door 3 (Gla	90	90	East	0,67	0,56	0,4			0,18	0,070	2,05	0,17			80%	100%	84%	33%	27%	100%	94%	30%	23%
3	L 1,2,3 E type	90	90	East	0,64	0,51	1,0			0,18	0,070	0,18	0,07			60%	100%	83%	85%	71%	100%	94%	89%	50%
3	L 1,2,3 E type	90	90	East	0,64	0,51	1,0			0,18	0,070	0,18	0,07			60%	100%	83%	85%	71%	100%	94%	89%	50%
2	01/Door 4 (Gla	90	90	East	0,62	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	33%	15%	100%	94%	30%	13%
2	01/Door 4 (Gla	90	90	East	0,67	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	84%	33%	16%	100%	94%	30%	13%
2	01/Door 4 (Gla	90	90	East	0,62	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	33%	15%	100%	94%	30%	13%
2	01/Door 4 (Gla	90	90	East	0,62	1,16	1,4			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	48%	23%	100%	94%	42%	18%
2	01/Door 4 (Gla	90	90	East	0,67	1,16	1,5			0,18	0,070	2,05	0,17	57%	57%	60%	100%	84%	48%	23%	100%	94%	42%	18%
2	01/Door 4 (Gla	90	90	East	0,62	1,16	1,4			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	48%	23%	100%	94%	42%	18%
2	01/Door 4 (Gla	90	90	East	0,62	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	33%	15%	100%	94%	30%	13%
2	01/Door 4 (Gla	90	90	East	0,67	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	84%	33%	16%	100%	94%	30%	13%
2	01/Door 4 (Gla	90	90	East	0,62	0,56	0,7			0,18	0,070	2,05	0,17	57%	57%	60%	100%	83%	33%	15%	100%	94%	30%	13%
6	L 0 E Type 6	90	90	East	0,91	0,16	0,9			0,18	0,070	0,18	0,07	57%	57%	60%	100%	87%	71%	35%	100%	95%	68%	22%
6	L 0 E Type 6	90	90	East	0,91	0,16	0,9			0,18	0,070	0,18	0,07	57%	57%	60%	100%	87%	71%	35%	100%	95%	68%	22%
6	L 0 E Type 6	90	90	East	0,54	1,31	4,2			0,18	0,070	0,18	0,07	57%	57%	60%	100%	81%	93%	43%	100%	93%	97%	31%
6	L 0 E Type 6	90	90	East	0,49	1,31	3,8			0,18	0,070	0,18	0,07	57%	57%									

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B**Treated floor area A_{TFA} m²**4630**

(Areas worksheet)

Room Height h

m

2,50Room ventilation volume ($A_{TFA} \cdot h$) = V_V m³**11576**

(Worksheet Annual heating)

Ventilation type

Please select

Balanced PH-Ventilation with HR

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for screening class	Several side exposed	One side exposed
No screening	0,10	0,03
Moderate screening	0,07	0,02
High screening	0,04	0,01
Coefficient f	15	20

Wind protection coefficient, e

for annual demand:

0,07

for Heating Load:

0,18

Wind protection coefficient, f

15**15**Net Air Volume for Press. Test V_{n50}

Air Change Rate at Press. Test

 n_{50}

1/h

1,00

1,00

6329 m³Air permeability q_{50} **0,87**m³/(hm²)

for annual demand:

0,00

for Heating Load:

0,00

Excess extract air

1/h

Infiltration air change rate

 $n_{V,Rest}$

1/h

0,038**0,096**

Selection of ventilation data input - Results

The PHPP offers two methods for dimensioning the air quantities and choosing the ventilation unit. Fresh air or extract air quantities for residential buildings and parameters for ventilation system can be determined using the standard planning option in the 'Ventilation' sheet. The 'Additional Vent' sheet has been created for more complex ventilation systems and allows up to 10 different ve. Furthermore, air quantities can be determined on a room-by-room or zone-by-zone basis. Please select your design method here.

Ventilation unit / Heat recovery efficiency design

☐	Standard design	(Ventilation worksheet see below)
☒	Various vent. units, non residential	(Worksheet Additional vent)

Average Air Exchange	Average Air Change Rate	Extract air excess (Extract air system)	Effective heat recovery efficiency Unit	Energy recovery value	Specific power input	Heat recovery efficiency SHX
m ³ /h	1/h	1/h	[-]	[-]	Wh/m ³	[-]
2028	0,18	0,00	80,8%	0,0%	0,40	0,0%

SHX efficiency

 η^*_{SHX} **0%**

STANDARD INPUT FOR BALANCED VENTILATION

Ventilation dimensioning for systems with one ventilation unit

Calculation in sheet 'Additional Vent': Extended data input for balanced ventilation

Occupancy	m²/P	7			
Number of occupants	P	680,0			
Supply air per person	m³/(P*h)	15			
Supply air requirement	m³/h	10200			
Extract air rooms		Kitchen	Bathroom	Bathroom (shower only)	WC
Quantity					
Extract air requirement per room	m³/h	60	40	20	20
Total Extract Air Requirement	m³/h	0			

Design air flow rate (maximum)

m³/h

Average air change rate calculation

Type of operation	Daily operation duration h/d	Factors referenced to maximum	Air flow rate m³/h	Air change rate 1/h
maximum		1,00	#WERT!	#WERT!
Standard	8,0	0,77	#WERT!	#WERT!
Basic	4,0	0,54	#WERT!	#WERT!
Minimum	12,0	0,40	#WERT!	#WERT!
Average value		0,55	Average air flow rate (m³/h)	Average air change rate (1/h)

Selection of ventilation unit with heat recovery

Installation site of ventilation unit

Heat recovery?

Ventilation unit selection

Sort: BY ID

[Go to ventilation units list](#)

Heat recovery efficiency Unit	Energy recovery	Specific power input [Wh/m³]	Application range [m³/h]	Frost required
η_{HR}	η_{ERV}			

Ψ	W/(mK)	0,000	See calculation below	Enter input for auxiliary calculation of exterior/supply
Ψ	W/(mK)	0,000	See calculation below	Enter input for auxiliary calculation of exhaust/extrac
Temperature of mechanical services room (Enter only if the central unit is outside of the thermal envelope.)	°C	20	Room temperature (°C)	20
			Av. Ambient Temp. Heating P. (°C)	4,5
			Av. Ground Temp (°C)	11,4

Effective heat recovery efficiency

$\eta_{HR,eff}$

Effective heat recovery efficiency subsoil heat exchanger

SHX efficiency

Heat recovery efficiency SHX

η_{SHX}

η_{SHX}

Secondary calculation

Ψ -value supply or ambient air duct

Nominal width:	60	mm
Insul. Thickness:	80	mm
Reflective?	x	No
Thermal conductivity	0,033	W/(mK)
Nominal air flow rate		m³/h
$\Delta\theta$	15 K	
Exterior duct diameter	0,060 m	
Exterior diameter	0,220 m	
α -Interior	#WERT!	W/(m²K)
α -Surface		W/(m²K)
Ψ -value		W/(mK)
Surface temperature difference		K

Secondary calculation

Ψ -value extract or exhaust air duct

Nominal width:	60	mm
Insul. Thickness:	80	mm
Reflective?	x	no
Thermal conductivity	0,033	W/(mK)
Nominal air flow rate		m³/h
$\Delta\theta$	15 K	
Exterior duct diameter	0,060 m	
Exterior diameter	0,220 m	
α -Interior	#WERT!	W/(m²K)
α -Surface		W/(m²K)
Ψ -value		W/(mK)
Surface temperature difference		K

EXTENDED DATA INPUT FOR BALANCED VENTILATION

Planning ventilation systems with multiple ventilation units

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Ventilation unit / Heat recovery efficiency design			
In Ventilation worksheet (standard design)			(Ventilation worksheet)
In Additional Vent (this worksheet)		x	(Additional vent)
Treated Floor Area A _{TFA}	m²	4630	(Areas worksheet)
Room Height h	m	2,50	(Worksheet Annual heating)
Room air volume for ventilation (A _{TFA} *h) = V _V	m³	11576	(Worksheet Annual heating)
Number of Occupants	P	680,0	(Ventilation worksheet)
Room temperature	°C	20	(Worksheet Annual heating)
Average external temp. heating period	°C	4,5	(Ventilation worksheet)
Average ground temp.	°C	11,4	(Ground worksheet)
Ventilation type	Balanced PH-Ventilation with HR		

Results of ventilation design and unit selection:

Ventilation Unit no.	Description of the unit	Design		Average value / yr.		Air ch.rt.
		V _{SUP} m³/h	V _{ETA} m³/h	V _{SUP} m³/h	V _{ETA} m³/h	
1	Parter	1500	1500	223	223	---
2	First floor	1500	1500	223	223	---
3	Second floor	1500	1500	223	223	---
4	Floor -1	1750	1750	183	183	---
5	Sector A 1 floor	470	470	52	52	---
6	Sector A 2 floor	300	300	38	38	---
7	Floor -1	550	550	82	82	---
8	Parter	1350	1250	201	186	---
9	Floor 1	5400	5500	803	818	---
10						---

Result for overall vent. syst.	14320	14320	2028	2028	0,18
--------------------------------	-------	-------	------	------	------

Effective heat recovery efficiency	Energy recovery value	spec. Input power	Heat recov. efficiency SHX	Cross check
81%	0%	0,40	0%	
81%	0%	0,40	0%	
82%	0%	0,40	0%	
81%	0%	0,40	0%	
81%	0%	0,40	0%	
75%	0%	0,40	0%	
78%	0%	0,40	0%	
80%	0%	0,40	0%	Supply and extract air should be the same!
81%	0%	0,40	0%	Supply and extract air should be the same!
81%	0%	0,40	0%	

Recommendations for dimensioning air quantities

Use of low odour and low-emission building materials/ furnishings:
It is strongly recommended to use building materials that cause no or only little pollution instead of increasing the outdoor air volume flow in order to reduce preventable pollution. This holds true independently from the chosen approach for the air quality determination; emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning unit.

Assessment of volume flow rates according to the number of persons
Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality the amounts of 20 to 30 m³/h/person are completely sufficient. Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance. IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as purge ventilation is carried out during breaks anyway. For typical external air CO₂ concentrations of around 400-500 ppm, it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

Fresh air flow rates per person:
- Recommended for residential buildings: around 30 m³/(h person)
- Recommended for offices and similar uses: around 30 m³/(h person) (AMEV: 28 m³/(h person); EN 13779 / IDA 3: at least 24 m³/(h person))
- Recommended for schools and day care centres: 15 to 20 m³/(h person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)
- Recommendation for sport halls: 60 m³/(h person) (DIN 18032-1)

Purging phase for intermittent ventilation operation
Due to the purge ventilation phase, the ventilation operation period is extended accordingly (utilisation time + purge ventilation phase). Please consider this for the ventilation design. Emissions have to be removed. Flushing the building prolongs the utilization time of the ventilation system (utilization time + flushing phase). Please consider this at design stage.

Design of air quantities

When designing the air quantities, please consider the design recommendations given above.
The ventilation operation period can be determined on the basis of the daily utilisation hours including purging phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be taken into account by means of reduction factors.

Room Nr.	Amount a	Room name	Assignment to ventilation unit	Area A m²	Clear height h m	Room vol. A x h m³	Volume flow per room			Air change rate per room n 1/h	Utilisation times			Reduction Red.1	Operation Red. 1	Reduction Red.2	Operation Red.2	Reduction Red.3	Operation Red. 3	Cross check	Average volume flows			Average air change rate 1/h
							V _{SUP} m³/h	V _{ETA} m³/h	V _{TRANS} m³/h		h/d h	d/week d	weeks/yr Weeks								V _{SUP} m³/h	V _{ETA} m³/h	V _{TRANS} m³/h	
1	5	Classroom	1	53	3,30	175	300			1,72	14	5	32	100%	30%	60%	0%	40%	70%		223			0,26
2	1	Corridors	1	122	3,30	403		1000	500	2,48	14	5	32	100%	30%	60%	0%	40%	70%			149	74	0,37
3	1	Lobbies	1	69	3,30	228		500		2,20	14	5	32	100%	30%	60%	0%	40%	70%			74		0,33
4	5	Classroom	2	53	3,30	175	300			1,72	14	5	32	100%	30%	60%	0%	40%	70%		223			0,26
5	1	Corridors	2	122	3,30	403		1000	500	2,48	14	5	32	100%	30%	60%	0%	40%	70%			149	74	0,37
6	1	Lobbies	2	69	3,30	228		500		2,20	14	5	32	100%	30%	60%	0%	40%	70%			74		0,33
7	5	Classroom	3	53	3,30	175	300			1,72	14	5	32	100%	30%	60%	0%	40%	70%		223			0,26
8	1	Corridors	3	122	3,30	403		1000	500	2,48	14	5	32	100%	30%	60%	0%	40%	70%			149	74	0,37
9	1	Lobbies	3	69	3,30	228		500		2,20	14	5	32	100%	30%	60%	0%	40%	70%			74		0,33
10	1	Lobbie -1	4	69	3,30	228	100			0,44	10	5	32	100%	30%	50%	30%	30%	40%		10			0,05
11	1	Corridor -1	4	18	3,30	59		150		2,53	10	5	32	100%	30%	50%	30%	30%	40%			16		0,26
12	1	Canteen	4	176	3,30	581	1550		50	2,67	10	5	32	100%	30%	50%	30%	30%	40%		162		5	0,28
13	1	Kitchen	4	68	3,30	224		1600	50	7,13	10	5	32	100%	30%	50%	30%	30%	40%			167	5	0,74
14	1	m behind kitch	4	79	3,30	262	100			0,38	10	5	32	100%	30%	50%	30%	30%	40%		10			0,04
15	1	mputer classro	5	51	3,30	168	300			1,79	14	5	32	100%	10%	70%	30%	20%	60%		33			0,20
16	1	Bookstore	5	16	3,30	52	50			0,96	14	5	32	100%	10%	70%	30%	20%	60%		6			0,11
17	1	Canteen	5	51	3,30	168	120	140		0,83	14	5	32	100%	10%	70%	30%	20%	60%		13	15		0,09
18	1	WC	5	8	3,30	26		80		3,06	14	5	32	100%	10%	70%	30%	20%	60%			9		0,34
19	1	Corridor	5	41	3,30	136		250	80	1,84	14	5	32	100%	10%	70%	30%	20%	60%			28	9	0,20
20	1	Corridor 2	5	8	3,30	26			80	3,03	14	5	32	100%	10%	70%	30%	20%	60%				9	0,33
21	1	Teachers room	6	17	3,30	56	30			0,53	14	5	50	100%	0%	50%	40%	20%	60%		4			0,07
22	1	Teachers room	6	33	3,30	109	90			0,82	14	5	50	100%	0%	50%	40%	20%	60%		12			0,11
23	1	Teachers room	6	16	3,30	52	30			0,58	14	5	50	100%	0%	50%	40%	20%	60%		4			0,07
24	1	Teachers room	6	51	3,30	169	150			0,89	14	5	50	100%	0%	50%	40%	20%	60%		19			0,11
25	1	WC	6	8	3,30	26		80		3,06	14	5	50	100%	0%	50%	40%	20%	60%			10		0,39
26	1	Corridor	6	41	3,30	136		220		1,62	14	5	50	100%	0%	50%	40%	20%	60%			28		0,21
27	1	Corridor 2	6	8	3,30	26			80	3,03	14	5	50	100%	0%	50%	40%	20%	60%				10	0,39
28	1	Fitness	7	96	3,30	317	250			0,79	14	5	32	100%	30%	60%	0%	40%	70%		37			0,12
29	1	Classroom	7	143	3,30	472	300			0,64	14	5	32	100%	30%	60%	0%	40%	70%		45			0,09
30	1	Corridor	7	120	3,30	396			550	1,39	14	5	32	100%	30%	60%	0%	40%	70%				82	0,21
31	1	Mechanical	7	256	4,40	1126		350		0,31	14	5	32	100%	30%	60%	0%	40%	70%			52		0,05
32	1	WC	7	11	3,30	36		100		2,75	14	5	32	100%	30%	60%	0%	40%	70%			15		0,41
33	1	Otehrs	7	67	3,30	221		100		0,45	14	5	32	100%	30%	60%	0%	40%	70%			15		0,07
34	2	Classroom	8	64	3,30	211	300			1,42	14	5	32	100%	30%	60%	0%	40%	70%		89			0,21
35	1	Classroom	8	51	3,30	167	300			1,80	14	5	32	100%	30%	60%	0%	40%	70%		45			0,27
36	1	Classroom	8	67	3,30	221	300			1,36	14	5	32	100%	30%	60%	0%	40%	70%		45			0,20
37	1	Entrance room	8	53	3,30	175	150			0,86	14	5	32	100%	30%	60%	0%	40%	70%		22			0,13
38	6	Storages	8	16	3,30	53		100		1,89	14	5	32	100%	30%	60%	0%	40%	70%			89		0,28
39	1	Corridor	8	202	3,30	667		450	700	1,05	14	5	32	100%	30%	60%	0%	40%	70%			67	104	0,16
40	1	WC	8	39	3,30	129		200		1,55	14	5	32	100%	30%	60%	0%	40%	70%			30		0,23
41	1	Others entrance	9	55	3,30	182		100		0,55	14	5	32	100%	30%	60%	0%	40%	70%			15		0,08
42	1	Classroom	9	58	3,30	191	300			1,57	14	5	32	100%	30%	60%	0%	40%	70%		45			0,23
43	1	Classroom	9	76	3,30	251	300			1,20	14	5	32	100%	30%	60%	0%	40%	70%		45			0,18
44	5	Storages	9	16	3,30	53		100		1,89	14	5	32	100%	30%	60%	0%	40%	70%			74		0,28
45	2	Classroom	9	67	3,30	221	300			1,36	14	5	32	100%	30%	60%	0%	40%	70%		89			0,20
46	2	Classroom	9	51	3,30	168	300			1,78	14	5	32	100%	30%	60%	0%	40%	70%		89			0,27
47	1	Corridor	9	204	3,30	673		1100	500	1,63	14	5	32	100%	30%	60%	0%	40%	70%			164	74	0,24
48	1	WC	9	39	3,30	129		200		1,55	14	5	32	100%	30%	60%	0%	40%	70%			30		0,23
49	1	Classroom	9	58	3,30	191	300			1,57	14	5	32	100%	30%	60%	0%	40%	70%		45			0,23
50	1	Classroom	9	76	3,30	251	300			1,20	14	5	32	100%	30%	60%	0%	40%	70%		45			0,18
51	5	Storages	9	16	3,30	53		100		1,89	14	5	32	100%	30%	60%	0%	40%	70%			74		0,28
52	2	Classroom	9	67	3,30	221	300			1,36	14	5	32	100%	30%	60%	0%	40%	70%		89			0,20
53	2	Classroom	9	51	3,30	168	300			1,78	14	5	32	100%	30%	60%	0%	40%	70%		89			0,27
54	1	Corridor	9	204	3,30	673		1100	500	1,63	14	5	32	100%	30%	60%	0%	40%	70%			164	74	0,24
55	1	WC	9	39	3,30	129		200		1,55	14	5	32	100%	30%	60%	0%	40%	70%			30		0,23
56	1	Classroom	9	58	3,30	191	300			1,57	14	5	32	100%	30%	60%	0%	40%	70%		45			0,23
57	1	Classroom	9	76	3,30	251	300			1,20	14	5	32	100%	30%	60%	0%	40%	70%		45			0,18
58	5	Storages	9	16	3,30	53		100		1,89	14	5	32	100%	30%	60%	0%	40%	70%			74		0,28
59	2	Classroom	9	67	3,30	221	300			1,36	14	5	32	100%	30%	60%	0%	40%	70%		89			0,20
60	2	Classroom	9	51	3,30	168	300			1,78	14	5	32	100%	30%	60%	0%	40%	70%		89			0,27
61	1	Corridor	9	204	3,30	673		1100	500	1,63	14	5	32	100%	30%	60%	0%	40%	70%			164	74	0,24
62	1	WC	9	39	3,30	129		200		1,55	14	5	32	100%	30%	60%	0%	40%	70%			30		0,23

63											100%	100%			
64											100%	100%			
65											100%	100%			
66											100%	100%			
67											100%	100%			
68											100%	100%			
69											100%	100%			
70											100%	100%			
71											100%	100%			
72											100%	100%			
73											100%	100%			
74											100%	100%			
30											100%	100%			
Additional lines: Please mark complete lines above, copy and paste multiple times													2028	2028	---
															0,11

Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet "Components". When choosing to use a compact unit the standard design in the Ventilation worksheet has to be used.

Go to ventilation units list																							
Ventilation Unit no.	Quantity	Description Ventilation units	Selection Unit type	Design vol. flow per unit m³/h	Entry area for volume flow rate from to m³/h		Electrical efficiency Wh/m³	Pressure loss calculation ODA-SUP ETA-EHA Additional			Entry area per line Subtraction		Cross check ----- Pressure loss assessment duct network	Interior location (x)	Exterior location (x)	Heat recovery efficiency Unit effective	Energy recovery value	Frost protection necessary	Subsoil HX Effective- efficiency degree	Efficiency of heat recovery	U noise level < 35dB(A)	Noise protection adapter Supply air db(A)	
	[-]							ΔP _{duct} Pa	ΔP _{duct} Pa	ΔP _{system} Pa	ΔP _{external} Pa	ΔP _{system} Pa											

Change sorting type																						
1	1	Parter	06ud Tangra ventilation unit EVB 16 H	1500	800	1600	0,40	55	55	65	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68
2	1	First floor	06ud Tangra ventilation unit EVB 16 H	1500	800	1600	0,40	55	55	65	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68
3	1	Second floor	06ud Tangra ventilation unit EVB 16 H	1500	800	1600	0,40	55	55	65	-	-	ok	x		0,82	82%	0%	yes	0%	n.a.	68
4	1	Floor -1	07ud Tangra ventilation unit EVB 20 H	1750	1000	2000	0,40	55	105	90	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68
5	1	ector A 1 floor	02ud Tangra ventilation unit EVB 06 H	470	250	600	0,40	45	45		100	-	ok	x		0,82	81%	0%	yes	0%	n.a.	61
6	1	ector A 2 floor	01ud Tangra ventilation unit EVB 04 H	300	150	400	0,40	45	45		100	-	ok	x		0,82	75%	0%	yes	0%	n.a.	57
7	1	Floor -1	02ud Tangra ventilation unit EVB 06 H	550	250	600	0,40	55	50		100	-	ok	x		0,82	78%	0%	yes	0%	n.a.	61
8	1	Parter	06ud Tangra ventilation unit EVB 16 H	1350	800	1600	0,40	65	55	60	-	-	ok	x		0,82	80%	0%	yes	0%	n.a.	68
9	1	Floor 1	07ud Tangra ventilation unit EVB 20 H	5400	1000	2000	0,40	70	55	70	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68
10																						

Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, both for interior as for exterior location of the ventilation unit. These duct sections can be entered here. The heat losses of the overlying duct section will be considered for the effective heat recovery efficiency. An entered duct section can also be used for multiple ventilation units. If in the section "Ventilation unit - selection" in one line a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of the location of installation		20,0		(only enter when at least one unit is installed outside of the thermal envelope)																					
Quantity	Cross check	Round duct ins. diameter mm	Rectangular duct		Insulation Thickness mm	Thermal conductivity W/(m K)	Reflective insulation duct (x)	Transmittance duct W/(m K)	Length of Supply air m	Ambient or Extract air Duct (l)	Exhaust or flow Duct (l)	Duct type	Design Volume rate	Vent. Unit 1	Vent. Unit 2	Allocation to ventilation units (when central unit applicable enter "1")									
			Width mm	Height mm												Vent. Unit 3	Vent. Unit 4	Vent. Unit 5	Vent. Unit 6	Vent. Unit 7	Vent. Unit 8	Vent. Unit 9	Vent. Unit 10		
1		315			150	0,033		0,291	2	1		Supply air	1500	1											
1		315			150	0,033		0,291	11		1	Abluft	1500	1											
1		315			150	0,033		0,293	2	1		Ambient air	1500		1										
1		315			150	0,033		0,293	7,5		1	Fortluft	1500		1										
1		315			150	0,033		0,293	2	1		Ambient air	1500			1									
1		315			150	0,033		0,293	4		1	Fortluft	1500			1									
1		315			150	0,033		0,294	2	1		Ambient air	1750				1								
1		315			150	0,033		0,294	14,5		1	Fortluft	1750				1								
1		200			150	0,033		0,212	2	1		Ambient air	470					1							
1		200			100	0,033		0,272	3		1	Fortluft	470					1							
1		200			150	0,033		0,205	5,5	1		Ambient air	300						1						
1		200			100	0,033		0,261	6,5		1	Fortluft	300						1						
1		160			150	0,033		0,187	6	1		Ambient air	550							1					
1		160			100	0,033		0,239	18		1	Fortluft	550							1					
1		315			150	0,033		0,293	3,5	1		Ambient air	1350								1				
1		315			150	0,033		0,293	14,5		1	Fortluft	1350								1				
3		315			150	0,033		0,298	3,5	1		Ambient air	5400										1		
3		315			150	0,033		0,298	11		1	Fortluft	5400										1		
													0												
													0												

Additional lines: Please mark complete lines above, copy and paste multiple times

SPECIFIC ANNUAL HEATING DEMAND (annual method)

Climate: User data - Велико Търнов

Interior Temperature: 20,0 °C

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Building type: School

Treated Floor Area A_{TFA}: 4630,4 m²

Building assembly	Temperature Zone	Area m²	U-Value W/(m²K)	Temp. Factor f _t	G _t kWh/a	per m² Treated Floor Area
Exterior Wall - Ambient	A	2554,0	0,143	1,00	76,7	6,03
Exterior Wall - Ground	B	362,1	0,180	0,10	76,7	0,11
Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	76,7	3,24
Floor slab / basement ceiling	B	1557,7	2,597	0,10	76,7	6,62
	A			1,00		
	A			1,00		
	X			0,75		
Windows	A	1247,8	0,973	1,00	76,7	20,10
Exterior Door	A	8,0	2,200	1,00	76,7	0,29
Exterior TB (length/m)	A	317,0	0,062	1,00	76,7	0,32
Perimeter TB (length/m)	P	273,1	-0,221	0,10	76,7	-0,10
Ground TB (length/m)	B			0,10		0,00
Total of all building envelope areas		7287,3				

Transmission heat losses Q_T

Total 169545 kWh/a

per m² Treated Floor Area 36,6 kWh/(m²a)

Ventilation System:

Effective heat recovery efficiency of heat recovery η_{eff} 81%

Efficiency of Subsoil Heat Exchanger η_{SHX} 0%

Effective Air Volume, V_v 4630,4 m³

Clear Room Height 2,50 m

11576,0 m³

η_{v,system} 1/h

η_{HR}

η_{v,Res} 1/h

Energetically Effective Air Exchange n_v 0,175

0,81

0,038

0,072

V_v m³

η_v 1/h

C_{As} W/(m²K)

G_t kWh/a

21048 kWh/a

4,5 kWh/(m²a)

Ventilation heat losses Q_V

11576,0 * 0,072 * 0,33 * 76,7 = 21048 kWh/a

4,5 kWh/(m²a)

Total heat losses Q_L

Q_T kWh/a

Q_V kWh/a

Reduction Factor Night/Weekend Saving

1,0

190593 kWh/a

41,2 kWh/(m²a)

Orientation of the area

Reduction Factor See 'Windows' worksheet

g-Value (perp. radiation)

Area m²

Radiation HP kWh/(m²a)

1 North 0,38 * 0,51 * 258,55 * 127 = 6435 kWh/a

2 East 0,24 * 0,51 * 286,55 * 251 = 8646 kWh/a

3 South 0,28 * 0,51 * 348,24 * 444 = 21971 kWh/a

4 West 0,20 * 0,51 * 354,44 * 281 = 10294 kWh/a

5 Horizontal 0,00 * 0,00 * 0,00 * 417 = 0 kWh/a

Available Solar Heat Gains Q_S

Total 47346 kWh/a

10,2 kWh/(m²a)

Internal Heat Gains Q_I

Length heating period d/a

Spec. Power q_i W/m²

A_{TFA} m²

60356 kWh/a

13,0 kWh/(m²a)

0,024 * 194 * 2,80 * 4630,4 = 60356 kWh/a

Free Heat Q_F

Q_S + Q_I = 107702 kWh/a

23,3 kWh/(m²a)

Ratio of Free Heat to Losses Q_F / Q_L = 0,57

Utilisation Factor Heat Gains η_G

(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶) = 97%

Heat Gains Q_G

η_G * Q_F = 104912 kWh/a

22,7 kWh/(m²a)

Annual heating demand Q_H

Q_L - Q_G = 85681 kWh/a

19 kWh/(m²a)

Limiting value 25 kWh/(m²a)

Requirement met? yes

(This page displays the sums of the monthly method over the heating period)

Climate: Велико Търново					Interior Temperature: 20 °C	
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B					Building type: School	
Spec. Capacity: 204 Wh/(m²K)					Treated Floor Area A _{FFA} : 4630,4 m²	
Building assembly	Temperature Zone	Area m²	U-Value W/(m²K)	Month. Red. Fac.	G _i kWh/a	per m² Treated Floor Area
Exterior Wall - Ambient	A	2554,0	0,143	1,00	87	6,85
Exterior Wall - Ground	B	362,1	0,180	1,00	10	0,14
Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	87	3,68
Floor slab / basement ceiling	B	1557,7	2,597	1,00	10	8,49
	A			1,00		
	X			0,75		
Windows	A	1247,8	0,973	1,00	87	22,82
Exterior Door	A	8,0	2,200	1,00	87	0,33
Exterior TB (length/m)	A	317,0	0,062	1,00	87	0,37
Perimeter TB (length/m)	P	273,1	-0,221	1,00	10	-0,13
Ground TB (length/m)	B			1,00		0,00
Total						42,5 kWh/(m²a)

Transmission heat losses Q_T

Effective Air Volume V _V	A _{FFA} m²	Clear Room Height m		
4630	2,50	11576		
Effective Air Change Rate Ambient n _{V,a}	Effective Air Change Rate Ground n _{V,g}	n _{V,system} 1/h	η ₁ %	η ₂ %
0,175	0,175	0,175	0%	0%
0,175	0,175	0,175	0%	0%
V _V m³	n _{V,equifraction} 1/h	C _{AE} Wh/(m²K)	G _i kWh/a	kWh/(m²a)
11576	0,072	0,33	87	23889
11576	0,000	0,33	56	0
Total				5,2 kWh/(m²a)

Ventilation losses ambient Q_VVentilation losses ground Q_{V,e}Ventilation heat losses Q_VTotal heat losses Q_L

Orientation of the area	Reduction Factor See "Windows" worksheet	g-Value (perp. radiation)	Area m²	Global Radiation kWh/(m²a)	kWh/a
North	0,38	0,51	258,6	239	11657
East	0,24	0,51	286,6	467	16109
South	0,28	0,51	348,2	699	34616
West	0,20	0,51	354,4	505	18476
Horizontal	0,00	0,00	0,0	787	0
Sum opaque areas					7484
Total					19,1 kWh/(m²a)


Available Solar Heat Gains Q_S

Length Heat. Period	Spec. Power q _i W/m²	A _{FFA} m²		
0,024	2,8	4630,4		
Free Heat Q _F	Q _S + Q _L			
	173289			
Ratio Free Heat to Losses	Q _F / Q _L			
	0,78			
Utilisation Factor Heat Gains η _G	81%			
Heat Gains Q _G	η _G * Q _F			
	140618			
Annual heating demand Q _H	Q _L - Q _G			
	80244			
Limiting value	25 kWh/(m²a)			
Requirement met?	yes			

Climate: Велико Търнов
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Interior Temperature: 20 °C
Building type: School
Treated Floor Area A_{TFA} : 4630 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating Degree Hours - Exterior	15,9	12,7	11,4	7,3	3,4	0,7	-0,9	-0,7	3,3	7,1	10,6	15,3	86	kKh
Heating Degree Hours - Ground	1,4	1,3	1,3	1,1	1,0	-2,3	-2,5	-2,5	0,7	0,8	1,0	1,2	2	kKh
Losses - Exterior	33230	26541	23677	15254	7041	1389	-1968	-1494	6916	14724	22168	31944	179422	kWh
Losses - Ground	5481	5084	5349	4567	3906	-9276	-10119	-10266	2639	3358	4036	4948	9705	kWh
Sum spec. losses	8,4	6,8	6,3	4,3	2,4	-1,7	-2,6	-2,5	2,1	3,9	5,7	8,0	40,8	kWh/m ²
Solar gains - North	710	963	1419	1875	2433	2737	2585	2230	1622	1216	760	659	19209	kWh
Solar gains - East	966	1207	1897	2760	3346	3449	3553	3070	2415	1725	966	828	26181	kWh
Solar gains - South	3021	3367	4209	4457	4259	4011	4308	4605	4754	4506	3219	2823	47541	kWh
Solar gains - West	1149	1446	2304	2864	3388	3353	3561	3391	2831	2195	1304	995	28781	kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - Opaque	444	588	905	1229	1475	1519	1590	1424	1127	827	494	395	12018	kWh
Internal Heat Gains	9646	8713	9646	9335	9646	9335	9646	9646	9335	9646	9335	9646	113575	kWh
Sum spec. gains solar + internal	3,4	3,5	4,4	4,9	5,3	5,3	5,5	5,3	4,8	4,3	3,5	3,3	53,4	kWh/m ²
Utilisation Factor	100%	100%	99%	85%	45%	100%	100%	100%	43%	86%	100%	100%	44%	
Annual heating demand	22777	15347	8790	792	1	0	0	0	1	829	10161	21546	80244	kWh
Spec. Heating Demand	4,9	3,3	1,9	0,2	0,0	0,0	0,0	0,0	0,0	0,2	2,2	4,7	17,3	kWh/m ²



Annual heating demand: Comparison

Monthly method	(Worksheet Heating Demand) 80244 kWh/a	(Worksheet Heating Demand) 17,3 kWh/(m ² a) reference to treated floor area according to PHPP
Annual method	(Worksheet Annual Heating Demand) 85681 kWh/a	(Worksheet Annual Heating Demand) 18,5 kWh/(m ² a) reference to treated floor area according to PHPP

SPECIFIC SPACE HEATING LOAD

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B		Building type: School	
Climate (HL): Велико Търнов		Treated Floor Area A_{TFA} : 4630,4 m ²	Interior Temperature: 20 °C

Design Temperature		Radiation:										
Weather 1:	-9,3	°C	North	East	South	West	Horizontal					
Weather 2:	-4,8	°C	19	39	82	35	56	W/m ²				
Ground Design Temp.	18,1	°C	16	23	40	24	36	W/m ²				

Building assembly	Temperature Zone	m ²	U-Value W/(m ² K)	Factor Always 1 (except "X")	TempDiff 1 K	TempDiff 2 K	P_T 1 W	P_T 2 W
1. Exterior Wall - Ambient	A	2554,0	0,143	1,00	29,3	24,8	10686	9047
2. Exterior Wall - Ground	B	362,1	0,180	1,00	1,9	1,9	121	121
3. Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	29,3	24,8	5739	4859
4. Floor slab / basement ceiling	B	1557,7	2,597	1,00	1,9	1,9	7556	7556
5.	A			1,00	29,3	24,8		
6.	A			1,00	29,3	24,8		
7.	X			0,75	29,3	24,8		
8. Windows	A	1247,8	0,973	1,00	29,3	24,8	35609	30146
9. Exterior Door	A	8,0	2,200	1,00	29,3	24,8	514	435
10. Exterior TB (length/m)	A	317,0	0,062	1,00	29,3	24,8	576	487
11. Perimeter TB (length/m)	P	273,1	-0,221	1,00	1,9	1,9	-113	-113
12. Ground TB (length/m)	B			1,00	1,9	1,9		
13. House/DU Partition Wall	I	28,6	0,782	1,00	3,0	3,0	67	67

Transmission heat load P_T

Total	=	60756	or	52606
-------	---	-------	----	-------

Ventilation System:

Effective Air Volume, V_v	A_{TFA} m ²	Clear Room Height m	m ³
4630,4	2,50	11576	

Heat recovery efficiency of the Heat Exchanger	η_{HR}	Heat Recovery Efficiency SHX	Efficiency SHX	η_{SHX} 1	η_{SHX} 2
81%	0%	0%	0%	0%	0%

Energetically Effective Air Exchange n_v	$n_{V,Res}$ (Heating Load) 1/h	$n_{V,system}$ 1/h	Φ_{HR}	Φ_{HR}	1/h	1/h
0,096	0,175	0,81	0,81	0,129	0,129	

Ventilation heat load P_V

V_v m ³	n_v 1/h	n_v 1/h	C_{air} Wh/(m ³ K)	TempDiff 1 K	TempDiff 2 K	P_V 1 W	P_V 2 W
11576,0	0,129	0,129	0,33	29,3	24,8	14485	12263

Total heating load P_L

P_L 1 W	P_L 2 W
75241	64869

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see "Windows" worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P_T 1 W	P_T 2 W
1. North	258,6	0,5	0,38	19	16	963	811
2. East	286,6	0,5	0,24	39	23	1345	793
3. South	348,2	0,5	0,28	82	40	4061	1981
4. West	354,4	0,5	0,20	41	26	1497	960
5. Horizontal	0,0	0,0	0,40	56	36	0	0

Solar heating power P_S

Total	=	7867	or	4545
-------	---	------	----	------

Internal heating load P_i

Spec. Power W/m ²	A_{TFA} m ²	P_i 1 W	P_i 2 W
1,6	4630	7409	7409

Heating power (gains) P_G

$P_T + P_i$	=	15275	or	11953
$P_L - P_G$	=	59966	or	52916

Heating load P_H

	=	59966	W
--	---	-------	---

Area specific space heating load PH / A_{TFA}

	=	13,0	W/m ²
--	---	------	------------------

Input Max. Supply Air Temperature	52	°C	
Max. Supply Air Temperature $\vartheta_{Supply,Max}$	52	°C	Supply Air Temperature Without Heating
			$\vartheta_{Supply,Min}$
			14,4
			15,2

For comparison: heating load transportable by the supply Air. $P_{Supply Air,Max}$

	=	25178	W specific:	5,4	W/m ²
Supply Air Heating Sufficient?		no			

Building:	Primary School 8 "Sveti Sveti Kiril i Metodi" - School		Building type:	School
Building volume:	11576	m³	Heat recovery η_{HRV} :	81%
Max. indoor absolute humidity:	12	g/kg	Energy recovery η_{ER} :	0%
Internal humidity sources:	2	g/(m²h)	Subsoil heat exchanger η_{SHX} :	0%

Results passive cooling		Results active cooling	
Frequency of overheating:	3,1%	at the overheating limit $\vartheta_{max} = 25$ °C	Useful Cooling Demand:
Frequency of exceeded humidity:	0,0%		Dehumidification demand:
max. humidity:	11,3	g/kg	

Summer background ventilation to ensure adequate air quality

Air exchange via ventilation system with supply	1,17	1/h	HRV/ERV in Summer (check only one field)
			None ☒
			automatic bypass, controlled by temperature difference ☐
			automatic bypass, controlled by enthalpy difference ☐
			always ☐

Air exchange via extract air system	0,62	1/h	Specific power consumption (for extract air system)
			0,30
			Wh/m³

Window ventilation air exchange	0,14	1/h
---------------------------------	------	-----

Effective air exchange

	$n_{V,system}$ 1/h		η_{SHX}		η_{HR}		$n_{V,equiv}$ 1/h
exterior $n_{V,e}$	1,170	*(1-	0%	)*(1-	0,81	) =	0,224
without HR	1,170	*(1-	0%	)			1,170
Ground $n_{L,g}$	1,170	*	0%	*(1-	0,81	) =	0,000
without HR	1,170	*	0%			=	0,000

Ventilation conductance

	V_V m³		$n_{V,equiv}$ 1/h		C_{air} Wh/(m³K)			
exterior $H_{V,e}$	11576	*	0,224	*	0,33	=	856,9	W/K
without HR	11576	*	1,170	*	0,33	=	4469,5	W/K
Ground $H_{V,g}$	11576	*	0,000	*	0,33	=	0,0	W/K
without HR	11576	*	0,000	*	0,33	=	0,0	W/K
Infiltration, window, extract air system	11576	*	0,796	*	0,33	=	3039,0	W/K

Additional Summer Ventilation for Cooling

Additional ventilation regulation

Minimum Acceptable Indoor Temperature: 22,0 °C

Type of additional ventilation

Window Night Ventilation, Manual	Night ventilation value	0,00	1/h
mechanical, automatically	Corresponding air change rate	0,62	1/h
Controlled ventilation	during operation, in addition to base air change	0,30	Wh/m³
	Specific power consumption	0,30	Wh/m³
	Temperature difference		Controlled by (please choose)
	Humidity difference		☒

Secondary Calculation: hygienic air exchange through window ventilation

Estimation for window air exchange to ensure sufficient air quality

Description	Day	Day	Day	Day	Day	Day	
Open duration [h/d]	4	4	4	4	1	4	
Climate Boundary Conditions							
Temperature Diff Interior - Exterior	4	4	4	4	4	4	K
Wind Velocity	1	1	1	1	1	1	m/s
Window Group 1							
Quantity	30	4	25	6	2	10	
Clear Width	0,75	0,75	0,75	0,75	0,90	0,84	m
Clear Height	1,60	1,60	1,60	1,35	3,00	1,92	m
Tilting window (check if appropriate)	x	x	x	x		x	
Opening Width (for tilting windows)	0,070	0,070	0,070	0,070		0,070	m
Window Group 2 (Cross Ventilation)							
Quantity	30	4	25	6	2	9	
Clear Width	0,75	0,75	0,75	0,75	0,90	0,80	m
Clear Height	1,60	1,60	1,60	1,35	3,00	1,45	m
Tilting window (check if appropriate)	x	x	x	x		x	
Opening Width (for Tilting Window)	0,070	0,070	0,070	0,070		0,070	m
Difference in Height to Window 1							m
							Total
Result: air exchange	0,05	0,01	0,04	0,01	0,02	0,02	0,14 1/h

Secondary calculation: additional night ventilation for cooling

Air change value during additional window night ventilation

Description	Night	Night	Night	Night	Night	Night	
Reduction Factor	100%	100%	100%	100%	100%	100%	
Climate Boundary Conditions							
Temperature Diff Interior - Exterior	1	1	1	1	1	1	K
Wind Velocity	0	0	0	0	0	0	m/s
Window Group 1							
Quantity	30	4	25	6	7	4	
Clear Width	0,75	0,75	0,75	0,75	2,15	2,40	m
Clear Height	1,60	1,60	1,60	1,35	2,05	2,60	m
Tilting window (check if appropriate)	x	x	x	x	x	x	
Opening Width (for Tilting Window)	0,070	0,070	0,070	0,070	0,060	0,060	m
Window Group 2 (Cross Ventilation)							
Quantity	30	4	25	6	7	2	
Clear Width	0,75	0,75	0,75	0,75	2,15	3,50	m
Clear Height	1,60	1,60	1,60	1,35	1,45	2,60	m
Tilting window (check if appropriate)	x	x	x	x	x	x	
Opening Width (for Tilting Window)	0,070	0,070	0,070	0,070	0,060	0,060	m
Difference in Height to Window 1							m
							Total
Result: night ventilation values	0,10	0,01	0,08	0,02	0,03	0,02	0,27 1/h

SUMMER: PASSIVE COOLING

Climate:	Белико Търнов		Building type:	School	
Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B		Treated Floor Area A_{TFA} :	4630,4	m ²
Overttemperature limit:	25	°C	Building volume:	11576	m ³
Nominal humidity:	12	g/kg	Internal humidity sources:	2,0	g/(m ² h)
Spec. Capacity:	204	Wh/(m ² K)			

Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Red. Factor $f_{r, Summer}$	H_{Summer} Heat Conductance
1. Exterior Wall - Ambient	A	2554,0	0,143	1,00	364,3
2. Exterior Wall - Ground	B	362,1	0,180	1,00	65,0
3. Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	195,6
4. Floor slab / basement ceiling	B	1557,7	2,597	1,00	4045,4
5.	A			1,00	
6.	A			1,00	
7.	X			0,75	
8. Windows	A	1247,8	0,973	1,00	1213,9
9. Exterior Door	A	8,0	2,200	1,00	17,5
10. Exterior TB (length/m)	A	317,0	0,062	1,00	19,6
11. Perimeter TB (length/m)	P	273,1	-0,221	1,00	-60,3
12. Ground TB (length/m)	B			1,00	

Exterior Thermal Transmittance, $H_{T,e}$	1811,0	W/K
Ground Thermal Transmittance, $H_{T,g}$	4050,1	W/K

Summer Ventilation from "SummVent" worksheet

Ventilation unit conductance		Ventilation parameter		Summer ventilation regulation	
Exterior $H_{v,e}$	856,9 W/K	Temperature amplitude summer	11,2 K	None	HRV/ERV
without HR	4469,5 W/K	Minimum Acceptable Indoor Temperature	22,0 °C	Controlled by temperature	x
Ground HV.g	0,0 W/K	Heat capacity air	0,33 Wh/(m ² K)	Controlled by enthalpy	
without HR	0,0 W/K	Supply air exchange	1,17 1/h	always	
Ventilation conductance, others		Ambient air exchange	0,80 1/h		Additional ventilation
Exterior	3039,0 W/K	Window night ventilation air exchange rate, manual @ 1K	0,00 1/h	Controlled by temperature	
		Air change rate due to mechanical, automatically controlled ventilation	0,62 1/h	Controlled by humidity	x
		Specific power consumption for	0,30 Wh/m ³		
		η_{HR}	81%		
		η_{ERV}	0%		
		η^{*}_{SHX}	0%		

Orientation of the area	Angle Factor Summer	Shading Factor Summer	Loss-Dirt	g-Value (perp. radiation)	Area m ²	Portion of Glazing	Aperture m ²
1. North	0,9	0,53	0,95	0,51	258,6	59%	35,3
2. East	0,9	0,43	0,95	0,51	286,6	49%	26,2
3. South	0,9	0,40	0,95	0,51	348,2	51%	30,4
4. West	0,9	0,34	0,95	0,51	354,4	49%	25,8
5. Horizontal	0,9	1,00	0,95	0,00	0,0	0%	0,0
6. Sum opaque areas							11,7

Total	129,3	m ² /m ²	0,03
-------	-------	--------------------------------	------

Solar Aperture

Specif. Power q_i	2,8 W/m ²	A_{TFA}	4630 m ²	W	12965	W/m ²	2,8
---------------------	----------------------	-----------	---------------------	---	-------	------------------	-----

Internal Heat Gains Q_i

Frequency of Overheating $h_{\theta \geq \theta_{max}}$	3,1%	At the overheating limit $\theta_{max} = 25\text{ °C}$
If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.		

Daily internal temperature stroke


Transmission kWh/d	243,4	+	Ventilation kWh/d	1305,0	+	Solar load kWh/d	536,7	) * 1000	/ (Spec. Capacity Wh/(m ² K)	204	* A_{TFA} m ²	4630	) =	2,2	K
--------------------	-------	---	-------------------	--------	---	------------------	-------	----------	--	-----	----------------------------	------	-----	-----	---

SPECIFIC USEFUL COOLING DEMAND

Climate: Велико Търново
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B

Interior Temperature: 25 °C
Building type: School
Treated Floor Area A_{FPA}: 4630 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating Degree Hours - Exterior	19,7	16,1	15,1	11,0	7,1	4,3	2,8	3,0	7,0	10,8	14,3	19,1	130	kKh
Heating Degree Hours - Ground	5,1	4,6	5,0	4,7	4,7	1,3	1,2	1,2	4,3	4,5	4,6	4,9	46	kKh
Losses - Exterior	180467	147477	137824	99377	64080	37993	24115	26190	62631	98448	130567	174911	1184082	kWh
Losses - Ground	20854	18970	20720	19432	19255	5383	5021	4872	17476	18698	18893	20312	189887	kWh
Losses summer ventilation	42808	34966	32652	23514	15125	8931	5776	6116	14796	23315	30965	41497	280462	kWh
Sum spec. heat losses	52,7	43,5	41,3	30,7	21,3	11,3	7,5	8,0	20,5	30,3	39,0	51,1	357,3	kWh/m²
Solar load North	494	671	989	1307	1695	1907	1801	1554	1130	848	530	459	13384	kWh
Solar load East	732	915	1439	2093	2537	2616	2694	2328	1831	1308	732	628	19853	kWh
Solar load South	1856	2069	2586	2738	2617	2465	2647	2830	2921	2769	1978	1734	29210	kWh
Solar load West	809	1018	1621	2015	2384	2359	2506	2386	1992	1544	918	700	20252	kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar load Opaque	444	588	905	1229	1475	1519	1590	1424	1127	827	494	395	12018	kWh
Internal Heat Gains	9646	8713	9646	9335	9646	9335	9646	9646	9335	9646	9335	9646	113575	kWh
Sum spec. loads solar + internal	3,0	3,0	3,7	4,0	4,4	4,4	4,5	4,4	4,0	3,7	3,0	2,9	45,0	kWh/m²
Utilisation Factor Losses	6%	7%	9%	13%	21%	38%	46%	53%	19%	12%	8%	6%	13%	
Useful Cooling Energy Demand	0	0	0	0	3	72	4826	343	2	0	0	0	5246	kWh
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,0	0,0	1,0	0,1	0,0	0,0	0,0	0,0	1,1	kWh/m²
specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0,2	kWh/m²
Sensible Fraction	100%	100%	100%	100%	100%	100%	86%	100%	100%	100%	100%	100%	87%	



SPECIFIC USEFUL COOLING DEMAND

(This page displays the sums of the monthly method over the cooling period))

Climate:	Велико Търново	Building type:	School
Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Sectio	Treated Floor Area A_{TFA} :	4630,4 m ²
Interior temperature summer:	25 °C	Building volume:	11576 m ³
Nominal humidity:	12 g/kg	Internal humidity sources:	2,0 g/(m ² h)
Spec. Capacity:	204 Wh/(m ² K)		

Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Mon. Red. Fac.	G _i kWh/a	kWh/a	per m ² Treated Floor Area
1. Exterior Wall - Ambient	A	2554,0	0,143	1,00	46	16767	3,62
2. Exterior Wall - Ground	B	362,1	0,180	1,00	22	1426	0,31
3. Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	46	9005	1,94
4. Floor slab / basement	B	1557,7	2,597	1,00	22	88712	19,16
5.	A			1,00			
6.	A			1,00			
7.	X			0,75			
8. Windows	A	1247,8	0,973	1,00	46	55873	12,07
9. Exterior Door	A	8,0	2,200	1,00	46	807	0,17
10. Exterior TB (length/m)	A	317,0	0,062	1,00	46	903	0,20
11. Perimeter TB (length/m)	P	273,1	-0,221	1,00	46	-2775	-0,60
12. Ground TB (length/m)	B			1,00			0,00
Total						170718	36,9

Transmission losses Q_T (negative: heat loads)

Summer Ventilation from 'SummVent' worksheet

Ventilation unit	conductance	Ventilation parameter	Summer ventilation regulation
Exterior $H_{V,e}$	856,9 W/K	Temperature amplitude summer	11,2 K
without HR	4469,5 W/K	Minimum Acceptable Indoor Temperature	22,0 °C
Ground $H_{V,g}$	0,0 W/K	Heat capacity air	0,33 Wh/(m ² K)
without HR	0,0 W/K	Supply air exchange	1,17 1/h
Ventilation conductance, others		Ambient air exchange	0,80 1/h
Exterior	3039,0 W/K	Window night ventilation air exchange rate, manual @ 1K	0,80 1/h
		Air change rate due to mechanical, automatically controlled	0,62 1/h
		Specific power consumption for	0,30 Wh/m ³
		η_{HR}	81%
		η_{ERV}	0%
		η^{SHX}	0%

Hygienic air change

Effective Air Change Rate Ambient $n_{a,e}$
Effective Air Change Rate Ground $n_{g,g}$

$n_{V,system}$ 1/h	η^{SHX}	η_{HR} (considers bypass)	$n_{V,Rest}$ 1/h	$n_{V,equifraction}$ 1/h
1,170	0%	0,00	0,796	1,966
1,170	0%	0,00		0,000

V_V m ³	$n_{V,equifraction}$ 1/h	C_{Air} Wh/(m ² K)	G _i kWh/a	kWh/a	kWh/(m ² a)
11576	1,966	0,33	44	332254	71,8
11576	0,000	0,33	0	0	0,0
11576	0,574	0,33	45	97575	21,1
Total					92,8

Ventilation heat losses Q_V

Q_T kWh/a	Q_V kWh/a	kWh/a	kWh/(m ² a)
170718	429828	600547	129,7

Total heat losses Q_L

Orientation of the area	Reduction Factor	g-Value (perp. radiation)	Area m ²	Global Radiation kWh/(m ² a)	kWh/a	kWh/(m ² a)
1. North	0,27	0,51	258,6	290	10241	
2. East	0,18	0,51	286,6	589	15406	
3. South	0,17	0,51	348,2	624	18986	
4. West	0,14	0,51	354,4	590	15187	
5. Horizontal	0,40	0,00	0,0	1018	0	
6. Sum opaque areas					9192	
Total					69013	14,9

Available Solar Heat Gains Q_S

kh/d	Length Heat. Period d/a	Spec. Power q_i W/m ²	A_{TFA} m ²	kWh/a	kWh/(m ² a)
0,024	214	2,8	4630,4	66589	14,4

Internal Heat Gains Q_i

Sum heat loads Q _F	Q _S + Q _I =	kWh/a 135602	kWh/(m²a) 29,3
-------------------------------	-----------------------------------	------------------------------------	--------------------------------------

Sum heat loads Q_F

Ratio of Losses to Free Heat Gains	$Q_L / Q_F =$	4.43
------------------------------------	---------------	------

Utilisation Factor Heat Losses η_G

Useful heat losses $Q_{V,n}$	$\eta_G \cdot Q_L$	=	130356	28,2
------------------------------	--------------------	---	--------	------

Useful heat losses $Q_{V,n}$

Useful Cooling Demand Q_K	$Q_F - Q_{V,n} =$	5246	1
-----------------------------	-------------------	------	---

Useful Cooling Demand Q_K

Limiting value	kWh/(m ² a)	Requirement met?
15	-	-

EnerPHit planning:

COMPRESSOR COOLING UNITS

Climate:	Белико Търнов		Building type:	School	
Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - 3rd floor		Sealed floor area A _{TFA} :	4630,4	m ²
Interior temperature summer:	25,0	°C	Mechanical cooling:		
Nominal humidity:	12,0	g/kg	Air exchange via ventilation system with supply air:	1,2	
Internal humidity sources:	2,0	g/(m ³ h)			

Supply Air Cooling

check as appropriate

On/Off Mode (check as appropriate)

max. cooling capacity (sensible + latent)

Temperature reduction dry

Seasonal energy efficiency ratio

0,0	K
2,0	

Recirculation Cooling

check as appropriate

On/Off Mode (check as appropriate)

max. cooling capacity (sensible + latent)

Volume flow rate at nominal power

Temperature reduction dry

Variable volume flow (check if appropriate)

Seasonal energy efficiency ratio

Additional Dehumidification

check as appropriate

Waste heat to room (please check if applicable)

Seasonal energy efficiency ratio

Panel Cooling

check as appropriate

Seasonal energy efficiency ratio

--

Useful cooling total

Cooling contribution by:

Supply Air Cooling

Recirculation Cooling

Dehumidification

Remaining for Panel Cooling

Total

sensible kWh/(m ² a)	latent kWh/(m ² a)	COP	Electricity Demand (kWh/a) kWh/(m ² a)	Sensible Fraction
1,1	0,2			87%
() + ()	/	2,0 =		
() + ()	/	0,0 =		
	/			0%
	/	0,0 =		100%
(0,0) + (0,0)	/		0,0	0%


Unsatisfied Demand

1,1	0,2
-----	-----

Cooling demand covered? (Yes/No)

Humidity loads and humidity removal

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Internal humidity sources:	1,1	1,0	1,1	1,0	1,1	1,0	1,1	1,1	1,0	1,1	1,0	1,1	12	kWh/m ²
Infiltration/Window/Extract air system	-11,0	-9,8	-10,0	-7,8	-5,0	-2,2	-1,0	-1,6	-4,1	-6,7	-8,5	-10,7	-78	kWh/m ²
Supply air ventilation system	-16,1	-14,3	-14,7	-11,5	-7,4	-3,2	-1,5	-2,3	-6,1	-9,8	-12,4	-15,7	-115	kWh/m ²
Summer ventilation window	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Summer ventilation mechanically	0,0	0,0	0,0	0,0	0,0	0,0	-0,5	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Total humidity load	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Dehumidification by supply air cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Dehumidification by circulation cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Additional Dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Total dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	
Unnecessary dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Missing dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0	kWh



COOLING LOAD

Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B										Building type:	School																				
Climate (HL):	Велико Търново										Treated Floor Area A _{TFA} :	4630,4 m ²										Interior Temperature:	25 °C									
											Building volume:	11576 m ³										Spec. Capacity:	204 Wh/(m ² ·h)									
																						Nominal humidity:	12,0 g/kg									
																						Internal humidity sources:	2,0 g/kg									
Temperature:	Ambient Air Dew Point Sky										Radiation:	North East South West Horizontal																				
Weather 1:	27,9 °C 18,6 16,5 °C											92 197 185 197 349 W/m ²																				
Weather 2:	24,3 °C 18,6 18,6 °C											63 158 236 158 268 W/m ²																				
Ground Design Temp:	23,4 °C SHX 11,4 °C																															
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² ·K)	Factor Always 1 (except "X")	TempDiff 1 K	TempDiff 2 K	P _T 1 W	P _T 2 W																								
1. Exterior Wall - Ambient	A	2554,0	0,143	1,00	2,9	-0,7	1044	-267																								
2. Exterior Wall - Ground	B	362,1	0,180	1,00	-1,6	-1,6	-104	-104																								
3. Roof/Ceiling - Ambient	A	1557,7	0,126	1,00	2,9	-0,7	561	-144																								
4. Floor slab / basement ceiling	B	1557,7	2,597	1,00	-1,6	-1,6	-6444	-6444																								
5.	A			1,00	2,9	-0,7																										
6.	A			1,00	2,9	-0,7																										
7.	X			0,75	2,9	-0,7																										
8. Windows	A	1247,8	0,973	1,00	2,9	-0,7	3479	-891																								
9. Exterior Door	A	8,0	2,200	1,00	2,9	-0,7	50	-13																								
10. Exterior TB (length/m)	A	317,0	0,062	1,00	2,9	-0,7	56	-14																								
11. Perimeter TB (length/m)	P	273,1	-0,221	1,00	-1,6	-1,6	96	96																								
12. Ground TB (length/m)	B			1,00	-1,6	-1,6																										
13. House/DU Partition Wall	I	28,6	0,782	1,00	3,0	3,0	67	67																								
14. Radiation correction ambient air			L _{ambiant} W/K	-61,8	2,9	-0,7	-177	45																								
15. Radiation correction sky			L _{sky} W/K	60,9	-8,5	-6,4	-516	-390																								
Transmission heat load P _T									Total	=	-1888	or	-8059																			
Ventilation load	V _V m ³	n _{V,equl} fraction 1/h	n _{V,equl} fraction 1/h	C _{Air} Wh/(m ³ ·K)	TempDiff 1 K	TempDiff 2 K	P _V 1 W	P _V 2 W																								
Exterior P _{V,e}	11576	1,966	1,966	0,33	2,9	-0,7	21519	-5511																								
Ground P _{L,e}	11576	0,000	0,000	0,33	-13,6	-13,6	0	0																								
Summer ventilation P _{L,s}	11576	0,000	0,000	0,33	0,0	0,0	0	0																								
Ventilation heat load P _V									Total	=	21519	or	-5511																			
Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W																									
1. North	258,6	0,5	0,27	92	63	3249	2234																									
2. East	286,6	0,5	0,18	197	158	5153	4140																									
3. South	348,2	0,5	0,17	185	236	5629	7189																									
4. West	354,4	0,5	0,14	203	173	5237	4457																									
5. Horizontal	0,0	0,0	0,40	349	268	0	0																									
6. Sum opaque areas						3094	2524																									
Solar load P _S									Total	=	22362	or	20544																			
Internal heating load P _I	Spec. Power W/m ²	A _{TFA} m ²	P _I 1 W	P _I 2 W																												
	2,8	4630	12965	12965																												
P _T + P _V + P _S + P _I				=	54958	or	19939																									
Cooling load P _C				=	54958	W																										
Area specific cooling load P _C / A _{TFA}				=	11,9	W/m ²																										
Please enter the minimum supply air temperature.	3 °C	Supply air temperature without cooling	θ _{Supply,Min}	27,9 °C	24,3 °C																											
For comparison: cooling load, transportable through the supply air P _{Supply,Max}				=	111139	95048																										
				specific:	24,0	20,5																										
Air conditioning over the supply air possible?							(yes/no)	yes																								
Daily internal temperature stroke	Transmission W	Ventilation W	Solar load W	Time h/d	Spec. Capacity Wh/(m ² ·K)	A _{TFA} m ²																										
	(-1887,9	+ 21519,2	+ 22361,7	) * 24	/ (204	* 4630	=	1,1	K																							
Dehumidification load	from 'Cooling' worksheet																															
Absolute humidity exterior air	13,4	OR	13,4	g/kg	Absolute humidity supply air	13,4	OR	13,4	g/kg																							
Ambient air mass flow	10867	OR	10867	kg/h	Supply air mass flow	15982	OR	15982	kg/h																							
Summer ventilation air mass flow	0	OR	0	kg/h	Humidity load, supply air	23070	OR	23070	g/h																							
Humidity load, outside air	15686	OR	15686	g/h	Humidity load, internal	9261	OR	9261	g/h																							
Enthalpy of vaporisation Wh/kg	707,639	/	1000	* g/kg	Humidity load g/h	48017	OR	48017	g/h	P _D 1 W	P _D 2 W																					
											=	33979	or	33979																		
Dehumidification load P _T											=	33979	W																			
Area specific dehumidification load P _T / A _{TFA}											=	7,3	W/m ²																			
Monthly Average values																																
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,0	0,0	1,0	0,1	0,0	0,0	0,0	0,0	kWh/m ²																			
Specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	kWh/m ²																			
Sensible Fraction	100%	100%	100%	100%	100%	100%	86%	100%	100%	100%	100%	100%																				
Minimum of sensible cooling load fraction occurred													100%																			

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B**

Interior Temperature:	20	°C
Building type:	School	
Treated Floor Area A_{TFA} :	4630	m ²
Occupancy:	680,0	Pers
Number of dwelling units:	1	
Annual heating demand $q_{Heating}$:	80244	kWh/a
Length of Heating Period:	194	d
Average heating load $Pave$:	17,2	kW
Marginal Utilisability of Additional Heat Gains:	87%	

Space Heat Distribution

Length of Distribution Pipes	L_H (Project)	
Heat Loss Coefficient per m Pipe	Ψ (Project)	
Temperature of the Room Through Which the Pipes	$\vartheta_{X, Mechanical Room}$	
Design Flow Temperature	ϑ_{dist} Flow, Design Value	
Design system heating load	$P_{heating}$ (exist./calc.)	
Flow Temperature Control (check)		
Design Return Temperature	ϑ_R	$= 0.714 \cdot (\vartheta_{dist} - 20) + 20$
Annual Heat Emission per m of Plumbing	q_{HL}	$= Y (J_m - \vartheta_X) t_{heating} \cdot 0.024$
Possible Utilization Factor of Released Heat	η_G	
Annual Losses	Q_{HL}	$= L_H \cdot q_{HL} \cdot (1 - \eta_G)$
Specif. losses	q_{HL}	$= \Sigma Q_{HL} / A_{TFA}$
*Performance ratio of heat distribution	$\epsilon_{a,HL}$	$= (q_H + q_{HV}) / q_H$

Parts			
Warm region	Cold Region		Total
1	2	3	
30,00	15,00	80,00	m
0,253	0,253	0,198	W/(mK)
20	10	20	°C
55,0	55,0	55,0	°C
62,0	62,0	40,0	kW
x	x	x	
45,0	45,0	45,0	°C
14	25	15	kWh/(m·a)
87%	0%	87%	-
52	380	149	580 kWh/a
			kWh/(m²a)
			101%
			0,1

0,1**DHW: Standard Useful Heat**

DHW Consumption per Person and Day (60 °C)	V_{DHW} (Project or Average Value 25 Litres/Person/d)	
Average Cold Water Temperature of the Supply	ϑ_{DW} Temperature of drinking water (Electricity worksheet)	
DHW Non-Electric Wash and Dish		
Useful heat - DHW	Q_{DHW}	
Specif. useful heat - DHW	q_{DHW}	$= Q_{DHW} / A_{TFA}$

4,0	Litre/Person/d
11,4	°C
1053	kWh/a
57005	kWh/a
	kWh/(m ² a)
12,3	

DHW Distribution and Storage

Length of Circulation Pipes (Flow + Return)	L_{HS} (Project)	
Heat Loss Coefficient per m Pipe	Ψ (Project)	
Temperature of the Room Through Which the Pipes	$\vartheta_{X, Mechanical Room}$	
Design Flow Temperature	ϑ_{dist} Flow, Design Value	
Daily circulation period of operation.	t_{Circ} (Project)	
Design Return Temperature	ϑ_R	$= 0.875 \cdot (\vartheta_{dist} - 20) + 20$
Circulation period of operation per year	t_{Circ}	$= 365 t_{Circ}$
Annual Heat Released per m of Pipe	q_{Z}	$= Y (J_m - \vartheta_X) t_{Circ}$
Possible Utilization Factor of Released Heat	η_{GDHW}	$= t_{heating} / 365d \cdot \eta_G$
Annual Heat Loss from Circulation Lines	Q_Z	$= L_{HS} \cdot q_{Z} \cdot (1 - \eta_{GDHW})$
Total length of individual pipes	L_U (Project)	
Exterior pipe diameter	$d_{U, Pipe}$ (Project)	
Tap openings per person per day		
Utilisation days per year		
Heat loss per tap opening	$q_{Individual}$	$= (q_{H2O} V_{H2O} + c_{H2O} V_{H2O}) (\vartheta_{dist} - \vartheta_X)$
Amount of tap openings per year	n_{Tap}	$= n_{Pers} \cdot n_{Tap} \cdot d / n_{WE}$
Annual Heat Loss	q_U	$= n_{Tap} \cdot q_{Individual}$
Possible Utilization Factor of Released Heat	$\eta_{G,U}$	$= t_{heating} / 8760 \cdot \eta_G$
Annual Heat Loss of individual pipes	Q_U	$= q_U \cdot (1 - \eta_{G,U})$
Average Heat Released from storage	P_S	
Possible Utilization Factor of Released Heat	$\eta_{G,S}$	$= t_{heating} / 8760 \cdot \eta_G$
Annual Heat Losses from storage	Q_S	$= P_S \cdot 8.760 \text{ kh} \cdot (1 - \eta_{G,S})$

Warm region	Cold Region		Total	
40,0	15,00			m
0,295	0,295			W/m/K
20	10,0			°C
60,0	55,0			°C
5,0	8,0			h/d
55	51			°C
1825	2920			h/a
20	37			kWh/m/a
46%	0%			-
433	553		986	kWh/a
2,00				m
0,010				m
3	3	3		-
150	150	150		d
0,0046				kWh/tap opening
306000				Tap openings per year
1419				kWh/a
46%				-
761			761	kWh/a
139				W
46%				
654			654	kWh/a

Total heat losses of the DHW system	Q_{WL}	$= Q_Z + Q_U + Q_S$
Specif. losses of the DHW system	q_{WL}	$= Q_{WL} / A_{TFA}$
Performance ratio DHW-distribution + storage	$\epsilon_{a,WL}$	$= (q_{TDHW} + q_{WV}) / q_{TDHW}$
Total heating demand of DHW system	Q_{GDHW}	$= Q_{DHW} + Q_{WL}$
Totalspec. heating demand of DHW system	q_{GDHW}	$= Q_{GDHW} / A_{TFA}$

2401	kWh/a
	kWh/(m ² a)
104%	-
59405	kWh/a
	kWh/(m ² a)
12,8	

12,8

Secondary calculation: Ψ -values of plumbing

Nominal width:	100	mm
Insulation Thickness:	80	mm
Mirrored?		Yes
	x	No
Thermal Conductivity	0,047	W/(mK)
$\Delta\theta$	30	K
Interior Pipe Diameter:	0,100	m
Exterior Pipe Diameter	0,102	m
Exterior Pipe Diameter	0,262	m
α -Surface	6,04	W/(m ² K)
Ψ-Value	0,295	W/(mK)
Surface Temperature Difference	1,778	K

SOLAR THERMAL SYSTEM

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B**

Building type: **School**

Treated Floor Area A_{TFA} : **4630,4** m²


Solar fraction

Heating Demand DHW	Q_{gDHW}	59405	kWh/a	(DHW+Distribution)
Annual heating demand		80824	kWh/a	(Worksheets Heating & DHW+Distribution)
Heating support (please check, if applicable)				
DHW priority (check if appropriate)				
Latitude:		43,1	°	(Worksheet Climate)
Collector:	Improved flat plate PK SL AL			
Solar Collector Area		22,30	m ²	
Deviation from North		180	°	
Angle of Inclination from the Horizontal		45	°	
Height of the Collector Field		1,00	m	
Height of Horizon	h_{Hori}		m	
Horizontal Distance	a_{Hori}		m	
Additional Reduction Factor Shading	r_{other}			
Occupancy		680,0	Persons	
Specific Collector Area		0,0	m ² /Pers	

Estimated solar DHW fraction	15%	8620 kWh/a	2 kWh/(m ² a)
Estimated solar coverage for heating	4%	3275 kWh/a	1 kWh/(m ² a)
Solar heat contribution total	8%	11895 kWh/a	3 kWh/(m ² a)

Secondary Calculation of Storage Losses

Solar Storage:	Water storage two heat exchangers		
Total storage volume	977	litre	
Volume Standby Part (above)	293	litre	
Volume Solar Part (below)	684	litre	
Specific heat losses storage (total)	4,0	W/K	
Typical Temperature DHW	60	°C	
Room Temperature	20	°C	
Storage heat losses (standby part only)	40	W	
Total storage heat losses	159	W	



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating demand DHW-preparation	5045	4557	5045	4883	5045	4883	5045	5045	4883	5045	4883	5045	59405	kWh/month
Heating demand space heating	22942	15458	8854	797	1	0	0	0	1	835	10234	21702	80824	kWh/month
Heating demand	27987	20015	13899	5680	5047	4883	5045	5045	4883	5881	15117	26748	140230	kWh/month
Radiation on Tilted Collector Surface	1511	1897	2706	3312	3533	3451	3702	3630	3249	2625	1671	1368	32655	kWh/month
Please enter: Solar production for DHW													0	kWh/month
Please enter: Solar production for heating													0	kWh/month
DHW heat demand covered by solar	0	2	18	637	1486	1504	1654	1614	1350	355	2	0	8620	kWh/month
Heating demand covered by solar	136	485	939	693	1	0	0	0	1	599	361	60	3275	kWh/month
Heating demand covered by solar	136	487	957	1330	1487	1504	1654	1614	1351	953	363	60	11895	kWh/month
Solar fraction	0%	2%	7%	23%	29%	31%	33%	32%	28%	16%	2%	0%	8%	-

Hit planning:

PHOTOVOLTAIC SYSTEM

Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B
Climate:	Велико Търнов

Building type:	School
----------------	--------


Information from the module data sheet

Technology	Poly-Si		
Nominal current		I_{MPP0}	A
Nominal voltage		U_{MPP0}	V
Nominal power		P_n	W _p
Temperature coefficient short-circuit current		α	%/K
Temperature coefficient open-circuit voltage		β	%/K

Further specifications

Latitude:		43,1	°	(Worksheet Climate)
Number of modules	n_M	45		
Deviation from North		180	°	
Angle of inclination from the horizontal		45	°	
Height of module array		1	m	
Height of horizon	h_{Hori}		m	
Horizontal distance	a_{Hori}		m	
Additional Reduction Factor Shading	r_{other}	10%		
Efficiency of the inverter	η_{HRV}	93%		

Annual yield of the inverter			kWh
Annual losses due to shading			kWh
PE value (non-renewable)			
CO ₂ -equivalent emission value			g/kWh



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Solar radiation on tilted surface	7	9	12	15	16	15	17	16	15	12	7	6	kWh/m²/Month
Ambient temperature	-1	1	5	10	16	19	22	21	16	11	5	0	°C
total monthly generation													kWh/month
Losses due to shading situation													kWh/month

Year	
146,4	kWh/m²/a
10,4	°C
	kWh/a
	kWh/a

ELECTRICITY DEMAND

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" Calculation in worksheet 'Electricity non-res'!

Column Nr.	1	2	3	4	5	6	7	8	8a	9	10	11	12	13	14
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Frequency	Reference Quantity	Useful Energy (kWh/a)	Electric Fraction	Non-Electric Fraction	Electricity Demand (kWh/a)	Additional demand	Marginal Performance Ratio	Solar Fraction	Non-Electric Demand (kWh/a)	Primary Energy-Demand (kWh/a)
Dishwashing	1	1	1,10 kWh/Use	1,00	65	/(P*a) * ##### P =	48620	100%	0%	48620					126412
Cold water connection															0
Clothes washing	1	1	1,10 kWh/Use	1,00	57	/(P*a) * ##### P =	42636	100%	0%	42636					110854
Cold water connection															0
Clothes drying with:	1	1	3,50 kWh/Use	0,88	57	/(P*a) * ##### P =	0	100%	0%	118703					308627
Condensation Dryer															0
Energy consumed by evaporation	0	1	3,13 kWh/Use	0,60	57	/(P*a) * ##### P =	0	100%	0%	0					0
Refrigerating	1	1	0,78 kWh/d	1,00	365	d/a * 1 HH =	285	100%		285					740
Freezing	1	0	0,88 kWh/d	0,90	365	d/a * 1 HH =	289	100%		289					752
or combination	0	1	1,00 kWh/d	1,00	365	d/a * 1 HH =	0	100%		0					0
Cooking with:	1	1	0,25 kWh/Use	1,00	500	/(P*a) * ##### P =	85000	100%		85000					221000
Electricity														0	0
Lighting	1	1	60 W	1,00	2,90	kh/(P*a) * ##### P =	0	100%		118320					307632
Consumer electronics	1	1	80 W	1,00	0,55	kh/(P*a) * ##### P =	29920	100%		29920					77792
Small appliances, etc.	1	1	50 kWh	1,00	1,00	/(P*a) * ##### P =	34000	100%		34000					88400
Total aux. electricity							50946			50946					132461
Other:							0			0					0
							0			0					0
							0			0					0
Total						##### kWh				528719 kWh		0 kWh		0 kWh	1374669 kWh
Specific Demand										114,2 kWh/(m²a)		0,0 kWh/(m²a)		0,0 kWh/(m²a)	296,9 kWh/(m²a)
Recommended maximum value										18					50

Building: **primary School 8 "Sveti Sveti Kiril I Metodi" - Section B**Latitude [°]: **43**

2		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	20	27
Utilisation Pattern		Periods of utilisation and operation																	
		Begin Utilisation [h]	End Utilisation [h]	Daily Utilisation Hours [h/d]	Annual Utilisation Days [d/a]	Annual Utilisation Hours [h/a]	Annual Utilisation Hours During Daytime [h/a]	Annual Utilisation Hours During Nighttime [h/a]	Daily operating hours of heating	Daily operating hours of ventilation	Lighting	Illumination Level [lux]	Height of utilisation level (0.8 or 0.0 m)	Height of utilisation level (0.8 or 0.0 m)	Relative Absenteeism	Part Use Factor of Building Operating Period for Lighting	Average Occupancy [m²/Pers.]		
1	Lobbies	7,5	18	11	180	1890	1803	87	13	13		200	0,0	0,0	0,80	1,00			
2	Corridors	7,5	18	11	180	1890	1803	87	13	13		100	0,0	0,0	0,80	1,00			
3	Computer room	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,30	0,40	2,0		
4	Bookstore	9,0	18	9	180	1620	1534	86	11	11		300	0,8	0,8	0,90	1,00			
5	Teacher offices	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,30	0,70	10,0		
6	Classroom	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,25	0,90	3,0		
7	Stairs	7,5	18	11	180	1890	1803	87	13	13		100	0,0	0,0	0,80	1,0			
8	Kitchen	10,0	16	6	180	990	990	0	8	8		100	0,8	0,8	0,80	0,4			
9	Canteen	10,0	16	6	180	990	990	0	8	8		100	0,8	0,8	0,80	0,4			
10	WC, Sanitary	7,5	18	11	180	1890	1803	87	13	13		200	0,8	0,8	0,90	1,0			
11				0		0	0	0	2	2				0,8					
12				0		0	0	0	2	2				0,8					
13				0		0	0	0	2	2				0,8					
14				0		0	0	0	2	2				0,8					
15				0		0	0	0	2	2				0,8					
16				0		0	0	0	2	2				0,8					
17				0		0	0	0	2	2				0,8					
18				0		0	0	0	2	2				0,8					
19				0		0	0	0	2	2				0,8					
20				0		0	0	0	2	2				0,8					
21	Single Office	7	18	11	250	2750	2543	207	13	13		500	0,8	0,8	0,30	0,70	10,00		
22	Group Office	7	18	11	250	2750	2543	207	13	13		500	0,8	0,8	0,30	0,70			
23	Open-Plan Office	7	18	11	250	2750	2543	207	13	13		500	0,8	0,8	0,00	1,00	15,00		
24	Meeting	7	18	11	250	2750	2543	207	13	13		500	0,8	0,8	0,50	1,00	2,00		
25	Counter Area	7	18	11	250	2750	2543	207	13	13		200	0,8	0,8	0,00	1,00			
26	Retail	8	20	12	300	3600	2999	601	14	14		300	0,8	0,8	0,00	1,00	7,00		
27	Classroom	8	15	7	200	1400	1398	2	9	9		300	0,8	0,8	0,25	0,90	2,00		
28	University Auditorium	8	18	10	150	1500	1409	91	12	12		500	0,8	0,8	0,25	0,70	0,75		
29	Bedroom	0	24	24	365	8760	4407	4353	24	24		300	0,8	0,8	0,00	0,50			
30	Hotel Room	21	8	11	365	4015	755	3260	24	24		200	0,8	0,8	0,25	0,30			
31	Canteen	8	15	7	250	1750	1748	2	9	9		200	0,8	0,8	0,00	1,00			
32	Restaurant	10	0	14	300	4200	2404	1796	16	16		200	0,8	0,8	0,00	1,00	1,50		
33	Kitchen Non-Residential	10	23	13	300	3900	2404	1496	15	15		500	0,8	0,8	0,00	1,00			
34	Kitchen, Storage, Preparation	7	23	16	300	3900	2404	1496	15	15		300	0,8	0,8	0,50	1,00			
35	WC, Sanitary	7	18	11	250	2750	2543	207	13	13		200	0,8	0,8	0,90	1,00			
36	Other Habitable Rooms	7	18	11	250	2750	2543	207	13	13		300	0,8	0,8	0,50	1,00			
37	Secondary Areas	7	18	11	250	2750	2543	207	13	13		100	0,8	0,8	0,90	1,00			
38	Circulation Area	7	18	11	250	2750	2543	207	13	13		100	0,0	0,0	0,80	1,00			
39	Storage, Services	7	18	11	250	2750	2543	207	13	13		100	0,8	0,8	0,98	1,00			
40	Server Room	0	24	24	365	8760	4407	4353	24	24		500	0,8	0,8	0,50	0,50			
41	Workshop	7	16	9	250	2250	2192	58	11	11		500	0,8	0,8	0,00	1,00			
42	Theatre Auditorium	19	23	4	250	1001	55	946	6	6		200	0,8	0,8	0,00	1,00			
43	Theatre Foyer	19	23	4	250	1001	55	946	6	6		300	0,8	0,8	0,50	1,00			
44	Theatre Stage	13	23	10	250	2500	1253	1247	12	12		1000	0,8	0,8	0,00	0,60			
45	Fair, Congress	13	18	5	150	1350	1260	90	11	11		300	0,8	0,8	0,50	1,00			
46	Exhibition	10	18	8	250	2001	1850	151	24	24		200	0,8	0,8	0,00	1,00			
47	Library Reading Room	8	20	12	300	3600	2999	601	14	14		500	0,8	0,8	0,00	1,00			
48	Open Access Library	8	20	12	300	3600	2999	601	14	14		200	0,8	0,8	0,00	1,00			
49	Library Repository	8	20	12	300	3600	2999	601	14	14		100	0,8	0,8	0,90	1,00			
50	Gymnasium	8	23	15	300	4500	3002	1498	17	17		300	0,8	0,8	0,30	1,00			
51	Parking Garage	7	18	11	250	2750	2543	207	0	0		75	0,0	0,0	0,95	1,00			
52	Public Parking Garage	9	0	15	365	5475	3290	2185	0	0		75	0,0	0,0	0,80	1,00			

ELECTRICITY DEMAND Non-Residential Use

Building: Primary School 8 "Sveti Sveti Kiril I Metodii" - Section B														
Treated Floor Area A _{trk} :		4630,4	m²		Window Properties (from Windows worksheet):									
Auxiliary Electricity Demand:		50946,5	kWh/a											
Primary Energy factors:														
Electricity:		2,6	kWh/kWh											
Natural gas:		1,1	kWh/kWh											
Energy Carrier for DHW:			kWh/kWh											
Solar fraction of DHW		15%												
Marginal Performance Ratio DHW:														

Lighting / non-residential	Percentage of treated floor area	Room Category	Room Category	Nominal Illuminance Level	Facade with Windows			
					Deviation from North	Orientation	Light Transmission Glazing	Existing window
Room / Zone				Lux	Degrees		-	[x]

Room Geometry: Input of a Typical Room or Room by Room					Input Warning	Daylight Utilisation	User Data: Installed Lighting Power	Installed Lighting Power (Standard)	Lighting Control	With motion?	Lighting Control	Utilisation Hours per Year [h/a]	User Determined: Lighting Full Load Hours	Full Load Hours of Lighting	Electricity Demand (kWh/a)	Spec. Electricity Demand (kWh/(m²a))	Primary Energy Demand (kWh/a)
Room Depth	Room Width	Room Height	Lintel Height	Window Width													
m	m	m	m	m								h/a	h/a	h/a	kWh/a	kWh/(m²a)	kWh/a

Area total is larger than 100%!															9														
Corridors	11%	2	Corridors	100	0	North	51%	x	2,7	45,0	3,3	2,3	35,3	medium	5	4,6		Manual	Without motion	1890		960,0	2249,3	4,4	5848,1				
Classrooms	25%	6	Classroom	300	180	South	51%	x	6,0	9,0	3,3	3,0	7,1	none	8	8,0		Manual	Without motion	1890		1170,0	10835,2	9,4	28171,4				
Lobbies	7%	1	Lobbies	200	0	North	51%	x	5,8	8,8	3,3	3,0	4,7	low	7	7,2		Manual	Without motion	1890		1120,0	2613,8	8,1	6795,8				
Stairs	2%	7	Stairs	100	0	North	51%	x	4,2	6,0	3,3	2,5	1,0	none	5	4,6		Manual	Without motion	1890		1280,0	545,3	5,9	1417,7				
Storages	5%	39	Storage, Services	100	0	North	51%		3,0	5,0	3,3	2,5		none	14	13,8		Manual	Without motion	2750	800	800,0	2556,0	11,0	6645,6				
Offices	2%	5	Teacher offices	300	180	South	51%	x	6,1	4,4	3,3	3,0	2,0	none	8	8,0		Manual	Without motion	1890		1008,0	746,8	8,1	1941,7				
Offices	1%	5	Teacher offices	300	0	North	51%	x	6,1	4,4	3,3	3,0	2,0	none	8	8,0		Manual	Without motion	1890		1043,0	386,4	8,3	1004,5				
Kitchen	2%	8	Kitchen	100	180	South	51%	x	5,7	8,9	3,3	2,3	6,5	none	14	13,8		Manual	Without motion	990		243,7	311,4	3,4	809,7				
Kitchen extra	1%	8	Kitchen	100	0	North	51%	x	2,5	7,6	3,3	2,3	2,8	low	14	13,8		Manual	Without motion	990		220,0	140,6	3,0	365,5				
Canteen S	4%	9	Canteen	100	180	South	51%	x	4,3	21,0	3,3	2,3	15,1	none	14	13,8		Manual	Without motion	990		216,0	552,1	3,0	1435,4				
Canteen N	2%	9	Canteen	100	0	North	51%	x	4,3	21,0	3,3	2,3	15,1	low	14	13,8		Manual	Without motion	990		220,0	281,2	3,0	731,0				
Corridor no windows	1%	2	Corridors	100	0	North	51%		2,7	12,2	3,3	2,3		none	14	13,8		Manual	Without motion	1890		1410,0	901,0	19,5	2342,6				
Classroom west	10%	6	Classroom	300	270	West	51%	x	5,8	8,9	3,3	2,7	7,1	none	8	8,0		Manual	Without motion	1890		1386,6	5136,4	11,1	13354,5				
Classroom east	9%	6	Classroom	300	90	East	51%	x	5,8	8,9	3,3	2,7	7,1	none	8	8,0		Manual	Without motion	1890		1307,6	4359,5	10,5	11334,8				
Corridors	8%	2	Corridors	100	180	South	51%	x	26,7	3,3	3,3	3,0	2,1	none	5	4,6		Manual	Without motion	1890		1352,0	2303,8	6,2	5989,8				
WCs	1%	10	WC, Sanitary	200	270	West	51%	x	4,4	2,8	3,3	3,0	2,1	none	22	21,6		Manual	Without motion	1890		1070,0	1070,2	23,1	2782,5				
WCs	1%	10	WC, Sanitary	200	270	West	51%		5,0	4,0	3,3	3,0		none	22	21,6		Manual	Without motion	1890		1350,0	1350,2	29,2	3510,6				
Gymnasium	1%	3	Computer room	300	90	East	51%	x	5,8	11,9	3,3	1,6	9,4	none	8	8,0		Manual	Without motion	1890		635,7	235,5	5,1	612,3				
Mechanical room	2%	39	Storage, Services	100	180	South	51%		5,0	4,0	3,3	3,0		none	14	13,8		Manual	Without motion	2750		1930,0	2466,5	26,6	6413,0				
Others without windows	0%	37	Secondary Areas	100	90	East	51%		5,0	4,0	3,3	3,0		none	14	13,8		Manual	Without motion	2750		0,0	0,0	0,0	0,0				
Entrances	0%	1	Lobbies	200	270	West	51%	x	2,2	6,2	3,3	3,0	5,2	medium	7	7,2		Manual	Without motion	1890		0,0	0,0	0,0	0,0				
Classroom east level -	2%	6	Classroom	300	90	East	51%	x	5,8	19,1	3,3	1,4	6,8	none	8	8,0		Manual	Without motion	1890		1527,3	1131,5	12,2	2941,9				
Corridors	1%	2	Corridors	100	0	North	51%	x	2,8	14,7	3,3	2,3	8,8	low	5	4,6		Manual	Without motion	1890		1020,0	217,3	4,7	564,9				
WC	0%	10	WC, Sanitary	200	260	West	51%	x	1,0	1,3	3,3	2,0	0,6	low	22	21,6		Manual	Without motion	1890		0,0	0,0	0,0	0,0				
WC	0%	10	WC, Sanitary	200	0	North	51%	x	2,8	1,7	3,3	2,3	0,9	low	22	21,6		Manual	Without motion	1890		0,0	0,0	0,0	0,0				
Computer room	1%	3	Computer room	300	180	South	51%	x	5,9	8,7	3,3	3,2	8,0	low	8	8,0		Manual	Without motion	1890		496,0	183,7	4,0	477,7				
Bookstore	0%	4	Bookstore	300	180	South	51%	x	5,9	2,7	3,3	3,2	2,7	low	8	8,0		Manual	Without motion	1620		0,0	0,0	0,0	0,0				
Teacher offices section	0%	5	Teacher offices	300	180	South	51%	x	5,9	2,7	3,3	2,6	1,8	none	8	8,0		Manual	Without motion	1890		0,0	0,0	0,0	0,0				

Canteen	1%	6	Classroom	300	180	South	51%	x
Teacher offices section	0%	5	Teacher offices	300	180	South	51%	x
Teacher offices section	1%	5	Teacher offices	300	180	South	51%	x
							51%	

5,9	8,7	3,3	3,2	8,0		low	8	8,0			Manual	Without motion	1890		1134,0	420,1	9,1	1092,2
5,9	2,7	3,3	2,6	1,8		none	8	8,0			Manual	Without motion	1890		0,0	0,0	0,0	0,0
5,9	2,7	3,3	2,6	1,8		none	8	8,0			Manual	Without motion	1890		978,1	362,3	7,8	942,0
						none		0,0			Manual	Without motion					0,0	

Office Equipment	Room Category	Room Category	In the thermal envelope? (I/O)	Existing/Planned? (I/O)	Quantity	Power Rating (W)	Utilisation Hours per Year (h/a)	Relative absenteeism	Duration of Utilisation in Energy Saving Mode (h/a)	Useful Energy (kWh/a)		Electricity Demand (kWh/a)	Primary Energy Demand (kWh/a)			
PC 1	3	Computer room	1	1	20	55	756	0,3		582		582,1	1514			
PC in Energy Saving Mode			1		20	2,0	756	0,3		9		9,1	24			
Monitor 1	3	Computer room	1	1	20	20	756	0,3		212		211,7	550			
Monitor in Energy Saving Mode			1		20	1,5	756	0,3		7		6,8	18			
PC 2	5	Teacher offices	1	1	4	55	1323	0,3		204		203,7	530			
PC in Energy Saving Mode			1		4	2,0	1323	0,3		3		3,2	8			
Monitor 2	5	Teacher offices	1	1	4	20	1323	0,3		74		74,1	193			
Monitor in Energy Saving Mode			1		4	1,5	1323	0,3		2		2,4	6			
Copier	5	Teacher offices	1	1	1	400	1890		1701	76		75,6	197			
Copier in Energy Saving Mode			1		1	30	1701			51		51,0	133			
Printer	5	Teacher offices	1	1	1	300	1890		1701	57		56,7	147			
Printer in Energy Saving Mode			1		1	2	1701			3		3,4	9			
Server	5	Teacher offices	1	1	0	100	1890			0		0,0	0			
Server in Energy Saving Mode			1		0	2,0	8760		1890	0		0,0	0			
Telephone System			1	1	1	94	8760			823		823,4	2141			
Hand Dryer (WC)			1	1	4	2000	20			160		160,0	416			
TV + DVD			1	1	1	440	250			110		110,0	286			
TV + DVD in Ener. Saving Mode			1	1	1	44	250			11		11,0	29			
										0		0,0	0			
										0		0,0	0			
Kitchen / Aux. Electricity	Room Category	Predominant Utilisation Pattern of Building	In the thermal envelope? (I/O)	Existing/Planned? (I/O)	Utilisation Days per Year (d/a)	Number of Meals per Utilisation Day	Norm. Consumption	Useful Energy (kWh/a)	Non-Electric Fraction	Electric Fraction	Additional demand	Marginal Performance Ratio	Solar Fraction	Other Primary Energy Demand (kWh/a)	Electricity Demand (kWh/a)	Primary Energy Demand (kWh/a)
Cooking	8	Kitchen	1	1	180	100	0,25	4500		100%				4500	0,0	0
Gas							0,10	1800		45%	0,30	1,20	0,15	1080	990,0	2574
Dishwashing			1	1	180	100	0,10	1800		100%				0	598,6	1556
DHW connection							1,64	599		100%				0	0,0	0
Refrigerating			1	1	365		0,0	0		100%				50,0	0,0	130
Exrta cooking energy use - old cooking equipment			1	1	180		0,25	0		100%				0,0	0,0	0
Coffee machine			1	1	200			50		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
								0		100%				0,0	0,0	0
Total Auxiliary Electricity								50946						50946,5		132461
Total								101635	kWh			1053		5580	96325	255395
Specific Demand												0,2		1,2	21	55

AUXILIARY ELECTRICITY

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B**

Treated Floor Area	4639	m ²	Operation Vent. System Winter		4,66	kh/a	Primary Energy factor - Electricity		2,69	kWh/kWh
Heating period	194	d	Operation Vent. System Summer		4,10	kh/a	Annual Space Heating Demand		17	kWh/(m ² a)
Air Volume	11576	m ³	Air Change Rate		0,18	h ⁻¹	Boiler Rated Power		490	kW
Dwelling Units	1	HH	Defrosting HX from		4,0	°C	DHW System Heating Demand		59495	kWh/a
Enclosed Volume	15290	m ³					Design Flow Temperature		55	°C

Column Nr.	1	2	3	4	5	6	7	8	9	10	11	12		
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Period of Operation	Reference Size	Electricity Demand (kWh/a)	Available as Interior Heat	Used During Time Period (kh/a)	Internal heat source Winter (W)	Internal heat source Summer (W)	Primary Energy Demand (kWh/a)		
Ventilation System														
Winter Ventilation	1		0,40	Wh/m ³	*	0,18	h ⁻¹	*	4,7	kh/a	*	11576	m ³	
Defroster HX	1	1	11031	W	*	1,00		*	0,8	kh/a	*	1		
Summer Ventilation	1	1,00	0,37	Wh/m ³	*	1,79	h ⁻¹	*	4,1	kh/a	*	11576	m ³	
							=	3776	considered in heat recovery efficiency			9818		
							=	8426	*	1,0	/	4,66	=	1810
							=	31076	*	1,0	/	4,10	=	7571
							Internal heat sources + Additional summer ventilation					1030	80797	
												10989		
Heating System														
Enter the Rated Power of the pump				W	Controlled/UnControlled (1/0)									
Circulation Pump	1	1	461	W	*	1,0		*	4,7	kh/a	*	1		
Boiler Electricity Consumption at 30% Load				W										
Aux. Energy - Heat. Boiler	1	0	266	W	*	1,00		*	0,65	kh/a	*	1		
Aux. Energy - Wood fired/pellet boiler	0	0	Data entries in Boiler worksheet. Auxiliary energy demand including possible drinking water prod.											
							=	2146	*	1,0	/	4,66	=	461
							=	172	*	1,0	/	4,66	=	0
							=	0	*	1,0	/	4,66	=	0
DHW system														
Enter average power consumption of pump				W										
Circulation Pump	1	1	66	W	*	1,00		*	8,2	kh/a	*	1		
Enter the Rated Power of the pump				W										
Storage Load Pump DHW			333	W	*	1,00		*	0,1	kh/a	*	1		
Boiler Electricity Consumption at 100% Load				W										
DHW Boiler Aux. Energy	1	0	798	W	*	1,00		*	0,1	kh/a	*	1		
Enter the Rated Power of the Solar DHW pump				W										
Solar Aux Electricity	1		275	W	*	1,00		*	1,8	kh/a	*	1		
Misc. Aux. Electricity														
Misc. Aux. Electricity				kWh/a	*	1,00		*	1,0		*	1		
							=	0	*	1,0	/	8,76	=	0
							=	481	*	0,5	/	8,76	=	0
							=	50946				2304	7604	132461
Total														
Specific Demand							kWh/(m ² a) divided by treated floor area:							
							11,0						28,6	

INTERNAL HEAT GAINS

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" Calculation in worksheet 'IHG non-res'

Utilisation Pattern:

School

2,80

W/m²

Type of Values Used:

Standard

12,18

W/m² in summer

No data input necessary

1,34

W/m²

[Go to utilisation pattern selection](#)

Calculation	Persons	680,0	P	Heating Demand	17	kWh/(m²a)				
Internal Heat Household	Living Area	4630	m²	Heating period	194	d/a				
Column Nr.	1	2	3	4	5	6	7	8	9	10
Application	Existing (1/0), or number of people	In the Thermal Envelope (1/0)	Norm Consumption	Utilization Factor	Frequency	Useful Energy (kWh/a)	Included in Electricity Balance?	Availability	Used During Time Period (kh/a)	Internal heat source Winter (W)
Dishwashing	1	1	1,1 kWh/Use	1,00	65 /(P*a)	48620 *		0,30 /	8,76 =	1665
Clothes Washing	1	1	1,1 kWh/Use	1,00	57 /(P*a)	42636 *		0,30 /	8,76 =	1460
Clothes drying with:	1	1	3,5 kWh/Use	0,88	57 /(P*a)	118703 *		0,70 /	8,76 =	9485
Condensation Dryer		1	0,0 kWh/Use			0		0,80 /		
Energy consumed by evaporation	0	1	-3,1 kWh/Use	0,60	57 /(P*a)	0 *(1-0) *		0,00 /	8,76 =	0
Refrigerating	1	1	0,8 kWh/d	1,00	365 d/a	285 *		1,00 /	8,76 =	33
Freezing	1	0	0,9 kWh/d	0,90	365 d/a	289 *		1,00 /	8,76 =	0
or combination	0	1	1,0 kWh/d	1,00	365 d/a	0 *		1,00 /	8,76 =	0
Cooking	1	1	0,3 kWh/Use	1,00	500 /(P*a)	85000 *		0,50 /	8,76 =	4852
Lighting	1	1	60,0 W	1,00	2,9 kh/(P*a)	118320 *		1,00 /	8,76 =	13507
Consumer Electronics	1	1	80,0 W	1,00	0,55 kh/(P*a)	29920 *		1,00 /	8,76 =	3416
Household Appliances/Other	1	1	50,0 kWh	1,00	1,0 /(P*a)	34000 *		1,00 /	8,76 =	3881
Auxiliary Appliances (cf. Aux Electricity Sheet)										2304
Other Applications (cf. Electricity Sheet)	0	0,0				0 *		0 /	8,76 =	0
Persons	680	1	80,0 W/P	1,00	8,76 kh/a	476544 *		0,55 /	8,76 =	29920
Cold Water	680	1	-4,1 W/P	1,00	8,76 kh/a					-2821
DHW - circulation	1	1	92,2 W	1,00	8,76 kh/a	807 *		1,00 /	8,76 =	92
DHW - individual pipes	1	1	162,0 W	1,00	8,76 kh/a	1419 *		1,00 /	8,76 =	162
DHW - storage	1	1	139,3 W	1,00	8,76 kh/a	1220 *		1,00 /	8,76 =	139
Evaporation	680	1	-25,0 W/P	1,00	8,76 kh/a	##### *		1,00 /	8,76 =	-17000
Total									W	50701
Specific Demand									W/m²	10,95
Heat Available From Internal Sources							194 d/a		kWh/(m²a)	51,0

EnerPHit planning:

INTERNAL HEAT GAINS non-residential Use

Building: Primary School 8 "Sveti Sveti Kiril I Metodi"

Utilisation Pattern: School

2,80 W/m²

Type of Values Used: Standard

No data input necessary

Calculation		Persons: 680,0 P		Heating period: 193,97 d/a		Room Temperature: 20 °C							
Internal Heat		Treated floor area: 4630,41 m ²		Internal Heat Gains Aux. Electricity: 2383,8 W									
Column Nr.	Select	Utilisation Pattern	Select	Activity of Persons	Planning with the number of persons or via floor area of utilisation zone (planning via area only if the occupancy is available for this utilisation pattern). Pers./Area (1 / 0)	Number of Occupants	Floor Area of Utilisation Zone (m ²)	Average Occupancy (Persons / m ²)	Heat emitted per person (W)	Utilisation Hours per Year [h/a]	Relative Presence	Used in Time Span (h/a)	Average Heat Emitted by Persons (W)
Persons A	6	Classroom	1	<= 10 yr., sitting	1 Planning with occupancy	{ 290 }*	{ }	* 0,33333333	* 60	* 1890	* 0,75	/ 8760	= 2816
Persons B	6	Classroom	2	> 10 yr., sitting	1 Planning with occupancy	{ 290 }*	{ }	* 0,33333333	* 80	* 1890	* 0,75	/ 8760	= 3754
Persons C	5	Teacher offices	2	> 10 yr., sitting	1 Planning with occupancy	{ 45 }*	{ }	* 0,1	* 80	* 1890	* 0,70	/ 8760	= 544
Persons D	3	Computer room	2	> 10 yr., sitting	1 Planning with occupancy	{ 20 }*	{ }	* 0,5	* 80	* 1890	* 0,70	/ 8760	= 242
Persons E	9	Canteen	2	> 10 yr., sitting	1 Planning with occupancy	{ 30 }*	{ }	* No standard value	* 80	* 990	* 0,20	/ 8760	= 54
Persons F	8	Kitchen	1	<= 10 yr., sitting	1 Planning with occupancy	{ 5 }*	{ }	* No standard value	* 60	* 990	* 0,20	/ 8760	= 7
Persons G				Invalid data input	1 Enter occupancy or floor area	{ }	{ }	* No standard value	* 0	* 0	* 1,00	/ 8760	= 0
Evaporation (person specific)						{ 573 }*	{ }			* 1890	* 0,75	/ 8760	= 0
Lighting / Equipment / Aux. Electricity								Useful Energy [kWh/a]			Availability	Used in Time Period (kh/a)	Average Heat Release
Lighting								41356			* 1,00	/ 8,76	= 4721
Office Applications (Within Therm. Envelope)								2384			* 1,00	/ 8,76	= 272
Cooking (Within Therm. Envelope)								4500			* 0,50	/ 8,76	= 257
Dishwashing (Within Therm. Envelope)								1800			* 0,30	/ 8,76	= 62
Cooling (Within Therm. Envelope)								599			* 1,00	/ 8,76	= 68
Other (Within Therm. Envelope)								50			* 1,00	/ 8,76	= 6
Auxiliary Appliances (See Aux Electricity Worksheet)													= 2304
Heat loss due to cold water (calculation from column AJ)	on/off (1 / 0)	Predominant Utilisation Pattern of Building (Data transferred from Electricity non-res worksheet, input kitchen)	Number of WCs (user data)	Amount of WCs: Standard values for schools are used (X)	Number of WCs (calculation value)	ΔT: Cold Water Temp. - Room Temp. [K]	Occupied Days per Year [d/a]	Loss daytime [W]	Loss Nighttime [W]	Availability	Used in Period (d/a)	Average Power Cold Water	
Cold Water Due to Flushing WC		8 Kitchen			0	-8	180	* (-40 + -13)	* 1,00	/ 365	= 0		
Total											W	15106	
Specific Demand											W/m ²	3,3	
Heat Available From Internal Sources							194 d/a				kWh/(m ² a)	15	

Building: Primary School 8 "Sveti Sveti Kiril i Metodii" - Section B		Building type: School		
Treated Floor Area A _{FA} : 4639 m ²		Space Heating Demand incl. Distribution: 17 kWh/(m ² a)		
Useful cooling demand incl. dehumidification: 0 kWh/(m ² a)				
		Final Energy kWh/(m ² a)	Primary Energy kWh/(m ² a)	Emissions CO ₂ -Equivalent kg/(m ² a)
Electricity Demand (without Heat Pump)				
Covered Fraction of Space Heating Demand	(Project)	0%	PE Value	CO ₂ -Emissions Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	0%	kWh/kWh	g/kWh
Direct Electric Heating	Q _{H,de}	0,0	0,0	0,0
Hot water, direct electric (without DHW wash&dish)	Q _{DHW,de} (DHW+Distribution, SolarDHW)	0,0	0,0	0,0
Electric Post heating DHW Wash&Dish	(Electricity, SolarDHW)	0,0	0,0	0,0
Electricity demand lighting/auxiliary tools/kitchen	Q _{EH} (Electricity worksheet)	9,8	25,5	6,7
Electricity Demand - Auxiliary Electricity		11,0	28,6	7,5
Total electricity demand (without heat pump)		20,8	54,1	14,1
Heat pump				
Covered Fraction of Space Heating Demand	(Project)	0%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	0%	kWh/kWh	g/kWh
Energy Carrier - Supplementary Heating		Electricity	2,6	680
Annual coefficient of performance of heat pump 1 (heating / heating&DHW)	SPF _{H+1} (HP worksheet)			
Annual coefficient of performance of heat pump 2 (DHW)	SPF _{H+1} (HP worksheet)			
Heat generation efficiency (excl. DHW wash&dish)	(HP worksheet)			
Heat generation efficiency (incl. DHW wash&dish)	(HP worksheet)			
Electricity Demand Heat Pump (without DHW Wash&Dish)	Q _{HP} (HP worksheet)	0,0	0,0	0,0
Non-Electric Demand, DHW Wash&Dish		0,0	0,0	0,0
Total electricity demand heat pump	(HP worksheet)	0,0	0,0	0,0
Compact Heat Pump Unit				
Covered fraction of space heating demand	(Project)	0%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	0%	kWh/kWh	g/kWh
Energy Carrier - Supplementary Heating		Electricity	2,6	680
COP Heat Pump Heating	SPF _{H+1} (Compact worksheet)	0,0		
COP Heat Pump DHW	SPF _{H+1} (Compact worksheet)	0,0		
Heat generation efficiency (excl. DHW wash&dish)	(Compact worksheet)			
Heat generation efficiency (incl. DHW wash&dish)	(Compact worksheet)			
Electricity Demand Heat Pump (without DHW Wash&Dish)	Q _{HP} (Compact worksheet)	0,0	0,0	0,0
Non-Electric Demand, DHW Wash&Dish		0,0	0,0	0,0
Total Compact Unit	(Compact worksheet)	0,0	0,0	0,0
Boiler				
Covered fraction of space heating demand	(Project)	100%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	100%	kWh/kWh	g/kWh
Boiler Type	(Boiler worksheet)	Low Temperature Boi-ler Gas		
Performance Ratio of Heat Generator	(Boiler worksheet)	114%		
Annual Energy Demand (without DHW Wash&Dish)	(Boiler worksheet)	31,3	34,5	7,8
Non-Electric Demand, DHW Wash&Dish	(Electricity worksheet)	0,2	0,2	0,1
Total heating oil/gas/wood		31,5	34,7	7,9
District Heat				
Covered fraction of space heating demand	(Project)	0%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	0%	kWh/kWh	g/kWh
Heat source	(District heating worksheet)			
Performance Ratio of Heat Generator	(District heating worksheet)	0%		
Heating Demand District Heat (without DHW Wash&Dish)	(District heating worksheet)	0,0	0,0	0,0
Non-Electric Demand, DHW Wash&Dish	(Electricity worksheet)	0,0	0,0	0,0
Total district heat		0,0	0,0	0,0
Other				
Covered fraction of space heating demand	(Project)	0%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of DHW Demand	(Project)	0%	kWh/kWh	g/kWh
Heat source	(Project)	Wood		
Performance Ratio of Heat Generator	(Project)	0%		
Annual Energy Demand, Space Heating		0,0	0,0	0,0
Annual Energy Demand, DHW (without DHW Wash&Dish)		0,0	0,0	0,0
Non-Electric Demand, DHW Wash&Dish	(Electricity worksheet)	0,0	0,0	0,0
Non-Electric Demand Cooking/Drying (Gas)	(Electricity worksheet)	1,0	1,1	0,1
Total - Other		1,0	1,1	0,1
Cooling with Electric Heat Pump				
Covered Fraction of Cooling Demand	(Project)	100%	PE Value	CO ₂ -Emission Factor (CO ₂ -Equivalent)
Heat source		Electricity	kWh/kWh	g/kWh
Seasonal energy efficiency ratio cooling			2,6	680
Energy Demand Space Cooling		0,0	0,0	0,0
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances		53,3	89,9	22,1
Total PE Value	89,9	kWh/(m ² a)		
Total emissions CO₂-Equivalent	22,1	kg/(m ² a)		(Yes/No)
Primary Energy Requirement		123	kWh/(m ² a)	yes
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)		42,3	63,1	15,3
Specific PE Demand - Mechanical System	63,1	kWh/(m ² a)		
Total emissions CO₂-Equivalent	15,3	kg/(m ² a)		
Solar electricity				
Planned Annual Electricity Generation	(Worksheet PV)		PE-Value (Generation)	CO ₂ -Emission Factor
Specific Demand			kWh/kWh	g/kWh
PE Value: conservation by solar electricity			kWh/(m ² a)	
Saved CO₂ emissions through solar electricity			kg/(m ² a)	

HEAT PUMP

Building: Primary School 8 "Sveti Sveti Kiril I Metodi"		Building type: School	
Climate: Велико Търнов		Treated Floor Area A_{TFA} :	4630 m ²

Inputs	Covered fraction of space heating demand	(PE Value worksheet)	0%	
	Space Heat Demand + Distribution Losses	$Q_{H+Q_{HL}}$ (DHW+Distribution)	80824	kWh/a
	Solar fraction for space heat	$\eta_{Solar, H}$ (SolarDHW worksheet)	4%	
	Effective Annual Heat Demand	$Q_{H,WI}=Q_{H+Q_{HL}}(1-\eta_{Solar, H})$	0	kWh/a
	Covered Fraction of DHW Demand	(PE Value worksheet)	0%	
	Total heat demand of DHW system	Q_{DHW} (DHW+Distribution)	57698	kWh/a
	Solar fraction for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)	0%	
	Effective DHW demand	$Q_{DHW,WI}=Q_{DHW}(1-\eta_{Solar, DHW})$	0	kWh/a
	Number of heat pumps in the system		1	
	Functionality		Heating & DHW	
Heating	Selection of HP: None	Heat source:		
	Selection of distribution system		Supply air heating	
	Design distribution temperature	θ_{design} (DHW+Distribution)	55, 00	°C
	Nominal Power of distribution system	P_{nom}	300, 00	kW
	Distribution system (fulfilled from expert users only)			
	Nominal Power of distribution system	P_{nom}	300, 00	kW
	Radiator exponent	n	1, 30	
	Heating storage		No	
	Specific heat losses storage	$U \cdot A_{storage}$		W/K
	Storage location in thermal envelope	Inside or outside of the thermal envelope	Inside	
Entries in relation to the domestic hot water system	Room temperature (Storage location: outside of thermal envelope)	(DHW+Distribution)	15, 00	°C
	Sink temperature of heat pump for heating	θ_{sink}	55, 00	°C
	Selection of HP: None	Heat source:		
	DHW temperature	(DHW+Distribution)	60, 00	°C
	DHW storage location	inside or outside of the thermal envelope	Outside	
	Specific heat losses storage	$U \cdot A_{storage}$	2, 5	W/K
	Room temperature (Storage location: outside of thermal envelope)	(DHW+Distribution)	10, 00	°C
	Type of backup heater		Electr. immersion heater	
	$\Delta\theta$ of Electric flow type heater		5, 0	K
	In case of one heat pump with functionality: Heating & DHW			
Control	Same heat pump's sink temperature for Heating and for DHW		No	
	Heat Pump Priority	(Manufacturer, Techn. Data)	DHW priority	
	Control strategy		On / off	
Heating	Depth (horizontal / vertical) ground heat exchanger	z	50, 0	m
	Power of pump for ground heat exchanger	P_{pump}	0, 05	kW

EnerPHit planning:

HEAT PUMP

0

Heating		θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Heat pump:					
Source:					
	Test Point 1				
	Test Point 2				
	Test Point 3				
	Test Point 4				
	Test Point 5				
	Test Point 6				
	Test Point 7				
	Test Point 8				
	Test Point 9				
	Test Point 10				
	Test Point 11				
	Test Point 12				
	Test Point 13				
	Test Point 14				
	Test Point 15				
Temperature difference in sink		$\Delta\theta_{\text{Sink}}$			K

DHW		θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Heat pump:					
Source:					
	Test Point 1				
	Test Point 2				
	Test Point 3				
	Test Point 4				
	Test Point 5				
	Test Point 6				
	Test Point 7				
	Test Point 8				
	Test Point 9				
	Test Point 10				
	Test Point 11				
	Test Point 12				
	Test Point 13				
	Test Point 14				
	Test Point 15				
Temperature difference in sink		$\Delta\theta_{\text{Sink}}$			K

Electrical energy consumption of pump (groundwater / ground)
 Energy by Direct Electricity
 Space heat supplied by HP
 Winter DHW supplied by HP
 Summer DHW supplied by HP
 Space heating supplied by HP without storage losses
 Winter DHW supplied by HP without storage losses
 Summer DHW supplied by HP without storage losses
 Electrical consumption of HP

Q_{pump}
 $Q_{\text{E,dlr}}$
 $Q_{\text{HP,Heating}}$
 $Q_{\text{HP,DHW,Winter}}$
 $Q_{\text{HP,DHW,Summer}}$
 $Q_{\text{HP,Heating}}$
 $Q_{\text{HP,DHW,Winter}}$
 $Q_{\text{HP,DHW,Summer}}$
 $Q_{\text{el,HP}}$

0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a
0	kWh/a

Seasonal performance factor of Heat Pump
 Seasonal Performance factor of System
 Heat generation efficiency DHW & heating

$\text{SPF}_{\text{H},1}$
 $\text{SPF}_{\text{H},3}$

Final electrical energy demand heat generation
 Annual primary energy demand

 Q_{final} Annual CO₂-Equivalent Emissions

1. HP: Heating or heating & DHW

kWh/a
kg/a

2. HP: Domestic hot water

kWh/(m ² a)
kg/(m ² a)

EnerPHit planning:

HP Ground (Ground probes / Ground collectors)

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Section B** Building type: **School**
 Climate: **Велико Търнов** Treated Floor Area A_{TFA} : **4630** m²

Ground probes

Probe field configuration
 Length of probe (HP worksheet)

Probes spacing/distance
 Depth ($z=H/2$)

Type of probe

Borehole radius
 Inner radius of pipe
 Exterior pipe radius
 Distance between pipes
 Inner radius of pipe casing (only coaxial)
 Exterior radius casing pipe (only coaxial)
 Thermal conductivity of pipe
 Thermal conductivity of back fill
 Probe time constant
 Internal borehole resistance
 Borehole resistance

Ground

Soil type
 Density of the ground
 Thermal capacity of ground
 Thermal conductivity of ground
 Soil temperature conductivity
 Ground temperature gradient

Brine

Brine (characteristics at 2 °C)
 Density of the brine
 dynamic viscosity of the brine
 Heat capacity brine
 Thermal conductivity of brine
 Brine - mass flow

Operation type

Waste heat of active cooling to ground probe? Please check, if applicable.

Heat pump operation duration
 Specific heat extraction rate as an annual average

A	Individual probe	
H	50	m
B		m
z	25	m
A	Double-U	
R _b		m
R _i		m
R _a		m
BU		m
R ₂		m
R _{a2}		m
λ _R		W/(mK)
λ _F		W/(mK)
t _p	#DIV/0!	d
R _a		Km/W
R _b		Km/W

J	0	
ρ_E	0	kg/m ³
c_{pE}	0	J/(kgK)
λ_E	0,0	W/(mK)
a_E	#DIV/0!	m/s ²
ΔT_G	0,022	K/m

E	0	
ρ_S	0	kg/m ³
η_S	0	kg/(ms)
cp_S	0	J/(kgK)
λ_S	0	W/(mK)
m_S		kg/s

		h/a
q _{ex}		W/m
H/R _b		W/K

Ground collectors

Inner radius of pipe	r _i	0,013	m
Exterior pipe radius	r _a	0,016	m
Thermal conductivity of pipe	λ _r	0,420	W/(mK)
Pipe depth	Z _{pipe}	50	m
Ground water depth	Z _{gw}		m
Pipe spacing	D	0,4	m
Base area		80	m ²
Pipe outer surface		20,1	m ²
Pipe length	L	200,0	m

Brine

Brine (characteristics at 2 °C)	E	0
Density of the brine	ρ_S	0 kg/m ³
dynamic viscosity of the brine	η_S	0 kg/(m·s)
Heat capacity brine	cp_S	0 J/(kg·K)
Thermal conductivity of brine	λ_S	0 W/(m·K)
Brine - mass flow	m_S	0,5 kg/s

Specific heat extraction rate

q _{ex}		W/m ²
U * A		W/K

Climate

Period duration		365	d
Average ground surface temperature	T _{m0}	11,4	°C
Surface temperature amplitude	T1	11,4	°C
Phase shifting surface	t ₀₂	31	d

HP Ground (Ground probes / Ground collectors)

Ground characteristics		Thermal conductivity	Density	Heat capacity	Heat capacity	Temperature	Source
		[W/(mK)]	[kg/m³]	[J/(kg K)]	[MJ/(m³ K)]	[10-7 m²/s]	
A	Sand, 9% moisture	0,980	1440	1507	2,170	4,520	[Neiß 1977]
B	Sand, 13% moisture	1,500	1600	1800	2,880	5,210	[Neiß 1977]
C	Ground, coarse gravel	0,520	2000	1840	3,680	1,410	[VDI 1984]
D	Loam, 36% moisture	2,300	1650	2847	4,700	4,900	[Neiß 1977]
E	Clay	1,280	1500	880	1,320	9,700	[VDI 1984]
F	Clay / Silt	2,200	2550	882	2,250	9,780	[VDI 2000]
G	Slate	2,100	2700	870	2,350	8,940	[VDI 2000]
H	Silt	1,500	1920	2938	5,640	2,660	[ISO 13370]
I	Rock	3,500	2500	2500	6,250	5,600	[ISO 13370]
J							

Properties of the brine		Temperature	Density	Heat capacity	Thermal conductivity	Dynamic viscosity
		[°C]	[kg/m³]	[J/(kg K)]	[W/(mK)]	[kg/(ms)]
A	Ethylene glycol 25%	2	1052	3950	0,480	0,0052
B	Potassium carbonate	2	1265	2941	0,544	0,0031
C	Potassium formate	2	1226	3190	0,534	0,00237
D	Water	2	997	4190	0,590	0,001307
E						

Result ground probe calculation

Month Borehole Temperature
°C

1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Calculation based on measured values of the laboratory evaluation for component certification

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Set** Building type: **School**

Treated Floor Area A_{TFA} : **4630** m²

Covered fraction of space heating demand (PE Value worksheet) **0%**

Space Heating Demand + Distribution Losses $Q_{SH} + Q_{HL}$ (DHW+Distribution) **80824** kWh

Solar contribution for space heating $\eta_{Solar, H}$ (SolarDHW worksheet) **4%**

Effective Annual heating demand $Q_{H,WH} = Q_{SH} * (1 - \eta_{Solar, H})$ **0** kWh

Covered Fraction of DHW Demand (PE Value worksheet) **0%**

Total Heating Demand of DHW system Q_{DHW} (DHW+Distribution) **58352** kWh

Solar contribution for DHW $\eta_{Solar, DHW}$ (SolarDHW worksheet) **15%**

Effective DHW Demand $Q_{DHW,WH} = Q_{DHW} * (1 - \eta_{Solar, DHW})$ **0** kWh

Sort: AS LIST

Compact unit selection:

Measured Values from Laboratory Test

Ventilation

Effective heat recovery efficiency η_{eff} (Test stand) **0%**

Electric Efficiency (Test stand) **0%** Wh/m³

Heating

Ambient Air Temperature T_{amb} **15** °C

Measured Thermal Power Heat Pump Heating $P_{HP, Heating}$ **0** kW

Measured COP Heating $COP_{Heating}$ **0**

Domestic Hot Water

Ambient Air Temperature T_{amb} **15** °C

Measured Thermal Power DHW Storage Heating-Up $P_{DHW, Heating-Up}$ **0** kW

Measured Thermal Power DHW Storage Reload $P_{DHW, Reload}$ **0** kW

Measured COP DHW Storage Heating-Up $COP_{DHW, Heating-Up}$ **0**

Measured COP DHW Storage Reload $COP_{DHW, Reload}$ **0**

Standby (inputs required only if different from storage reload)

Ambient Air Temperature T_{amb} **15** °C

Measured Thermal Power Heat Pump Standby $P_{HP, Standby}$ **0** kW

Measured COP Standby $COP_{Standby}$ **0**

Specific heat loss storage incl. connections

Average Storage Temperature in Standby Mode $T_{DHW, Standby}$ (Test stand) **0%**

Heat pump priority

separate heat pumps: **0%** DHW Priority **0%** Heating priority: **0%**

Room temperature (°C) **20**

Av. Ambient Temp. Heating P. (°C) **5**

Av. Ground Temp (°C) **11**

Efficiency SHX Exhaust Air Mixing

Heat Recovery Efficiency SHX Exhaust Air Mixing (if applicable) η_{SHX} **0%**

Volume Flow Rate of Added Exhaust Air (if applicable)

Hydraulic frost protection V_{add} (Test stand) **0** m³/h

Heat supplied by direct electricity

Space heat supplied by HP $Q_{HP, Heating}$ **0** kWh/a

Winter DHW supplied by HP

Winter standby heat supplied by HP $Q_{HP, Standby, Winter}$ **0** kWh/a

Summer DHW supplied by HP

Summer standby heat supplied by HP $Q_{HP, Standby, Summer}$ **0** kWh/a

Performance Ratio of Heat Generator, DHW & Space Heating

Annual Coefficient of Performance

SPF_{H,3}

Final energy demand heat generation

Q_{final}

Annual primary energy demand

Annual CO₂-Equivalent Emissions

incl. DHW Connection for Washing Machines & Dishwashers

59405 kWh

15%

0 kWh

Building: **Primary School 8 "Sveti Sveti Kiril I Metodi" - Sectir**Building type: **School**Treated Floor Area A_{TFA} : **4630** m²

Covered fraction of space heating demand (PE Value worksheet)

100%Space Heating Demand + Distribution Losses $Q_{SH} + Q_{SHS}$ (DHW+Distribution)**89824** kWhSolar contribution for space heating $\eta_{Solar, H}$ (SolarDHW worksheet)**4%****Effective Annual heating demand** $Q_{H,W} = Q_{SH} * (1 - \eta_{Solar, H})$ **77549** kWhSpace Heating Demand without Distribution Losses Q_{SH} (Verification sheet)**80244** kWh

Covered Fraction of DHW Demand (PE Value worksheet)

100%Total Heating Demand of DHW system Q_{DHW} (DHW+Distribution)**59405** kWhSolar contribution for DHW $\eta_{Solar, DHW}$ (SolarDHW worksheet)**15%****Effective DHW Demand** $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$ **50785** kWh

Boiler Type (Project)

Low Temperature Boi-ler Gas

Additional selection only in the case of

Natural Gas

Primary Energy factor (Data worksheet)

1,1 kWh/kWhCO₂-Emissions Factor (CO₂-Equivalent)**250** g/kWhUseful heat provided Q_{Use} **128334** kWh/aMax. Heating Power Required for Heating the Building P_{BH} (Heating load worksheet)**59,97** kWLength of the Heating Period t_{HP} **4655** hLength of DHW Heating Period t_{DHW} **8760** h

Use characteristic values entered (check if appropriate)?

xDesign Output P_{Nom} (Rating Plate)**400** kW

Installation of Boiler (Outdoor: 0, Indoor: 1)

0**Input Values (Oil and Gas Boiler)**Boiler Efficiency at 30% Load $\eta_{30\%}$ (Manufacturer)**92%**Boiler Efficiency at Nominal Output $\eta_{100\%}$ (Manufacturer)**91%**Standby Heat Loss Boiler at 70 °C $q_{b,70}$ (Manufacturer)**0,4%**Average Return Temperature Measured at 30% Load $t_{30\%}$ (Manufacturer)**40** °C**Input Values (Biomass Heat Generator)**Efficiency of Heat Generator in Basic Cycle η_{GZ} (Manufacturer)**60%**Efficiency of Heat Generator in Constant Operation η_{SO} (Manufacturer)**70%**Average Fraction of Heat Output Released to Heating Circuit $Z_{HC,m}$ (Manufacturer)**0,4**Temperature Difference Betw. Power-On and Power-Off Δt (Manufacturer)**30** KFor Interior Installations: Area of Mechanical Room A_{mech} (Project)**0** m²Useful heat output per basic cycle $Q_{N,GZ}$ (Manufacturer)**600,0** kWhAverage Power Output of the Heat Generator $Q_{N,m}$ (Manufacturer)**400,0** kW

Heat generator without pellets conveyor

Unit with regulation (no fan / no starting aid)

Heating energy demand for a basic machine cycle $Q_{HE,GZ}$ (Manufacturer)**12,02** kWhPower consumption in steady state operation $P_{el,SB}$ (Manufacturer)**6010** WUtilisation factor heat generator heating run $\eta_{H,G,K} = f_g * \eta_{IC}$ **89%**Utilisation factor heat generator DHW run $\eta_{TW,G,K} = \eta_{100\%} / f_{g,TW}$ **86%**Utilisation factor heat generator DHW & heating $\eta_{g,K}$ **88%**Final energy demand space heating $Q_{Final, HE} = Q_{H,W} * e_{H,G,K}$ **87022** kWh/aFinal energy demand DHW $Q_{Final, DHW} = Q_{DHW,W} * e_{TW,G,K}$ **59030** kWh/aTotal final energy demand $Q_{Final} = Q_{Final, DHW} + Q_{Final, HE}$ **146052** kWh/a

Annual primary energy demand

160657 kWh/aAnnual CO₂-Equivalent Emissions**36513** kg/akWh/(m²a)**31,5** kWh/(m²a)**34,7** kWh/(m²a)**7,9** kg/(m²a)

Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Se		Building type:	School1	
	Treated Floor Area A _{TFA} :		4630		m²
Covered fraction of space heating demand	(PE Value worksheet)	0%			
Annual heating demand kWh/a	Q _H (DHW+Distribution)	80824		kWh	
Solar contribution for space heating	η _{Solar, H} (SolarDHW worksheet)	4%			
Effective Annual heating demand	Q _{H,WI} =Q _H *(1-η _{Solar, H})	0		kWh	
Covered Fraction of DHW Demand	(PE Value worksheet)	0%			
DHW Demand	Q _{DHW} (DHW+Distribution)	59405		kWh	
Solar contribution for DHW	η _{Solar, DHW} (SolarDHW worksheet)	15%			
Effective DHW Demand	Q _{DHW,WI} =Q _{DHW} *(1-η _{Solar, DHW})	0		kWh	
Heat source		None			
Primary Energy factor	(Data worksheet)			kWh/kWh	
CO ₂ -Emissions factor (CO ₂ -Equivalent)	(Data worksheet)	0		g/kWh	
Utilisation factor of heat transfer station	ha,HX				
		kWh/a		kWh/(m²a)	
Final energy demand heat generation	Q _{final} = Q _{Use} * e _{a,DH}	0		0,0	
Annual primary energy demand		0		0,0	
		kg/a		kg/(m²a)	
Annual CO ₂ -Equivalent Emissions		0		0,0	

Table of Primary Energy Factors and CO ₂ -Equivalent Emissions Factors of Various Energy Carriers				
Energy Type		Energy Carrier	PE (non-regenerative) kWh _{Prim} /kWh _{Final}	CO ₂ GEMIS 3.0 kg/kWh _{Final}
Fuel Source	1	None		
	2	Oil	1,1	0,31
	3	Natural Gas	1,1	0,25
	4	LPG	1,1	0,27
	5	Hard Coal	1,1	0,44
Electricity	6	Wood	0,2	0,05
	7	Electricity-Mix	2,6	0,68
	8	Electricity from Photovoltaics	0,7	0,25
District Heat	1	None	0	0
	2	Hard Coal CGS 70% PHC	0,8	0,24
	3	Hard Coal CGS 35% PHC	1,1	0,32
	4	Hard Coal HS 0% PHC	1,5	0,41
Gas CGS	5	Gas CGS 70% PHC	0,7	-0,07
	6	Gas CGS 35% PHC	1,1	0,13
	7	Gas HS 0% PHC	1,5	0,32
Heating Oil-EL CGS	8	Oil CGS 70% PHC	0,8	0,1
	9	Oil CGS 35% PHC	1,1	0,25
	10	Oil HS 0% PHC	1,5	0,41

Data Source: DIN V 4701-10/GEMIS 4.14

Heat Generator			Selection of gas type	
Nr.	Type		Nr.	Type
1	None		1	Natural Gas
2	Improved gas condensing boiler		2	LPG
3	Improved oil condensing boiler		3	
4	Condensing boiler gas			
5	Condensing boiler oil			
6	Low Temperature Boiler Gas			
7	Low Temperature Boiler Oil			
8	Wood Log Burning (Direct and Indirect Release of Heat)			
9	Wood Pellet Burning (Direct and Indirect Release of Heat)			
10	Wood Pellet Burning (Only Indirect Release of Heat)			
11	Reserve			

Dishwashing		
1	Washing	
2	DHW Connection	
	Cold water connection	

Clothes Drying		Availability Electricity	Availability Evaporation
1	Clothesline	1	1
2	Drying Closet (cold!)	1	1
3	Drying Closet (cold!) in Exhaust Air	0,9	0,9
4	Condensation Dryer	0,7	0
5	Electric Exhaust Air Dryer	1	1
6	Gas Exhaust Air Dryer	1	1

Cooking		Electric Fraction	Primärenergiefaktor	CO ₂ factor
1	Electricity	100%	2,6	0,68
2	Natural Gas	0%	1,1	0,25
3	LPG	0%	1,1	0,27